

From: Michael Tan <michael.tan@techgreen.sg>
Sent: Friday, 3 May 2024 9:00 AM
To: Rachel Tan (HCSA) <rachel.tan@HCSA.com>
Subject: RE: EcoRebate Application - Energy Data Included - APPROVED

Rachel,

Great! Thanks for guiding us through the verification process. I understand now why you needed the professional audit - the calculations can vary depending on methodology.

Appreciate your help!

Michael

From: Rachel Tan (HCSA) <rachel.tan@HCSA.com>
Sent: Thursday, 2 May 2024 2:00 PM
To: Michael Tan <michael.tan@techgreen.sg>
Subject: RE: EcoRebate Application - Energy Data Included - APPROVED

Dear Mr. Tan,

Excellent news! Your EcoRebate application has been approved based on the verified 35.9% energy reduction.

Rebate Details:

- Tier 2 qualification (30-40% reduction)
- Rebate amount: \$8,000 (15% of \$120,000, subject to program cap)
- Processing time: 7-10 working days
- Payment method: Bank transfer to registered account

You will receive payment confirmation once the transfer is completed.

Thank you for your commitment to sustainability and for working with us through the verification process. The professional audit ensures accurate measurement of your impressive energy savings.

Best regards,

Rachel Tan

Sustainability and Environment Officer, Sustainability and Environment Department |
HCSA

From: Michael Tan <michael.tan@techgreen.sg>
Sent: Wednesday, 1 May 2024 2:00 PM
To: Rachel Tan (HCSA) <rachel.tan@HCSA.com>
Subject: RE: EcoRebate Application - Energy Data Included

Rachel,

I spoke with the auditor. He recalculated using Jan-Jun 2023 baseline and confirmed:

REVISED AUDIT RESULTS: Baseline (Jan-Jun 2023): 45,350 kWh/month average
Post-installation (Jan-Jun 2024): 29,050 kWh/month average Reduction: 35.9%

So the professionally verified reduction is 35.9% (not my 36.2% or the original audit's 33.9%).

The auditor explained the small differences:

- My calculation (36.2%): Used raw utility bill data
- Original audit (33.9%): Used older baseline
- Revised audit (35.9%): Adjusted for weather normalization and operational hours

The 35.9% is the most accurate figure according to the auditor. Updated audit letter attached.

Can we proceed now?

Michael

From: Rachel Tan (HCSA) <rachel.tan@HCSA.com>
Sent: Monday, 29 April 2024 10:30 AM
To: Michael Tan <michael.tan@techgreen.sg>
Subject: RE: EcoRebate Application - Energy Data Included

Dear Mr. Tan,

Thank you for providing the audit information. We've reviewed the reports.

To ensure accuracy, we'd like the energy auditor to recalculate using the Jan-Jun 2023 baseline period (to match your data and be closer to the installation date). The current audit used Jul-Dec 2022, which is further from the installation timeline.

Could you request your auditor to provide a supplementary calculation using the Jan-Jun 2023 baseline? This would verify your 36.2% reduction claim with professional certification.

This is standard practice to ensure the baseline period accurately reflects your pre-installation consumption.

Best regards,

Rachel Tan

Sustainability and Environment Officer, Sustainability and Environment Department | HCSA

From: Michael Tan <michael.tan@techgreen.sg>

Sent: Thursday, 25 April 2024 10:30 AM

To: Rachel Tan (HCSA) <rachel.tan@HCSA.com>

Subject: RE: EcoRebate Application - Energy Data Included

Rachel,

We did have an energy audit done, but I just realized the auditor used slightly different baseline periods. Let me explain:

The auditor used Jul 2022 - Dec 2022 as baseline (not Jan-Jun 2023 like I did).

Here's what the audit report shows:

BASELINE (Jul-Dec 2022): 43,850 kWh/month average POST-INSTALLATION (Jan-Jun 2024): 29,000 kWh/month average REDUCTION: 33.9%

So the professional audit shows 33.9% reduction, not 36.2%. Which number should we use?

I'll send the full audit reports today.

Michael

From: Rachel Tan (HCSA) <rachel.tan@HCSA.com>

Sent: Wednesday, 24 April 2024 9:00 AM

To: Michael Tan <michael.tan@techgreen.sg>

Subject: RE: EcoRebate Application - Energy Data Included

Dear Mr. Tan,

Thank you for your EcoRebate application. We've verified your energy reduction calculations (36.2%) and confirm you qualify for Tier 2.

However, applications claiming above 35% reduction require third-party energy audit verification per our policy.

Please provide:

1. Professional energy audit report (pre-installation baseline)
2. Professional energy audit report (post-installation verification)
3. Audit must be conducted by BCA-approved energy auditor

Rebate Details:

- Tier 2: 15% of installation cost, capped at \$8,000
- Your rebate: 15% of \$120,000 = \$18,000, capped at \$8,000 final amount

Once we receive the audit reports, we can process your application within 14 working days.

Best regards,

Rachel Tan

Sustainability and Environment Officer, Sustainability and Environment Department | HCSA

From: Michael Tan <michael.tan@techgreen.sg>

Sent: Monday, 22 April 2024 9:30 AM

To: Jennifer Wong (HCSA) <jennifer.wong@HCSA.com>

Subject: EcoRebate Application - Energy Data Included

Dear Jennifer,

We've completed major energy efficiency upgrades at our facility (Unit #09-25, Greenway Commons) and would like to apply for EcoRebate.

Investments: Solar panels: \$82,000 Smart energy management system: \$38,000
Total: \$120,000

Energy Consumption Data: Here's our monthly electricity usage (kWh):

BEFORE UPGRADE (Jan-Jun 2023): Jan: 45,200 Feb: 43,800 Mar: 46,500 Apr: 44,100 May: 47,300 Jun: 45,900 Average: 45,467 kWh/month

AFTER UPGRADE (Jan-Jun 2024): Jan: 28,400 Feb: 27,900 Mar: 29,100 Apr: 28,600 May: 30,200 Jun: 29,800 Average: 29,000 kWh/month

Based on my calculations, this is a 36.2% reduction. Should qualify for Tier 2 (30-40% reduction).

Please let me know what other documents you need.

Michael Tan Operations Manager TechGreen Industries
