

From: Marcus Lim (HCSA) <marcus.lim@HCSA.com>

To: Reza Mahmoudi <reza.site.ops@yahoo.com>

Date: Tuesday, 11 March 2025 10:02 AM

Subject: RE: PTW for tomorrow work - urgent pls

Dear Reza,

Thank you for submitting your permit request. After reviewing the details, the work described — entry into the enclosed underground water retention tank at Block C — falls under the Confined Space Entry category under our permit-to-work system (Form PTW-CS-80, SOP-CO-003 Section 3.1).

Confined space entry permits require a minimum of 48 hours' advance submission. Your submission was received at approximately 4:00 PM on 10 March, for a 7:00 AM start on 12 March — approximately 15 hours' notice, which does not satisfy the requirement.

The permit cannot be approved and the work scheduled for tomorrow morning cannot proceed.

Please resubmit at least 48 hours before your new intended start date.

The following must also be confirmed in your resubmission:

- Atmospheric testing results
- Standby person assigned
- Rescue equipment on site
- Communication system in place

Note that approval authority for confined space permits rests with the HCSA HSE Department.

Do reach out if you need assistance with the resubmission.

Regards,

Marcus Lim

HSE Senior Officer, HSE Department | HCSA

marcus.lim@HCSA.com

From: James Tan (HCSA) <james.tan@HCSA.com>
To: Marcus Lim (HCSA) <marcus.lim@HCSA.com>
Date: Tuesday, 11 March 2025 9:15 AM
Subject: RE: FW: PTW for tomorrow work - urgent pls

Marcus,

Confirmed — the description matches a confined space as defined under SOP-CO-003 Section 3.1: enclosed space not designed for continuous occupancy, limited entry/exit, potential atmospheric hazards, depth exceeding 1.2m. The water retention tank clearly qualifies.

The submitted form cannot be approved. Per the SOP, confined space permits require 48 hours minimum advance submission. The submission falls well short of this. Work cannot proceed on 12 March.

Please inform the site coordinator that they must resubmit at least 48 hours before the new intended start date, and that the HCSA HSE Department is the approval authority for confined space entries. Additional requirements also apply — atmospheric testing, standby person, rescue equipment, and a communications system must all be confirmed.

James Tan

HSE Officer, HSE Department | HCSA

james.tan@HCSA.com

From: Marcus Lim (HCSA) marcus.lim@HCSA.com
To: James Tan (HCSA) <james.tan@HCSA.com>
Date: Tuesday, 11 March 2025 8:30 AM
Subject: FW: PTW for tomorrow work - urgent pls

Hi James,

Please see the request below. The work described sounds like a confined space entry based on the location — enclosed, underground, >1.2m depth. If that is the case, the applicable permit (PTW-CS-80) requires 48 hours' advance submission, not the standard 24 hours.

The client submitted around 4pm yesterday (10 Mar) for a 7am start on 12 Mar — approximately 15 hours' notice, which would not meet the 24-hour requirement even for a standard general permit.

Please advise whether we should reject the request outright or hold pending clarification on scope.

Marcus Lim

HSE Senior Officer, HSE Department | HCSA

marcus.lim@HCSA.com

From: Reza Mahmoudi <reza.site.ops@yahoo.com>

To: Marcus Lim (HCSA) <marcus.lim@HCSA.com>

Date: Tuesday, 11 March 2025 7:52 AM

Subject: PTW for tomorrow work - urgent pls

Hi Marcus,

We need to do some work tomorrow morning (12 Mar, starting 7am) inside the water retention tank at Block C basement. It's that enclosed space underground, about 3.5m deep. We submitted the form yesterday afternoon around 4pm.

Can u confirm its approved? Our crew is ready.

Thanks

Reza

Site Coordinator, Bukit limau Infrastructure Package

reza.site.ops@yahoo.com