

From: Marcus Lim (HCSA) <marcus.lim@HCSA.com>

To: Reza Mahmoudi <reza.site.ops@yahoo.com>

Date: Tuesday, 11 March 2025 10:02 AM

Subject: RE: PTW for tomorrow work - urgent pls

Dear Reza,

Thank you for submitting your permit request. After reviewing the details, the work described — entry into the enclosed underground water retention tank at Block C — falls under the Confined Space Entry category under our permit-to-work system (Form PTW-CS-80, SOP-CO-003 Section 3.1).

Confined space entry permits require a minimum of 48 hours' advance submission. Your submission was received at approximately 4:00 PM on 10 March, for a 7:00 AM start on 12 March — approximately 15 hours' notice, which does not satisfy the requirement.

The permit cannot be approved and the work scheduled for tomorrow morning cannot proceed.

Please resubmit at least 48 hours before your new intended start date.

The following must also be confirmed in your resubmission:

- Atmospheric testing results
- Standby person assigned
- Rescue equipment on site
- Communication system in place

Note that approval authority for confined space permits rests with the HCSA HSE Department.

Do reach out if you need assistance with the resubmission.

Regards,

Marcus Lim

HSE Senior Officer, HSE Department | HCSA

marcus.lim@HCSA.com

From: Reza Mahmoudi <reza.site.ops@yahoo.com>

To: Marcus Lim (HCSA) <marcus.lim@HCSA.com>

Date: Tuesday, 11 March 2025 7:52 AM

Subject: PTW for tomorrow work - urgent pls

Hi Marcus,

We need to do some work tomorrow morning (12 Mar, starting 7am) inside the water retention tank at Block C basement. It's that enclosed space underground, about 3.5m deep. We submitted the form yesterday afternoon around 4pm.

Can u confirm its approved? Our crew is ready.

Thanks

Reza

Site Coordinator, Bukit limau Infrastructure Package

reza.site.ops@yahoo.com