

From: Aaron Kumar (HCSA) <aaron.kumar@HCSA.com>

Sent: Tuesday, 19 March 2024 5:00 PM

To: James Tan (HCSA) <james.tan@HCSA.com>

Cc: Michael Chen (HCSA) <michael.chen@HCSA.com>

Subject: Level 9 Electrical Inspection - Report

James,

Inspection completed. As suspected, the issue is in the main circuit panel:

- Faulty circuit breaker causing intermittent power loss
- Affecting all Level 9 common area lighting
- Explains why individual fixture repairs didn't solve the problem

Solution:

- Replace faulty circuit breaker
- Rewire affected circuits
- Install surge protector
- Estimated completion: Thursday, March 21

Work will be done overnight (10pm-6am) to minimize tenant disruption.

I'll update the tenant directly.

Aaron

Senior Commercial Properties and Maintenance Officer, Commercial Properties and Maintenance Department | HCSA

From: Aaron Kumar (HCSA) <aaron.kumar@HCSA.com>

Sent: Monday, 18 March 2024 2:15 PM

To: James Tan (HCSA) <james.tan@HCSA.com>

Cc: Michael Chen (HCSA) <michael.chen@HCSA.com>

Subject: RE: Extremely Disappointed with Service - URGENT

James,

I checked the maintenance records. You're right - we've been treating the symptoms, not the root cause.

I've scheduled a comprehensive electrical inspection for Level 9 common area tomorrow (March 19) with our senior electrician. He'll inspect the entire circuit, not just the fixtures.

I suspect it's a wiring issue in the main panel, which would explain why the problem keeps recurring.

Inspection tomorrow 9am-12pm. I'll provide a full report by end of day Tuesday.

Aaron

Aaron Kumar

Senior Commercial Properties and Maintenance Officer, Commercial Properties and Maintenance Department | HCSA

From: James Tan (HCSA) <james.tan@HCSA.com>
Sent: Monday, 18 March 2024 11:30 AM
To: Michael Chen (HCSA) <michael.chen@HCSA.com>
Cc: Aaron Kumar (HCSA) <aaron.kumar@HCSA.com>
Subject: RE: Extremely Disappointed with Service - URGENT

Michael,

I reviewed the complaint history for Corporate Services International (Unit #09-16):

Complaint 1 - January 2024:

- Issue: Common area lighting on Level 9 flickering
- Status: CLOSED - Replaced bulbs on Jan 15
- Resolution: Marked as resolved

Complaint 2 - February 2024:

- Issue: Same lighting issue recurring
- Status: CLOSED - Electrician attended Feb 10, replaced ballast
- Resolution: Marked as resolved

Complaint 3 - March 2024 (current):

- Issue: Lighting still faulty
- Status: OPEN - Just received

This is indeed their **3rd complaint** about the same issue. The problem is recurring despite two previous repair attempts. This suggests a deeper electrical issue that hasn't been properly diagnosed.

Aaron - this needs a comprehensive electrical inspection, not just quick fixes. Can you arrange for a senior electrician to conduct a thorough assessment?

Michael - I'll call the tenant personally to apologize and explain our action plan.

James

James Tan

Commercial Properties and Maintenance Officer, Commercial Properties and Maintenance Department | HCSA

From: Michael Chen (HCSA) <michael.chen@HCSA.com>
Sent: Monday, 18 March 2024 9:00 AM
To: James Tan (HCSA) <james.tan@HCSA.com>
Cc: Aaron Kumar (HCSA) <aaron.kumar@HCSA.com>
Subject: FW: Extremely Disappointed with Service - URGENT

Hi James,

Escalating this complaint from Unit #09-16, Verdant Plaza. The tenant claims this is their third issue and previous matters haven't been resolved properly.

Could you check how many complaints we've received from this tenant? I need to understand the history before responding.

Aaron - can you also check on the lighting issue they mentioned?

This needs urgent attention.

Michael

Michael Chen

Senior Commercial Properties and Maintenance Officer, Commercial Properties and Maintenance Department | HCSA

From: Andrew Lim <andrew.lim@corporateservices.sg>
Sent: Friday, 15 March 2024 4:30 PM
To: Michael Chen (HCSA) <michael.chen@HCSA.com>
Subject: Extremely Disappointed with Service

Michael,

I am extremely disappointed with the service we've been receiving. This is the THIRD time we've had issues that haven't been properly resolved.

We've reported the faulty common area lighting on our floor twice already, and it's still not fixed. This is unacceptable and affecting our business operations.

I expect immediate action or I will escalate this to your management.

Andrew Lim Corporate Services International Unit #09-16, Verdant Plaza