

M.P.P.K.V.V. C. LTD. INDORE CIRCLE																			
S.N o	Name of Circle	NAME OF DIVISION	Name of EHV 5/s or 33/11 KV 5/s	Line KV Capacity (33 or 11)	Name of 33 KV / 11 KV feeder	Planned shutdown			DATE- 08.11.2019			Reason for Planned Shutdown (Maintenance/Erection work/ FSP / Safety purpose etc.)	Shutdown Approved by -	Approval Granted to-	Alternate Supply Arrangements are available or not (Yes/No)	It has been Reported on Whatsapp Group	Demand in MW affected due to Shutdown.	Remark(Are as affected)	Remark(Areas affected)
						Group (for 33KV) / Category (for 11 KV)	Date of Planned Shutdown	Duration of to	Total Duration										
1	INDORE CITY	WEST	SECTOR-A	11KV	AVANTIKA NAGER	CHQ	08.11.2019	12:30	13:15	0:45	FOR 100 KVA DTR REPLACEMENT WORK AT OPPOSITE MP BEER SECTOR-A SAWER ROAD	SE CITY	AE (HTM)	NO	YES	0.65		AVANTIKA NAGER Area	
2	INDORE CITY	WEST	CITY CONTROL ROOM	11KV	11KV MAIN-2	CHQ	08.11.2019	06:00	06:15	0:15	FOR 11 KV SHIVVILAS I/C ISOLATER I/C SIDE Y PHASE CLAMP RED HOT	SE CITY	AE (HTM)	NO	YES	0.26		11KV SHIVVILAS & 11KV SAWER ROAD	
3	INDORE CITY	WEST	Gandhi nagar	11 KV	11kv Budhania,boriya & bhangda	CHQ	08.11.2019	06:30	06:50	00:20	BUSBAR I/C ISOLATER R-PHASEMAINTENANCE RED HOT WORK	SE CITY	AE (HTM)	NO	YES	0.65		BHANGDA AREA	
4	INDORE CITY	North	33/11 KV MANGLIYA	11 KV	11 KV SDA FEEDER	CHQ	08.11.2019	07:00	09:00	02:00	6 NO. POLE ERECTION & 1 NO. DTR CHARGING WORK UNDER IPDS NEAR SINGAPUR MATCH	SE CITY	AE (HTM)	NO	YES	0.45		SDA COMPOUND	
5	INDORE CITY	North	33/11KV MPSRTC	11KV	11KV Kalali	CHQ	08.11.2019	11:00	12:00	01:00	For 315 KVA DTR Replacement work at Patnipura	SE CITY	AE (HTM)	NO	YES	0.5		Y.N.Road, Malwa Mill Chouraha, Anaj Mandi, GSTIS Colony, Gokul Apprtt., Charak Hospital, Ahilyamata colony, Ranisati Gate, Sukhsagar Apprtt., Bima colony, Amol hospital, Prakash Tower	
6	INDORE CITY	EAST	BTC GRID	11KV	BASKET BALL	CHQ	08.11.2019	06:30	09:00	02:30	TREE CUTTING & HT CONSUMERS CONNECTION CHAKE AND FOUR POLE MAINTENANCE WORK.	SE CITY	AE (HTM)	NO	YES	0.95		AGRAWAL STORE, DM TOWER, CARE WELL HOSPITAL AND VIKAS PRADHIKARN ETC.	
7	INDORE CITY	EAST	TUKOGANJ	11KV	TEL. ESSENTIAL	CHQ	08.11.2019	07:00	08:00	01:00	FOUR POLE MAINTENANCE WORK.	SE CITY	AE (HTM)	NO	YES	0.8		BAL VINAY MANDIR SCHOOL, VIMAL VINAY BUILDING, YASHWANT COLONY AND CLUB ETC.	
8	INDORE CITY	EAST	MAHALAXMI	11KV	TULSI NAGAR	CHQ	08.11.2019	11:00	13:00	02:00	FOR VCB REPLACEMENT WORK.	SE CITY	AE (HTM)	NO	YES	0.45		TULASI NAGAR NAMRATA GARDEN,WWW SKY SHOP, ANKUR AANGAN AND RR AVENUE ETC.	
9	INDORE CITY	EAST	MAHALAXMI	11KV	KHAJRANA(R)	CHQ	08.11.2019	10:30	11:00	00:30	LOAD SHEDDING / LOAD MANAGEMENT WORK.	SE CITY	AE (HTM)	NO	YES	0.5		SAIKRUPA, RAMKRUSHAN BAG, YADAV SHOW ROOM AND MR-10 ETC.	
10	INDORE CITY	South Division	Univercity	11 kv	Khandwa naka	CHQ	08.11.2019	08:00	12:00	04:00	11 kv Line Conductor Stringing work under Kshema power IPDS work at Khandwa Naka Road	SE CITY	AE (HTM)	NO	YES	1.28		SOYABEAN CENTER, NANAK NAGAR, 1SHIVAM NAGAR,	
11	INDORE CITY	South Division	Univercity	11 kv	Indrapuri	CHQ	08.11.2019	07:00	11:00	04:00	Tree cutting & line maintenance	SE CITY	AE (HTM)	NO	YES	1.63		Water tank, monica plaza, 329 indrapuri colony, 299 indrapuri colony,	
12	INDORE CITY	Central	132kv chambal	33KV	Rajmohila-2	CHQ	08.11.2019	10:00	10:45	00:45	ME B-PHASE RED HOT WORK	SE CITY	AE (HTM)	YES	YES	NIL		NIL	
13	INDORE CITY	Central	Rajmohila	11 kv	MHOW & AIR	CHQ	08.11.2019	11:30	13:00	01:30	MAINTENANCE & B-PHASE VCB POLE RED HOT WORK	SE CITY	AE (HTM)	NO	YES	0.5		MHOW & AIR AREA	
14	INDORE CITY	Central	NAGIN NAGAR	33KV	33KV NAGIN NAGAR- 2(GUMASTA O/G)	CHQ	08.11.2019	14:00	14:40	00:40	B-PHASE VCB POLE RED HOT WORK	SE CITY	AE (HTM)	YES	YES	NIL		NIL	
15	INDORE CITY	Central	GUMASTA NAGAR	11 kv	IDA-1	CHQ	08.11.2019	15:00	15:30	00:30	Y-PHASE ISOLATER RED HOT WORK	SE CITY	AE (HTM)	NO	YES	0.5		IDA-1 AREA	