

M.P.P.K.V.V. C. LTD. INDORE CIRCLE															
Planned Shutdown 01.01.2019															
S.No	Name of Circle	NAME OF DIVISION	Name of EHV S/s or 33/11 KV S/s	Line KV Capacity (33 or 11)	Name of 33 KV / 11 KV feeder	Group (for 33KV) / Category (for 11 KV)	Date of Planned Shutdown	Duration of Planned Shutdown		Total Duration	Reason for Planned Shutdown (Maintenance/Erection work/ FSP / Safety purpose etc.)	Alternate Supply Arrangements are available or not	Demand in MW affected due to Shutdown.		Areas affected
								From	to						
1	INDORE CITY	North	33/11 KV vistara grid	33 KV	33 KV SANCHANAGAR 2ND	VIII	01.01.2019	10:30	10:45	0:15	FOR VCB WORK BY STM TEAM WORK	NO	2.5		ALL FEEDER AFFECTED
2	INDORE CITY	North	33/11 KV MODERN	5MVA	5 MVA PTR NO. 3	-	01.01.2019	6:30	6:45	0:15	FOR HEAVY RED HOT WORK	NO	1		C-2
3	INDORE CITY	EAST	DRP LINE	11KV	NAGAR NIGAM	CHQ	01.01.2019	9:30:00	10:00:00	0:30:00	FOR X-MER INSTALL WORK.	No	0.65		LUCKY BUILDERS, NAGAR NIGAM AND SABJI MANDI , SUBHASH MARG ETC
4	INDORE CITY	EAST	GOYAL NAGAR	33KV	SANCHAR NAGAR - I (INCOMMING FEEDER)	CHQ	01.01.2019	7:00:00	7:15:00	0:15:00	33KV INCOMMING FEEDER VCB ON & OFF PROBELM WORK BY STM.	YES.	Nil		WILL BE SUPPLY CHANGE OVER AVALIBEL.
5	INDORE CITY	EAST	SC.NO.140 TALAB WALA	11KV	GANESH DHAM	CHQ	01.01.2019	7:45:00	8:00:00	0:15:00	FOR SCADA CRP FEEDER ON & OFF PROBELM WORK BY STM.	No	0.95		ASHISH NAGAR , BRAJESHWARI NX, GANESH DHAM AND SHUBHLABH PRIMIUM ETC
6	INDORE CITY	EAST	SC.NO.140 TANKI WALA	11KV	PASSPORT FEEDER	CHQ	01.01.2019	8:30:00	8:45:00	0:15:00	FOR VCB AUTOMATIC ON PROBELM WORK BY STM.	No	0.45		11KV PASSPORT FEEDER AFFECTED.