

M.P.P.K.V.V. C.LTD. INDORE CIRCLE																			
S.No	Name of Circle	NAME OF DIVISION	Name of EHV S/s or 33/11 KV S/s	Line KV Capacity (33 or 11)	Name of 33 KV / 11 KV feeder	Planned shutdown			DATE-01.12.2019			Reason for Planned Shutdown (Maintenance/Erection work/ PSP / Safety purpose etc.)	Shutdown Approved by -	Approval Granted to-	Alternate Supply Arrangements are available or not (Yes/No)	It has been Reported on Whatsapp Group	Demand in MW affected due to Shutdown.	Remark(Areas affected)	Remark(Areas affected)
						Group (for 33KV) / Category (for 11 KV)	Date of Planned Shutdown	Duration of From - to	Total Duration										
1	INDORE CITY	South Division	Indra complex	11 kv	main no.2	CHQ	01.12.2019	15:00	15:30	0:30		VCB work by STM	SE CITY	AE(Maint.)	No	YES	1.56		jaora compound & shankar bagh feeder
2	INDORE CITY	South Division	Indra complex	33 kv	5 mva PTR no.2	CHQ	01.12.2019	15:30	16:00	0:30		LV side red hot work	SE CITY	AE(Maint.)	No	YES	1.56		jaora compound & shankar bagh feeder
3	INDORE CITY	South Division	Indra complex	11 kv	TS no.2	CHQ	01.12.2019	16:00	16:30	0:30		CT Replacement work by STM	SE CITY	AE(Maint.)	No	YES	0.75		Gadi adda , railway crossing & other area
4	INDORE CITY	South Division	Indra complex	11 kv	Shankar bagh	CHQ	01.12.2019	16:30	17:00	0:30		CT Replacement work by STM	SE CITY	AE(Maint.)	No	YES	0.77		shankar bagh ,murai mohalla harihan colony
5	INDORE CITY	South Division	Indra complex	33 kv	Daly college no.2 O/G	CHQ	01.12.2019	17:00	17:30	0:30		CT Replacement work by STM	SE CITY	AE(Maint.)	Yes	YES	nil		nil
6	INDORE CITY	EAST	SATYA SAI	11KV	MALVIYA NAGAR ,PHOENIX GREEN & PRESS COMPLEX OLD	CHQ	01.12.2019	6:30	9:00	2:30		FOR 11 KV FEEDER M.E. REPLACEMENT WORK	SE CITY	AE(Maint.)	NO.	YES	0.65		DEWAS NAKA , DOORSANCHAR, ORBITE MALL AND PU-4,MALVIYA NAGAR GALI NO. 1,2 , CHANDRA NAGAR ,BARKHA SCHOOL ETC.
7	INDORE CITY	EAST	SATYA SAI	11KV	SCH NO. 94	CHQ	01.12.2019	9:30	10:30	1:00		FOR 11 KV FEEDER M.E. REPLACEMENT WORK	SE CITY	AE(Maint.)	NO.	YES	0.48		CLASSIC PURNIMA, SHEETAL NAGAR, CHIKITK NAGAR AND GULAB BAG COLONY ETC.
8	INDORE CITY	EAST	SATYA SAI	11KV	VELOCITY	CHQ	01.12.2019	10:30	11:30	1:00		FOR 11 KV FEEDER M.E. REPLACEMENT WORK	SE CITY	AE(Maint.)	NO.	YES	0.57		MAHIDPUR WALA, VELLOCTY SINEMA AND MAHAK VATIKA, ARAWAL SHOW ETC.
9	INDORE CITY	EAST	SHALIMAR TOWNSHIP	11KV	SHALIMAR TOWNSHIP	CHQ	01.12.2019	12:00	13:00	1:00		FOR 11 KV FEEDER M.E. REPLACEMENT WORK	SE CITY	AE(Maint.)	NO.	YES	0.69		SHALIMAR TOWN, BAPU NAGAR AND GULAB BAG
10	INDORE CITY	Central	Bijalpur	11 KV	Sanjay nagar	CHQ	01.12.2019	08:00	11:00	03:00		1 No's 11 KV Pole Erection & Conductor Stringing At Jitu Patwari Office Road Mazzid Soni garden Bijalpur Mini School Under IPDS	SE CITY	AE(Maint.)	No	YES	0.45		Sanjay nagar, Gram Bijalpur
11	INDORE CITY	Central	Rau	11 KV	Rangwasa	CHQ	01.12.2019	08:00	11:00	03:00		Due to 2 No. 11 KV Pole Erection & Structure Fitting Renovation DTR At Rau Industrial Area Under IPDS	SE CITY	AE(Maint.)	No	YES	0.36		Rau Industrial Area, Cancer Hospital. Dehri Area & ETC.
12	INDORE CITY	Central	Pragati nagar	11 KV	Siddhipuram	CHQ	01.12.2019	08:00	11:00	03:00		Due to 2 No. DTR Augmentation Work at Siddhipuram Colony Under IPDS	SE CITY	AE(Maint.)	No	YES	0.74		Vaishali nagar Ahilya nagar, Braj Vihar Colony, Siddhipuram & Etc
13	INDORE CITY	Central	Bijalpur	11 KV	Setelight	CHQ	01.12.2019	08:00	11:00	03:00		Due to 11 kv line Post monsoon Line maintenance Work	SE CITY	AE(Maint.)	No	YES	0.38		Setelight Town Ship,haydary Township.Maskin E Seftya & ETC
14	INDORE CITY	Central	Revenue Nagar	11 KV	Usha nagar	CHQ	01.12.2019	06:00	06:30	00:30		Due to VCB Pole R -Phase I/C Side Red Hot Work	SE CITY	AE(Maint.)	No	YES	0.94		Usha nagar,Mhow Naka. Usha nagar Ext. mahalaxmi mandir & Etc
15	INDORE CITY	Central	Bijalpur	33 KV	Bijalpur-1 I/C	CHQ	01.12.2019	07:00	07:30	00:30		Due to Four Pole Jumper Red hot Work at Rajendra nagar S/S	SE CITY	AE(Maint.)	Yes	YES	-		Supply Chang Over
16	INDORE CITY	Central	132 KV Chambal	33 KV	Rajmohalla-1	VIII	01.12.2019	13:00	13:30	00:30		Due to VCB Testing Work by STM	SE CITY	AE(Maint.)	Yes	YES	-		Supply Chang Over
17	INDORE CITY	WEST	AIRPORT	11KV	11 KV MAIN NO.-2	CHQ	01.12.2019	7:45	8:00	0:15		FOR 11 KV AIRPORT I/C ISOLATOR B-PHASE CLAMP RED HOT WORK	SE CITY	AE(Maint.)	NO	YES	0.24		11 KV BSP, H-LINK & AIRPORT
18	INDORE CITY	WEST	CITY CONTROL ROOM	11KV	11 KV MAIN NO.-3	CHQ	01.12.2019	6:30	7:00	0:30		FOR ISOLATOR R & B-PHASE CLAMP RED HOT WORK	SE CITY	AE(Maint.)	NO	YES	0.24		PLOGROUND - I & II, IT BUILDING
19	INDORE CITY	WEST	SANGAM NAGAR	11KV	33 KV Zinsi O/G	CHQ	01.12.2019	7:15	7:30	0:15		FOR ISOLATOR R & B-PHASE CLAMP RED HOT WORK	SE CITY	AE(Maint.)	Yes	YES	-		No Area Affected
20	INDORE CITY	WEST	ZINSI HAT	11 KV	GOVT PRESS	CHQ	01.12.2019	14:00	14:30	0:30		FOR C.T. WIRING WORK BY STM	SE CITY	AE(Maint.)	NO	YES	0.62		GOVT PRESS
21	INDORE CITY	WEST	BAJAJ KHANA	11 KV	11 KV MAIN	CHQ	01.12.2019	12:30	13:00	0:30		FOR VCB MECHANISM PROBLEM WORK BY STM	SE CITY	AE(Maint.)	NO	YES	0.62		BAJAJ KHANA & MTC
22	INDORE CITY	WEST	132 KV CHAMBAL	33 KV	L.T. INDUSTRIAL	CHQ	01.12.2019	8:30	9:00	0:30		FOR 33 KV SIDE B-PHASE RED HOT WORK AT EHV S/s	SE CITY	AE(Maint.)	NO	YES	0.15		15 NO's L.T. CONSUMER AFFECTED
23	INDORE CITY	North	33/11 kv SECTOR E	5 MVA	5 MVA PTR NO 1	CHQ	01.12.2019	09:00	10:00	01:00		FOR PTR MAINTENANCE WORK BY STM	SE CITY	AE(Maint.)	NO	YES	0.65		11 KV SAGAR & SECOTR B
24	INDORE CITY	North	33/11 kv SECTOR E	5 MVA	5 MVA PTR NO 2	CHQ	01.12.2019	10:00	11:00	01:00		FOR PTR MAINTENANCE WORK BY STM	SE CITY	AE(Maint.)	NO	YES	0.28		11 KV SECTOR E &E-1
25	INDORE CITY	North	33/11 kv SECTOR E	5 MVA	5 MVA PTR NO 3	CHQ	01.12.2019	12:30	13:30	01:00		FOR PTR MAINTENANCE WORK BY STM	SE CITY	AE(Maint.)	NO	YES	0.49		11 KV RURAL
26	INDORE CITY	North	33/11 kv SECTOR E	11 KV	11 KV SECTOR E-1	CHQ	01.12.2019	11:30	12:00	00:30		FOR VCB WORK BY STM	SE CITY	AE(Maint.)	NO	YES	0.75		Areas affected
27	INDORE CITY	North	33/11 kv SECTOR E	11 KV	11 KV SECTOR E	CHQ	01.12.2019	12:00	12:30	00:30		FOR VCB WORK BY STM	SE CITY	AE(Maint.)	NO	YES	0.68		Areas affected
28	INDORE CITY	North	33/11 kv MODERN	5 MVA	5 MVA PTR NO 1	CHQ	01.12.2019	14:00	15:00	01:00		FOR PTR MAINTENANCE WORK BY STM	SE CITY	AE(Maint.)	NO	YES	0.52		11 kv rural & b-1
29	INDORE CITY	North	33/11 kv MODERN	5 MVA	5 MVA PTR NO 3&4	CHQ	01.12.2019	15:00	15:30	00:30		FOR SILICA JAIL REPLACEMENT WORK BY STM	SE CITY	AE(Maint.)	NO	YES			11 kv c-1 & marimata & Choutha sansar
30	INDORE CITY	North	33/11 kv MODERN	11 KV	11 KV RURAL	CHQ	01.12.2019	15:30	16:00	00:30		FOR VCB WORK BY STM	SE CITY	AE(Maint.)	NO	YES			Areas affected
31	INDORE CITY	North	33/11 kv MAHAKAL	11 KV	11 KV MEHANDI PUR BALAJI	CHQ	01.12.2019	10:00	17:00	07:00		FOR CONDUCTOR REPLACEMENT WORK BY STC	SE CITY	AE(Maint.)	NO	YES			Areas affected
32	INDORE CITY	North	33/11 kv MAHAKAL	11 KV	11 KV UJJAIN	CHQ	01.12.2019	10:00	17:00	07:00		FOR SAFETY PURPOSE WORK ON 11 kv MEHANDI PUR BALAJI FEEDER BY STC	SE CITY	AE(Maint.)	NO	YES			Areas affected
33	INDORE CITY	North	220 KV NORTH ZONE	33 KV	33 KV ZONAL 1ST	IX	01.12.2019	10:00	17:00	07:00		FOR SAFETY PURPOSE BY STC	SE CITY	AE(Maint.)	NO	YES			14 HT CONSUMER AFFECTED
34	INDORE CITY	North	33/11 kv MODERN	11 KV	11 KV CHOUTHASANSAR	CHQ	01.12.2019	10:00	17:00	07:00		FOR CONDUCTOR REPLACEMENT WORK BY STC	SE CITY	AE(Maint.)	NO	YES			Areas affected
35	INDORE CITY	North	33/11 kv SECTOR C	11 KV	11 KV SHIVAM GAS	CHQ	01.12.2019	10:00	17:00	07:00		FOR CONDUCTOR REPLACEMENT WORK BY STC	SE CITY	AE(Maint.)	NO	YES			Areas affected
36	INDORE CITY	North	33/11 kv MODERN	11 KV	11 KV MARIMATA	CHQ	01.12.2019	10:00	17:00	07:00		FOR CONDUCTOR REPLACEMENT WORK BY STC	SE CITY	AE(Maint.)	NO	YES			Areas affected
37	INDORE CITY	North	220 NORTH ZONE	33 KV	33 KV VIJAY NAGAR NO. 1&2	VIII	01.12.2019	10:00	17:00	07:00		FOR CONDUCTOR REPLACEMENT WORK BY STC	SE CITY	AE(Maint.)	NO	YES	0.69		2 HT CONSUMER AFFECTED & SCHEME NO 78 GRID
38	INDORE CITY	North	33/11 kv SECTOR E	11 KV	11 KV SECTOR E-1	CHQ	01.12.2019	10:00	17:00	07:00		FOR CONDUCTOR REPLACEMENT WORK BY STC	SE CITY	AE(Maint.)	NO	YES	0.75		Areas affected
39	INDORE CITY	North	33/11 kv SECTOR E	11 KV	11 KV SECTOR E	CHQ	01.12.2019	10:00	17:00	07:00		FOR SAFETY PURPOSE BY STC	SE CITY	AE(Maint.)	NO	YES	0.67		Areas affected
40	INDORE CITY	North	33/11 kv SECTOR E	11 KV	11 KV RURAL	CHQ	01.12.2019	10:00	13:00	03:00		FOR SAFETY PURPOSE BY STC	SE CITY	AE(Maint.)	NO	YES	0.75		Areas affected
41	INDORE CITY	North	33/11 kv ELECTRONIC COM	33/11	33/11 kv ELECTRONIC COM (11 KV FEEDER ALL AFFECTED)	CHQ	01.12.2019	11:00	16:00	05:00		FOR PTR NO 2 REPLACEMENT WORK BY STC & FOR BRAKET INSTALLATION 5% SUPERVISION WORK CONTRACTOR NAME PANCHOU	SE CITY	AE(Maint.)	NO	YES	0.45		11 KV VEENA NAGAR & EC-2 & EC-1 & NANDA NAGAR & READYMED COM & BHAGIATH PUR & GAURI NAGAR & CLREK COLONY