M.P.P.K.V.V. C. LTD. INDORE CIRCLE Planned shutdown DATE- 25.09.2019																	
S.N Name of Circle	NAME	OF Name of EHV S/s ON or 33/11 KV S/s	Line KV Capacity (33 or 11)	Name of 33 KV / 11 KV feeder		Date of Planned	Dura From	tion of Du		Reason for Planned Shutdown (Maintenance/Erection work/ FSP / Safety purpose etc.)	Shutdown Approved by -	Approval Granted to-	Alternate Supply Arrangements are available or not (Yes/No)	It has been Reported on Whatsapp Group	Demand in MW affected due to Shutdown.	Remark(Are	Remark(Areas affected)
1 INDORE CITY	7	ral Gumasta nagar	11KV	Sirpur	CHQ	25.09.2019			3:00	Due to 2 No. DTR installation Work At Nalle Wali DP Noorani nagar Under IPDS	SE CITY	AE(Maint.)	No	YES	0.5	Paper Declared	Noorani nagar, Green park Ambar nagar Geeta nagar
2 INDORE CITY	Cent	ral Rajendra nagar	11KV	Annapurna	СНО	25.09.2019	8:00	11:00	3:00	Due to 3 No. Pole Eraction & 3 Span Conductor Stringing Work at Takshila & Woman Collage Under IPDS	SE CITY	AE(Maint.)	No	YES	0.45	Paper Declared	takshila parisar, Dhanvantri nagar, Rajendra nagar, Waman Polotecnic Collage & ETC
3 INDORE CITY	Cent	ral Navda panth	11KV	City IP	CHQ	25.09.2019	8:00	11:00	3:00	4No. Pole Erection work & 5 Span Conductor Stringing work Under IPDS	SE CITY	AE(Maint.)	No	YES	0.65	Paper Declared	Village sihasa,Village Bank,ahmed nagar,PK Bandhu compound,Dhar Road
4 INDORE CITY	Cent	ral Footi kothi	11KV	Ahirkhedi	CHQ	25.09.2019	13:00	15:00	2:00	Due to 2 No. DTR Charging & 4 No. Pole Erection Work At Ahirkhedi Gram & kakad Under IPDS	SE CITY	AE(Maint.)	No	YES	0.4	Paper Declared	Ahirkhedi, Gram Ahirkhedi kakad, Ht Conn. Shradha Saburi Colony, Vidur nagar, Choudhary market & Etc
5 INDORE CITY	Cent	ral Gumasta nagar	11KV	Dravin nagar	СНО	25.09.2019	8:00	11:00	3:00	4 Span Counductor stringing & Gaurding Tighting (Near Substation & Dravin nagar Nagar Nigam Zone) Under IPDS	SE CITY	AE(Maint.)	No	YES	0.35	Paper Declared	Dravin nagar, nakoda Chook, Kut-kut Bhawan, Sch no 71 & Etc
6 INDORE CITY	Cent	ral Revenue nagar	11KV	Vishvkarma Nagar	CHQ	25.09.2019	8:00	11:00	3:00	Due to 2 No. DTR Augmantataion Work at Vishvkarma nagar Under IPDS	SE CITY	AE(Maint.)	No	YES	0.25	Paper Declared	bank Colony, narendra tiwari marg, Vishvkarma nagar & ETC
7 INDORE CITY	Cent	ral Annapurna	11KV	Silver Aux	CHQ	25.09.2019	10:00	12:00	2:00	Due to Defective ME Replacement Work at Grid	SE CITY	AE(Maint.)	No	YES	0.45		bank Colony, narendra tiwari marg, Vishvkarma nagar & ETC
8 INDORE CITY	Cent	ral Annapurna	11KV	Bhawanipur	CHQ	25.09.2019	10:00	11:00	1:00	Due to Double CKT.With Silver AUX For Safety purpose	SE CITY	AE(Maint.)	No	YES	0.5		bank Colony, narendra tiwari marg, Vishvkarma nagar & ETC
9 INDORE CITY	Cent	-	11KV	Feeder no 4	CHQ	25.09.2019	13:00	15:00	2:00	Due to Defective ME Replacement Work at Grid	SE CITY	AE(Maint.)	No	YES	0.45		bank Colony, narendra tiwari marg, Vishvkarma nagar & ETC
10 INDORE CITY	Cent	Zone	33 kv	Bijalpur-1 & 2	VIII	25.09.2019	7:00	14:00	7:00	Due to Counductor Replacement WORK Under IPDS	SE CITY	AE(Maint.)	Yes	YES	NIL		No Area Affected
11 INDORE CITY	Cent	ral 220 KVA South Zone	33 kv	Harsola	CHQ	25.09.2019	7:00	14:00	7:00	Due to Counductor Replacement WORK Under IPDS	SE CITY	AE(Maint.)	Yes	YES	NIL		No Area Affected
12 INDORE CITY	Cent	ral 220 KVA South Zone	33 kv	Pithampur	CHQ	25.09.2019	7:00	14:00	7:00	Due to Counductor Replacement WORK Under IPDS	SE CITY	AE(Maint.)	Yes	YES	NIL		4 no HT Conn Affected
13 INDORE CITY	Sout Divis		11 kv	manik bagh	CHQ	25.09.2019	8:00	10:00	2:00	1 No. DTR charging work by STC	SE CITY	AE(Maint.)	No	YES	1.87		manik bagh road ,brook brand colony
14 INDORE CITY	E Sout Divis		11 kv	phase no.1	CHQ	25.09.2019	10:00	12:00	2:00	1 No. DTR charging work by STC	SE CITY	AE(Maint.)	No	YES	0.98		limbodi, phase no.1 area
15 INDORE CITY	E Sout Divis		11 kv	Indrapuri	CHQ	25.09.2019	11:00	12:00	1:00	1 No. DTR charging work by STC	SE CITY	AE(Maint.)	No	YES	1.96		indrapuri , khandwa road,
16 INDORE CITY	Sout Divis	th ODU Couth	11 kv	Chavni & Bus stand	CHQ	25.09.2019	7:00	10:00	3:00	4 No.Pole Erection work by nagar nigam under smart city at juni indore brize	SE CITY	AE(Maint.)	No	YES	2.02	Paper Declared	nasiya road, bus stand, cristion college
17 INDORE CITY		th Daly college	11 kv	Industrial	CHQ	25.09.2019	6:00	6:30	0:30	O/G Isolator red hot work	SE CITY	AE(Maint.)	No	YES	0.69		udhyog nagar , kailash grain,
18 INDORE CITY		th Navlakha	11 kv	Main no. 1	CHQ	25.09.2019	12:30	13:00	0:30	VCB TRIP TEST WORK BY STM.	SE CITY	AE(Maint.)	No	YES	0.72		Chitawad & Malwa House feeder
19 INDORE CITY		th Navlakha	11 kv	Vidhya nagar	CHQ	25.09.2019	13:00	13:30	0:30	VCB TRIP TEST WORK BY STM.	SE CITY	AE(Maint.)	No	YES	0.64		vidhya nagar ,ashok nagar,
20 INDORE CITY		th Navlakha	11 kv	Main no. 3	CHQ	25.09.2019	13:30	13:50	0:20	VCB TRIP TEST WORK BY STM.	SE CITY	AE(Maint.)	No	YES	0.71		Navlakha no. 1 & 2feeder
22 INDORE CITY	WES	CITY CONTROL	11KV	5MVA PTR NO. (V.LP, URJA PARISAR, JAIL ROAD, TILAKPATH,)	СНО	25.09.2019	6:00	6:20	0:20	FOR 11 MAIN NO.01 ISOLATOR O/G SIDE Y PHASE CLAMP NET BOLT & 11 V.I.P. B PHASE CT & AB SWITCH CLAMP RED HOT & ALL JUMPER CHECK WORK.	SE CITY	AE(Maint.)	No	YES	0.45		11KV V.I.P, URJA PARISAR, JAIL ROAD, TILAKPATH
23 INDORE CITY	WES	220KV NORTH ZONE	33KV	33KV SANGAM NAGAR 2	CHQ	25.09.2019	6:40	7:00	0:20	ISOLATOR MALE FEMALE CONTACT REPLACEMENT WORK AT SCH-155.	SE CITY	AE(Maint.)	YES	YES	NIL		NIL
24 INDORE CITY	WES	SANGAM NAGAR	11KV	RAMBALI NAGAR	CHQ	25.09.2019	7:15	7:30	0:15	ME OIL LEAKAGE work at S/s	SE CITY	AE(Maint.)	No	YES	0.4		All LT Consume & Laxmipura Colony, Laxmanpura Eat Bhatta, Archana Nagar.
25 INDORE CITY	WES	CANCAM	11KV	KAVERI NAGAR	СНО	25.09.2019	8:00	10:00	2:00	FOR RMU CHARGING WORK BY MEGAWIEN	SE CITY	AE(Maint.)	No	YES	0.35		Sch. No. 51 Mim. Area, Rajput Wala, Shubham Nagar, Kavery Nagar, Mama Patty, Leck Palace, Garib Nawaj, Mahavir Nagar, Saket Dham, Shrinath Vihar, Shubham Palace, Kedar Nagar, Poonam Wala.
26 INDORE CITY	WES	SANGAM NAGAR	11KV	I.D.A51	CHQ	25.09.2019	8:00	10:00	2:00	FOR RMU CHARGING WORK BY MEGAWIEN	SE CITY	AE(Maint.)	No	YES	0.25		Schame No. 51, Pachlore Bhawan, Watar Tank Maharana Pratap Zone, Ahilya Nagar, GuruNanak Colony, Lutar Bag, Shubham Nagar, Gourav Kirana Store, Sch. 155, Ganesh Bag Colony, Shambhu Dayal Bagicha.
27 INDORE CITY	WES	ST NAGIN NAGAR	11KV	5MVA PTR NO01	CHQ	25.09.2019	8:00	8:45	0:45	FOR POST MONSOON MAINTENANCE WORK BY STM.	SE CITY	AE(Maint.)	No	YES	0.45		11KV KALANI, RAJ NAGAR
28 INDORE CITY	WES	ST NAGIN NAGAR	11KV	5MVA PTR NO02	CHQ	25.09.2019	9:00	9:45	0:45	FOR POST MONSOON MAINTENANCE WORK BY STM.	SE CITY	AE(Maint.)	No	YES	0.5		11KV NAGIN NAGAR, RANI PALACE
29 INDORE CITY	WES		11KV	5MVA PTR NO03	CHQ	25.09.2019	10:00	10:45	0:45	FOR POST MONSOON MAINTENANCE WORK BY STM.	SE CITY	AE(Maint.)	No	YES	0.45		11KV VIJYASHREE
30 INDORE CITY	EAS	T 132KV-SATYA SAI	33KV	SATYA SAI	CHQ	25.09.2019	7:00	8:00	1:00	I/C ISOLATOR RED HOT ATTEND WORK.	SE CITY	AE(Maint.)	No	YES	1		SATYA SAI GRID
31 INDORE CITY	EAS	T SC.NO.134	11KV	BARLA	CHQ	25.09.2019	10:00	12:00	2:00	TREE CUTTING & MAINTENANCE WORK.	SE CITY	AE(Maint.)	No	YES	0.65		IDA QATER, SLATER HOUSE AND JASPAL DA DABA ETC
32 INDORE CITY	EAS	T MAHALAXMI	11KV	KHAJRANA(R)	CHQ	25.09.2019	15:30	16:00	0:30	VCB TRIP TEST WORK BY STM.	SE CITY	AE(Maint.)	No	YES	25		SAIKRUPA, RAMKRUSHAN BAG, YADAV SHOW ROOM AND MR-10 ETC.
33 INDORE CITY	EAS	GRID	33KV	SNACHAR NAGAR- II (INCOMMING FEEDER-)	СНО	25.09.2019	16:30	17:00	0:30	33KV INCOMMING SIDE VCB TEST WORK BY STM.	SE CITY	AE(Maint.)	YES	YES	NIL		NIL
34 INDORE CITY	Nor	Sector E	11 kv	11 kv E-1	CHQ	25.09.2019	17:00	17:30	0:30	1 No. DTR Augmentation work Under ND SCHEME(100KVA TO 200KVA)	SE CITY	AE(Maint.)	No	YES	0.25		Sector E & shivlkanth Nagar
35 INDORE CITY	Nor	Miralijali Pur	11 kv	11 kv Mother Teresa	CHQ	25.09.2019	6:30	11:00	4:30	line maintenance & Tree Cutting work	SE CITY	AE(Maint.)	No	YES	0.95	Paper Declared	Mother Tereca colony
36 INDORE CITY	Nor	nagar	11 kv	11 kv Scheme No. 78	CHQ	25.09.2019	8:00	11:00	3:00	for Feeder Bifurcation work by STC Team	SE CITY	AE(Maint.)	No	YES	0.55		Schm.No.78, Prestige Public school
37 INDORE CITY	Nor	th 33/11 kv Vijay nagar	33 kv	33 kv Scheme no. 78 1st & 2nd	CHQ	25.09.2019	10:00	11:00	1:00	for Seafty Purpose work On Scheme no. 78	SE CITY	AE(Maint.)	No	YES	0.25		33/11 kv Scheme No 78 Grid Affected
38 INDORE CITY	Nor	33/11 kg Loha	11 kv	11 kv New Loha Mandi	CHQ	25.09.2019	6:00	6:30	0:30	R-phase i/c isolator red hot work of 11 kv New loha mandi	SE CITY	AE(Maint.)	No	YES	0.4		New loha mandi,
39 INDORE CITY	Nor	33/11 kg Loha	33 kv	33 kv Main	CHQ	25.09.2019	6:30	7:00	0:30	B-PHASE O/G Isolator Red hot work	SE CITY	AE(Maint.)	No	YES	0.35		11 kv Lasudiya naka & New Loha mandi & Niranjan Pur