

M.P.P.K.V.V. C. LTD. INDORE CIRCLE																			
S.N o	Name of Circle	NAME OF DIVISION	Name of EHV S/s or 33/11 KV S/s	Line KV Capacity (33 or 11)	Name of 33 KV / 11 KV feeder	Planned shutdown			DATE- 19.10.2019				Shutdown Approved by -	Approval Granted to-	Alternate Supply Arrangements are available or not (Yes/No)	It has been Reported on Whatsapp Group	Demand in MW affected due to Shutdown.	Remark(Are as affected)	Remark(Areas affected)
						Group (for 33KV) Category (for 11 KV)	Date of Planned Shutdown	Duration of From to	Total Duration	Reason for Planned Shutdown (Maintenance/Erection work/ FSP / Safety purpose etc.)									
1	INDORE CITY	South Division	Mayur nagar	11 kv	Ram nagar	CHQ	19.10.2019	8:00	12:00	4:00	5 no. Pole Erection work by Kshema power IPDS work at Khandwa road	SE CITY	AE(Maint.)	No	Yes	0.76	Paper Declared	SHRI BALAJI ENG KE SAMNE, PRABHU TOLE KATA KE SAMNE,APURVA PALACE, VAEDAN FACTORY,	
2	INDORE CITY	South Division	Sabji mandi	11 kv	Main no. 4	CHQ	19.10.2019	6:00	6:30	0:30	I/C Isolator clamp & Bus side R,Y-phase Isolator clamp red hot work at yard	SE CITY	AE(Maint.)	No	Yes	1.2		Bijalpur , Gayatri nagar , Pawanputra nagar	
3	INDORE CITY	South Division	Sabji mandi	33 kv	Sabji Mandi I/C	CHQ	19.10.2019	6:30	7:00	0:30	O/G feeder ME R-phase & Y,B-phase Isolator /CT Clamp red hot work at yard	SE CITY	AE(Maint.)	Yes	Yes	Nil		Nil	
4	INDORE CITY	South Division	Mechanic Nagar	11 kv	Main no. 1	CHQ	19.10.2019	7:00	7:30	0:30	11 kv main no. Y-phase CT Clamp red hot work at Yard	SE CITY	AE(Maint.)	No	Yes	0.68		11 kv Aditya nagar & Sidharth Nagar feeder or related Area	
5	INDORE CITY	South Division	University	33 kv	Palda naka I/C	CHQ	19.10.2019	10:00	11:00	1:00	33 kv feeder ME I/C side R,Y-phase clamp red hot work at yard	SE CITY	AE(Maint.)	No	Yes	0.46		11 kv Van-vibhag, Khatiwala tank, Anand nagar feeder	
6	INDORE CITY	South Division	University	11 kv	5 mva no.2	CHQ	19.10.2019	10:00	11:00	1:00	I/C Y-phase Jumper clamp & Khatiwala tank feeder Y-phase AB switch I/C side clamp red hot work at yard	SE CITY	AE(Maint.)	No	Yes	1.24		11 kv Anand nagar + Khatiwala tank +Vanvibhag feeders	
7	Indore city	South Division	Mayur nagar	11 kv	Ram nagar	CHQ	19.10.2019	7:00	11:00	4:00	Due to 11 KV Line Post Monsoon maintenance Work	SE CITY	AE(Maint.)	No	Yes	1.82		SHRI BALAJI ENG KE SAMNE, PRABHU TOLE KATA KE SAMNE,APURVA PALACE, VAEDAN FACTORY,	
8	INDORE CITY	North	33/11 KV KABIT KHEDI	11 KV	11 KV CHANDRA GUPT	CHQ	19.10.2019	8:00	8:30	0:30	FOR DTR CHARGE WORK BY STC TEAM	SE CITY	AE(Maint.)	No	Yes	0.5		MR-10 Sukhliya C Sector	
9	City Indore	North	33/11 KV setelite	11 KV	11 kv ro house	CHQ	19.10.2019	16:30	17:00	0:30	FOR VCB TRIP TEST WORK BY STM TEAM.	SE CITY	AE(Maint.)	No	Yes	0.65		Ro-house Area	
10	City Indore	North	33/11 KV setelite	11 KV	11 kv Magar Kheda	CHQ	19.10.2019	17:00	17:30	0:30	FOR VCB TRIP TEST WORK BY STM TEAM.	SE CITY	AE(Maint.)	No	Yes	0.7		Magar Kheda area	
11	City Indore	North	33/11 KV setelite	11 KV	11 kv main	CHQ	19.10.2019	17:30	18:00	0:30	FOR VCB TRIP TEST WORK BY STM TEAM.	SE CITY	AE(Maint.)	No	Yes	0.5		11kv feeder-1	
12	INDORE CITY	WEST	CHOTA BANGARDA	11KV	PADMALAY	CHQ	19.10.2019	8:25	8:40	0:15	For me oil leakage work.	SE CITY	AE(Maint.)	No	Yes	0.68		11kv padmalya feeder related area.	
13	INDORE CITY	WEST	AIRPORT	11KV	8MVA PTR NO.2	CHQ	19.10.2019	12:30	13:00	0:30	FOR VCB TRIP TEST WORK BY STM TEAM.	SE CITY	AE(Maint.)	No	Yes	0.46		11kv airport, Hi-link, BSF	
14	INDORE CITY	WEST	AIRPORT	11KV	11 MAIN NO.2	CHQ	19.10.2019	13:00	13:30	0:30	FOR VCB TRIP TEST WORK BY STM TEAM.	SE CITY	AE(Maint.)	No	Yes	1.24		11kv airport, Hi-link, BSF	
15	INDORE CITY	WEST	SANGAM NAGAR	11KV	AERODRUM-2	CHQ	19.10.2019	14:00	14:30	0:30	FOR VCB TRIP TEST WORK BY STM TEAM.	SE CITY	AE(Maint.)	No	Yes	1.82		11Aerodrum feeder related area.	
16	INDORE CITY	WEST	SANGAM NAGAR	11KV	SUBHASH MARG- 1	CHQ	19.10.2019	15:00	15:30	0:30	FOR VCB TRIP TEST WORK BY STM TEAM.	SE CITY	AE(Maint.)	No	Yes	1.3		11kv Subhash Marg,1 feeder related area.	
17	INDORE CITY	WEST	SANGAM NAGAR	11KV	RAMBALI NAGAR	CHQ	19.10.2019	15:30	16:00	0:30	FOR VCB TRIP TEST WORK BY STM TEAM.	SE CITY	AE(Maint.)	No	Yes	0.4		11kv Rambali nagar feeder related area.	
18	INDORE CITY	WEST	CITY CONTROL ROOM	11KV	RAJWADA	CHQ	19.10.2019	9:00	10:00	1:00	CM HELPLINE COMPLAINT BHARAT SINGH BY ELECTRICALWAIR TREE CUTTING WORK	SE CITY	AE(Maint.)	No	Yes	0.4		Deelip Singh Colony, Mamta Deyari, Chedilal Dubey Road, Idgaha, Sadar Bazar Watar Tank, Bhishti Mohalla, Juna Risala, Aman Chouk, Sikndrabad Colony, Dhobi Ghat, Ahilya Paltun, Kamunity Hol, Bora Kabristan.	
19	INDORE CITY	WEST	BAJAJ KHANA	11KV	1KV MAIN	CHQ	19.10.2019	6:00	6:15	0:15	B-PHASE CT OIL LEAKAGE WORK	SE CITY	AE(Maint.)	No	Yes	0.4		11KV BAJAJ KHANA, MTC FEEDER RELATED AREA.	
20	INDORE CITY	WEST	AIRPORT	11KV	VIDHYA DHAM	CHQ	19.10.2019	6:25	6:40	0:15	I/C Isolator Y-phase clamp red hot work at yard	SE CITY	AE(Maint.)	No	Yes	0.4		PanchSheel Nagar, VidhayDham Tempal, Cityjan Hospital, ShriKrishn Nagar, KanyKunj Bagicha, RatanBag, Vyanktesh Nagar Main, Kalani Chouraha, Anjali Nagar, Malwa Hosp., Teacher Nagar.	
21	INDORE CITY	NORTH	220KV NORTH ZONE	33KV	IND-A	CHQ	19.10.2019	6:50	7:20	0:30	Y-phase CT & I/C Isolato clamp red hot work at yard	SE CITY	AE(Maint.)	Yes	Yes	Nil		Nil	
22	INDORE CITY	WEST	132kv chambal	33KV	CITY-1	CHQ	19.10.2019	8:00	8:15	0:15	VCB Y-PHASE POLE CLAMP RED HOT WORK	SE CITY	AE(Maint.)	Yes	Yes	Nil		Nil	
23	INDORE CITY	WEST	SECTOR-A	11KV	11 MAIN-1	CHQ	19.10.2019	7:20	7:35	0:15	FOR I/C ISOLATOR JUMPER RED HOT WORK.	SE CITY	AE(Maint.)	NO	Yes	0.65		11KV SUNDAR NAGAR, 11KV RURAL FEEDER RELATED AREA.	
24	INDORE CITY	WEST	CITY CONTROL ROOM	11KV	11 MAIN NO.-2	CHQ	19.10.2019	7:45	8:00	0:15	FOR VCB Y PHASE POLE CLAMP RED HOT WORK.	SE CITY	AE(Maint.)	NO	Yes	0.75		11KV SHIVVILASH, 11KV SANWER ROAD FEEDER REALATED AREA.	
25	INDORE CITY	Central	Rajmohalla	11 KV	AIR & Mhow	CHQ	19.10.2019	8:00	11:00	3:00	Due to 11 KV Line Post Monsoon maintenance Work	SE CITY	AE(Maint.)	NO	Yes	0.4		Swastik Nagar, MOG Line, balda Colony, Rajsav gram, Chatri Puura Police Thana, Joshi Mohalla. Vardhman nagar, Arjun Pura & ETC.	
26	INDORE CITY	Central	Silicon City	11 KV	PTR No.-1	CHQ	19.10.2019	6:30	7:30	1:00	Due to PTR Post Monsoon maintenance Work	SE CITY	AE(Maint.)	NO	Yes	0.95		11 kv Feeder No. -1 & 2	
27	INDORE CITY	Central	Silicon City	11 KV	PTR No.-2	CHQ	19.10.2019	7:30	8:30	1:00	Due to PTR Post Monsoon maintenance Work	SE CITY	AE(Maint.)	NO	Yes	0.74		11 kv Feeder No. -3	
28	INDORE CITY	Central	Silicon City	11 KV	PTR No.-3	CHQ	19.10.2019	8:30	9:30	1:00	Due to PTR Post Monsoon maintenance Work	SE CITY	AE(Maint.)	NO	Yes	0.68		11 kv Feeder No. -4 & 5	
29	INDORE CITY	Central	New york city	11 KV	PTR No.-1	CHQ	19.10.2019	10:30	11:30	1:00	Due to PTR Post Monsoon maintenance Work	SE CITY	AE(Maint.)	NO	Yes	0.49		11 kv Feeder No. -1 & 2	
30	INDORE CITY	EAST	132KV- SATYA SAI	33 KV	MAHALAXMI GRID	CHQ	19.10.2019	6:30	10:30	4:00	33/11 kv S/s Post Monsoon Maintenance work	SE CITY	AE(Maint.)	NO	Yes	0.69		MAHALAXMI GRID	
31	INDORE CITY	EAST	SANCHAR NAGAR -2	33 KV	SC.NO.134 GRID	CHQ	19.10.2019	10:00	12:00	2:00	33/11 kv S/s Post Monsoon Maintenance work	SE CITY	AE(Maint.)	NO	Yes	0.75		SC.NO.134 GRID	
32	INDORE CITY	EAST	SC.NO.134	11 KV	AASRFI NGR.	CHQ	19.10.2019	10:00	12:00	2:00	Due to 11 KV Line Post Monsoon maintenance Work	SE CITY	AE(Maint.)	NO	Yes	0.98		ASHRFI NAGAR , DOLAT BAG, ZALARIA ROAD ETC.	