

| M.P.P.K.V.V.C.LTD. INDORE CIRCLE | | | | | | | | | | | | | | | | | | |
|----------------------------------|----------------|------------------|---------------------------------|-----------------------------|------------------------------|---|--------------------------|---------------------|----------|----------------|--|----------------------|---------------------|---|--|------------------------|--|--|
| S.No | Name of Circle | NAME OF DIVISION | Name of EHV S/s or 33/11 KV S/s | Line KV Capacity (13 or 11) | Name of 33 KV / 11 KV feeder | Group (for 33KV) / Category (for 11 KV) | Date of Planned Shutdown | Duration of Planned | | Total Duration | Reason for Planned Shutdown (Maintenance/Erection work/ PSP / Safety purpose etc.) | Shutdown Approved by | Approval Granted to | Alternate Supply Arrangements are available or not (Yes/No) | Demand in MW affected due to Shutdown. | Remark(Areas affected) | Remark(Areas affected) | |
| | | | | | | | | From | to | | | | | | | | | |
| 1 | INDORE CITY | WEST | 132 NAWDA PANTH | 33 KV | 33KV GANDHI NAGAR | VIII | 26.06.19 | 6:00:00 | 10:00:00 | 4:00:00 | For Pre Monsoon Maintenance Work. | SE CITY | AE(Maint.) | YES | | PAPER DECLARED | NIL | |
| 2 | INDORE CITY | South Division | OPH East | 11 kv | Chhawani | CHQ | 26.06.19 | 6:30:00 | 9:00:00 | 2:30:00 | Line Shifting Work By Nagar Nigam At Gadi Adda | EE south | AE(Maint.) | No | 1.68 | | 11 kv Chhawani Area or feeder | |
| 3 | INDORE CITY | South Division | Indira Complex | 33 kv | OPH O/G | VIII | 26.06.19 | 6:30:00 | 9:00:00 | 2:30:00 | Line Shifting Work By Nagar Nigam At Gadi Adda | EE south | AE(Maint.) | Yes | Nil | | nil | |
| 4 | INDORE CITY | South Division | Mayur nagar | 11 kv | Nemawar road | CHQ | 26.06.19 | 6:00:00 | 6:30:00 | 0:30:00 | Dtr Charging By Stc Under Ipds Scheme | EE south | AE(Maint.) | No | 0.48 | | mayur nagar ,shiv nagar , nemawar road | |
| 5 | INDORE CITY | South Division | Palda naka | 11 kv | Kohinoor | CHQ | 26.06.19 | 7:00:00 | 8:00:00 | 1:00:00 | Dtr Charging By Stc | EE south | AE(Maint.) | No | 1.3 | | kohinoor colony, saline stone, shakti dhram kata, near reliance petro pump,370/5/1 new balaji nagar,netroal sume | |
| 6 | INDORE CITY | South Division | Navlakha | 11 kv | Microwave & Vidhya nagar | CHQ | 26.06.19 | 9:00:00 | 9:30:00 | 0:30:00 | Dtr Installation Work By Kohama Power Under Ipds Scheme | EE south | AE(Maint.) | No | 1.26 | | Shi palsikar colony, police thana, joshi colony, devshri complex, shi tripathi steelation,palsikar, 34khattat , BHAGWAN NAGAR ROSHAN APPT, SUKHDHAM APPT, 91 NO JANKI NAGAR, | |
| 7 | INDORE CITY | South Division | Palda Industrial | 11 kv | Vinayak | CHQ | 26.06.19 | 6:00:00 | 6:30:00 | 0:30:00 | 11 Kv Feeder R-Phase I/C Side Ct Clamp Red Hot Work | EE south | AE(Maint.) | No | 0.43 | | 11 kv Vinayak feeder | |
| 8 | INDORE CITY | South Division | University | 11 kv | Main no. 3 | CHQ | 26.06.19 | 6:30:00 | 7:00:00 | 0:30:00 | 11 Kv Main No.3 R-B-Phase Ct Clamp Red Hot Work | EE south | AE(Maint.) | No | 0.81 | | 11 kv Vishnupuri & Indrapuri feeder affected aera | |
| 9 | INDORE CITY | South Division | 220 kv EHV south zone | 33 kv | Pagnispaga | VIII | 26.06.19 | 10:00:00 | 11:00:00 | 1:00:00 | Tree Cutting Work By Nagar Nigam At Palsikar | EE south | AE(Maint.) | Yes | Nil | | No Supply Effectted | |
| 10 | INDORE CITY | South Division | Indira Complex | 11 KV | Main no.2 | CHQ | 26.06.19 | 7:00:00 | 7:30:00 | 0:30:00 | 11 Kv Main No. 2 Bus Cupler R-Phase Isolator Red Hot Work | EE south | AE(Maint.) | No | 0.66 | | 11 kv T.S. no.1 & 2 feeder or Area | |
| 11 | INDORE CITY | South Division | Indira Complex | 11 KV | Indira Complex | CHQ | 26.06.19 | 7:00:00 | 7:30:00 | 0:30:00 | 11 Kv Feeder Me R-Phase O/G Side Bushing Clamp Red Hot Work | EE south | AE(Maint.) | No | 0.42 | | Janki nagar, opp vishal tower-1,opp vishal tower-2, indira complex, opp krishna hotel, krishna boys hostel | |
| 12 | INDORE CITY | EAST | PRESS COMPLEX | 11 KV | ANOO P NAGAR | CHQ | 26.06.19 | 6:30:00 | 9:30:00 | 3:00:00 | Line Maintenance And Tree Cutting | | | NO | | PAPER DECLARED | Anoop nagar , gangor sweet , | |
| 13 | INDORE CITY | EAST | 33/11KV BTC | 11 KV | 56 SHOP | CHQ | 26.06.19 | 6:30:00 | 9:30:00 | 3:00:00 | Line Maintenance And Tree Cutting | | | NO | | PAPER DECLARED | 56 dukan , palasiya | |
| 14 | INDORE CITY | EAST | PRESS COMPLEX | | SREE NAGAR | CHQ | 26.06.19 | 6:30:00 | 9:30:00 | 3:00:00 | Line Maintenance And Tree Cutting | | | NO | | PAPER DECLARED | sree nagar , anoop nagar, lig | |
| 15 | INDORE CITY | North | 33/11 Kv Vijay nagar | 11 KV | 11 KV Scheme No. 54 | CHQ | 26.06.19 | 6:00:00 | 10:00:00 | 4:00:00 | Tree Cutting & Line Maintenance Work | EE Sir North | AE SAAB | NO | | PAPER DECLARED | sch no 54 , vijay nagar , nyay nagar | |
| 16 | INDORE CITY | North | 33/11 Kv mangliya | 11 KV | 11 kv Dream City | CHQ | 26.06.19 | 6:00:00 | 9:00:00 | 3:00:00 | Tree Cutting & Line Maintenance Work | EE Sir North | AE SAAB | NO | | PAPER DECLARED | dream city aera | |
| 17 | INDORE CITY | North | 33/11 Kv mahakal | 11 kv | 11 kv ujain road | CHQ | 26.06.19 | 13:00:00 | 13:30:00 | 0:30:00 | For Conductor Clearance Work | EE Sir North | AE SAAB | NO | | | Areas affected | |
| 18 | INDORE CITY | North | 33/11 Kv SHILANTH | 11KV | 11KV Main | CHQ | 26.06.19 | 6:30:00 | 7:00:00 | 0:30:00 | For Vcb Work By Stm Team & I/C Isolator Red Hot Work Of 11Kv Main &Disc Replacement Work Of 11kv Over Bridge | EE Sir North | AE SAAB | NO | | | shivshakti nagar & shivaji nagar & over bridge & kulkarni bhata | |
| 19 | INDORE CITY | North | 33/11 Kv LIG | 11 KV | 11 kv Old Palasiya | CHQ | 26.06.19 | 6:00:00 | 6:15:00 | 0:15:00 | For Ct Circuit Work | EE Sir North | AE SAAB | NO | | | palasiya , janjir square | |
| 20 | INDORE CITY | North | 33/11 Kv LIG | 11 KV | 11 kv Main | CHQ | 26.06.19 | 5:45:00 | 6:00:00 | 0:15:00 | For I/C Isolator Red Hot Work Of 11Kv Main | EE Sir North | AE SAAB | NO | | | 11KV Old palasiya & Uttam Bhaw & Industry House | |
| 21 | INDORE CITY | North | 33/11 Kv Vijay nagar | 33KV | 33KV Scheme No.78 1st | CHQ | 26.06.19 | 7:20:00 | 7:30:00 | 0:10:00 | For Vcb Work By Stm Team | EE Sir North | AE SAAB | Yes | | | nil | |
| 22 | INDORE CITY | North | 33/11 Kv Niranjan Pur | 11KV | 11KV Mother Teresa | CHQ | 26.06.19 | 9:00:00 | 9:25:00 | 0:25:00 | For Vcb Work By Stm Team | EE Sir North | AE SAAB | No | | | mother teresa colony | |
| 23 | INDORE CITY | North | 33/11 Kv Niranjan Pur | 11KV | 11KV EWS | CHQ | 26.06.19 | 9:30:00 | 9:50:00 | 0:20:00 | For Vcb Work By Stm Team | EE Sir North | AE SAAB | No | | | mangliya rural colony | |
| 24 | INDORE CITY | North | 33/11 Kv Setelite | 11KV | 11KV Feeder No. 2 | CHQ | 26.06.19 | 10:30:00 | 11:00:00 | 0:30:00 | For Ct Replacement Work By Stm Team | EE Sir North | AE SAAB | No | | | setelite colony | |
| 25 | INDORE CITY | Central | Footi Kothi | 11KV | Vidur Nagar | CHQ | 26.06.19 | 7:00:00 | 10:00:00 | 3:00:00 | Due To Line Maintenance & Tree Cutting P/D Shutdown | | | NO | 1 MW | PAPER DECLARED | Cat road, Reshi palace,Digvijay Multl, Ramshabada & ETC | |
| 26 | INDORE CITY | Central | Rau | 11KV | Pigdamber IP & rural | CHQ | 26.06.19 | 7:00:00 | 10:00:00 | 3:00:00 | Due To Ipds Pole Eraction Work P/D Shutdown | | | NO | 1 MW | | Area Affected Related to This Feeder | |
| 27 | INDORE CITY | Central | Rau | 11KV | Rau-1 | CHQ | 26.06.19 | 7:00:00 | 7:15:00 | 0:15:00 | Due To Jumper Open For Ipds Pole Eraction Work P/D Shutdown | | | NO | 1 MW | | 2 no DTr Affected | |
| 28 | INDORE CITY | Central | Rau | 11KV | Rau-1 | CHQ | 26.06.19 | 10:00:00 | 10:15:00 | 0:15:00 | Due To Jumper Reconnected After Work | | | NO | 1 MW | | 2 no DTr Affected | |
| 29 | INDORE CITY | Central | Annapurna | 11KV | Silver AUX | CHQ | 26.06.19 | 7:00:00 | 10:00:00 | 3:00:00 | Due To Ipds Pole Eraction Work P/D Shutdown | | | NO | 1 MW | | Silver AUX,Umesh nagar, Devendra nagar, Nemi nagar ,Vijay nagar & ETC | |
| 30 | INDORE CITY | Central | Pragati Nagar | 11KV | Pragati Nagar | CHQ | 26.06.19 | 7:00:00 | 10:00:00 | 3:00:00 | Due To Ipds Pole Eraction Work P/D Shutdown | | | NO | 1 MW | | Vigyan nagar, Prabhu nagar, Saraswati nagar, Silver AUX,Umesh nagar & ETC | |
| 31 | INDORE CITY | Central | Revenue Nagar | 11KV | Mahawar nagar | CHQ | 26.06.19 | 7:00:00 | 10:00:00 | 3:00:00 | Due To Ipds Pole Eraction Work P/D Shutdown | | | NO | 1 MW | | Revenue nagar, RTO Road, Raja Bag, gurumanak Colony, mahawar nagar & ETC | |
| 32 | INDORE CITY | Central | Rajendra nagar | 11KV | AIR | CHQ | 26.06.19 | 7:00:00 | 7:30:00 | 0:30:00 | Due To 2 No Tree Cutting Work Agensst Consumer Complant | | | NO | 1 MW | | Area Affected Related to This Feeder | |
| 33 | INDORE CITY | Central | Revenue Nagar | 11KV | Usha nagar | CHQ | 26.06.19 | 10:00:00 | 11:00:00 | 1:00:00 | Due To 2 No Tree Cutting Work Agensst Consumer Complant By Nagar Nigam | | | NO | 1 MW | | Usha nagar, usha nagar Ext. mahalaxmi mandir & ETC | |
| 34 | INDORE CITY | Central | Bijalpur | 11KV | Mundi | CHQ | 26.06.19 | 10:00:00 | 10:15:00 | 0:15:00 | Due To 1 No Pole Eraction Work By Ipds Agensst Cm Help Line Complant | | | NO | 1 MW | | Gram Mundi, Setelight & ETC | |
| 35 | INDORE CITY | Central | Bijalpur | 11KV | Main no 3 | CHQ | 26.06.19 | 6:15:00 | 6:30:00 | 0:15:00 | Due To Red Hot Work | | | NO | 1 MW | | Area Affected Related to This Feeder | |
| 36 | INDORE CITY | Central | Silicon City | 11KV | Feeder no 5 | CHQ | 26.06.19 | 5:45:00 | 6:00:00 | 0:15:00 | Due To Red Hot Work | | | NO | 1 MW | | silicon city | |
| 37 | INDORE CITY | Central | Star City | 11KV | All Feeder | CHQ | 26.06.19 | 11:00:00 | 11:15:00 | 0:15:00 | Due To Red Hot Work | | | NO | 1 MW | | Star city | |