

M.P.P.K.V.V. C. LTD. INDORE CIRCLE																		
S.No	Name of Circle	NAME OF DIVISION	Name of EHV 5/s or 33/11 KV S/s	Line KV Capacity (33 or 11)	Planned shutdown			DATE- 03.08.2019			Reason for Planned Shutdown (Maintenance/Erection work/ FSP / Safety purpose etc.)	Shutdown Approved by -	Approval Granted to-	Alternate Supply Arrangements are available or not (Yes/No)	It has been Reported on Whatsapp Group	Demand in MW affected due to Shutdown.	Remark(Areas affected)	Remark(Areas affected)
					Name of 33 KV / 11 KV feeder	Group (for 33KV) / Category (for 11 KV)	Date of Planned Shutdown	Duration of	From	to								
1	INDORE CITY	WEST	SANGAM NAGAR	11 kv	SUBAHSH MARG-1	CHQ	3.08.2019	05:15	05:30	00:15	FOR R & B PHASE CT RED HOT WORK.	SE CITY	AE(Maint.)	No	Yes	0.5		Gadra Khedi, Palhar Nagar, Sahu Nagar, Ramchandra Nagar Chouraha, Sadhna Nagar, Ratlam Tower, Monika Iskrim, Snah Swits.
2	INDORE CITY	WEST	SANGAM NAGAR	11 kv	AIRODRUM-1	CHQ	3.08.2019	05:30	05:45	00:15	FOR R & B PHASE CT RED HOT WORK.	SE CITY	AE(Maint.)	No	Yes	0.45		LIC, Siment Goduwn, Rukhmani Nagar, Suvidhi, Akhand Nagar, Amrakunji, Sanwariya Nagar, Om Bihar, Shriyantn Nagar, Sahu Nagar, Krishn Nagar.
3	INDORE CITY	South Division	Mechanic Nagar	11 kv	Sidharth Nagar	CHQ	3.08.2019	07:00	10:00	03:00	4 no. Pole Erection work at Sidharth nagar by Kashama power under IPDS work	SE CITY	AE(Maint.)	No	Yes	1.84	PAPER DECLARED	Sidharth Nagar Area or feeder
4	INDORE CITY	South Division	Tejaji nagar	11 kv	Anuradha nagar	CHQ	3.08.2019	07:00	10:00	03:00	3 no. Pole Erection work at Anuradha nagar by Kashama power under IPDS work	SE CITY	AE(Maint.)	No	Yes	1.63	PAPER DECLARED	Anuradha nagar ,khandwa road , ashish nagar
5	INDORE CITY	South Division	Palda Industrial	11 kv	R.D. Udyog Nagar & Kalindi	CHQ	3.08.2019	13:00	13:30	00:30	For New HT Connection DTR Charging work at M/S. ACC Ltd.	SE CITY	AE(Maint.)	No	Yes	0.72		11 kv R.D. Udyog Nagar & Kalindi Feeder
6	INDORE CITY	South Division	Navlakha	11 kv	Main no. 1	CHQ	3.08.2019	06:00	06:30	00:30	11 kv main no.1 O/G Clamp red hot work	SE CITY	AE(Maint.)	No	Yes	0.49		Mahadev dal mil, 62 prakash nagar, 107 prakash nagar, b-5 shiv kripa colony, sajan nagar dal mil, kalyan dal mil, brejhashwari tower, kk udyog nagar, kalyan dal mil ke pass
7	INDORE CITY	South Division	University	11 kv	Main No. 2	CHQ	3.08.2019	06:30	07:00	00:30	11 kv main no.2 Y-phase AB Switch O/G clamp red hot work	SE CITY	AE(Maint.)	No	Yes	0.76		11 kv Khatiwala Tank , Anand Nagar , Van Vibhag
8	INDORE CITY	South Division	Palda industrial	11 kv	Kalindi feeder	CHQ	3.08.2019	12:30	13:00	00:30	VCB Trip Test work by STM	SE CITY	AE(Maint.)	No	Yes	0.45		Kalindi Feeder
9	INDORE CITY	South Division	Indira Complex	11 kv	Main No. 1	CHQ	3.08.2019	08:00	08:30	00:30	VCB Trip Test work by STM	SE CITY	AE(Maint.)	No	Yes	0.79		NEAR SBI NHEHRU STADIUM,MATHURA WALA, GPO POST OFFICE, SHANKAR BAG ,CHAWNI ,DIVISION OFFICE ,IDA COMPOUND
10	INDORE CITY	South Division	Shri Krishna Avenue	11 kv	8 MVA	CHQ	3.08.2019	09:00	09:30	00:30	33 kv vcb not proper on/off to panel chack by STM	SE CITY	AE(Maint.)	No	Yes	1.16		Feeder No. 1 & 2 , shri krishna avenue colony
11	INDORE CITY	South Division	New Rani Bag	11KV	Sukhmani	CHQ	3.08.2019	10:00	10:30	00:30	Panel On/off Indication checked by STM	SE CITY	AE(Maint.)	No	Yes	0.42		11 kv Sukhamani feeder
12	INDORE CITY	Central	Rau	11KV	Rau-1	CHQ	03.08.2019	08:00	11:00	03:00	Due to 5 Span Guarding & DTR Renovation Work At Rau Over Bridge to Cancer Hospital Under IPDS	SE CITY	AE(Maint.)	No	Yes	0.5	PAPER DECLARED	Rau Bas Stand, Kanupriya nagar, Hasan ji nagar & ETC
13	INDORE CITY	Central	Pragati nagar	11KV	Pragati nagar	CHQ	03.08.2019	08:00	11:00	03:00	Due to 3 Pole Eraction & Cable Stringing & 3 Composite Line At Pragati nagar Under IPDS	SE CITY	AE(Maint.)	No	Yes	0.45	PAPER DECLARED	Pragati nagar, Krishna nagar, tiwari nagar, jawahar Nagar & Etc
14	INDORE CITY	Central	Gumasta nagar	33KV	Nagin nagar 2	CHQ	03.08.2019	17:30	18:00	00:30	VCB Trip Test work by STM	SE CITY	AE(Maint.)	Yes	Yes	NIL		No Area Affected
15	INDORE CITY	Central	Gumasta nagar	11KV	IDA-2	CHQ	03.08.2019	18:30	19:00	00:30	VCB Trip Test work by STM	SE CITY	AE(Maint.)	No	Yes	0.6		Area Affected Releted to This Feeder
16	INDORE CITY	EAST	SHALIMAR TOWNSHIP	11KV	SHALIMAR TOWNSHIP	CHQ	8/3/2019	06:30	10:30	04:00	TREE CUTTING & MAINTENANCE WORK.	SE CITY	AE(Maint.)	No	Yes	0.42	PAPER DECLARED	SHALIMAR TOWN, BAPU NAGAR AND GULAB BAG ETC.
17	INDORE CITY	EAST	SANCHAR NGR.	11KV	PAKIZA LIFE STYLE	CHQ	8/3/2019	06:30	10:30	04:00	TREE CUTTING & MAINTENANCE WORK.	SE CITY	AE(Maint.)	No	Yes	0.5	PAPER DECLARED	PAKIZA LIFE STYLE
18	INDORE CITY	North	33/11 kv Niranjan pur	11 kv	11 kv Main	CHQ	03.08.2019	16:00	16:30	00:30	VCB Trip Test work by STM	SE CITY	AE(Maint.)	No	Yes	0.35		11KV E.W.S. ,MOTHER TERESA ,ROYAL AMAR GREEN
19	INDORE CITY	North	33/11 kv Niranjan pur	11 kv	11 kv EWS	CHQ	03.08.2019	16:30	17:00	00:30	VCB Trip Test work by STM	SE CITY	AE(Maint.)	No	Yes	0.65		Mangliya rural colony,
20	INDORE CITY	North	220 North Zone	33 kv	33 kv Sector C	IX	03.08.2019	10:00	17:00	07:00	for Conductor Replacement work by STC Team	SE CITY	AE(Maint.)	yes	Yes	NIL		NIL
21	INDORE CITY	North	220 North Zone	33 kv	33 kv Zonal 1st	IX	03.08.2019	10:00	17:00	07:00	for Conductor Replacement work by STC Team	SE CITY	AE(Maint.)	yes	Yes	NIL		NIL
22	INDORE CITY	North	33/11 kv Modern	11 kv	11 kv B-1	CHQ	03.08.2019	10:00	11:00	01:00	for Jumper Disconnected work on 33 kv Sector C & Zonal 1st Seafy Purpose	SE CITY	AE(Maint.)	No	Yes	0.5		Sector F Industrial Area
23	INDORE CITY	North	33/11 kv Modern	11 kv	11 kv B-1	CHQ	03.08.2019	16:00	17:00	01:00	after work Jumper connected	SE CITY	AE(Maint.)	No	Yes	0.5		Sector F Industrial Area
24	INDORE CITY	North	33/11 kv Mahakal	11 kv	11 kv Ujjain Road	CHQ	03.08.2019	10:00	11:00	01:00	for Jumper Disconnected work on 33 kv Sector C & Zonal 1st Seafy Purpose	SE CITY	AE(Maint.)	No	Yes	0.35		
25	INDORE CITY	North	33/11 kv Mahakal	11 kv	11 kv Ujjain Road	CHQ	03.08.2019	16:00	17:00	01:00	after work Jumper connected	SE CITY	AE(Maint.)	No	Yes	0.35		
26	INDORE CITY	North	33/11 kv Sector F	11 kv	11 kv Supreme Roll	CHQ	03.08.2019	10:00	11:00	01:00	for Jumper Disconnected work on 33 kv Sector C & Zonal 1st Seafy Purpose	SE CITY	AE(Maint.)	No	Yes	0.8		Sector F Industrial Area
27	INDORE CITY	North	33/11 kv Sector F	11 kv	11 kv Supreme Roll	CHQ	03.08.2019	16:00	17:00	01:00	after work Jumper connected	SE CITY	AE(Maint.)	No	Yes	0.8		Sector F Industrial Area
28	INDORE CITY	North	33/11 kv MPSRTC	33 kv	33 kv Malti Feeder	VIII	03.08.2019	06:15	06:30	00:15	for VCB CT Red hot work	SE CITY	AE(Maint.)	yes	Yes	NIL		NIL
29	INDORE CITY	North	33/11 kv MPSRTC	11KV	5 MVA PTR No. 3	CHQ	03.08.2019	06:30	07:00	00:30	for Brekar & CT & Isolator Red hot work	SE CITY	AE(Maint.)	No	Yes	0.45		11kv ESI
30	INDORE CITY	North	33/11 kv Mangliya	11 kv	11 KV LT Consumer	CHQ	03.08.2019	06:00	09:00	03:00	8 No.Pole Erection work Near Mangliya Under IPDS	SE CITY	AE(Maint.)	No	Yes	0.35	PAPER DECLARED	Mangliya, raukhedi, sulakhedi
31	INDORE CITY	North	33/11 kv Mahalaxmi	11 kv	11 kv Goyal Evenu	CHQ	03.08.2019	06:00	09:00	03:00	8 NO. DTR Renovation work at MR-11 In front of shimlapark Under IPDS	SE CITY	AE(Maint.)	No	Yes	0.3	PAPER DECLARED	Goyal avenu,trimala green, MR-11,Reva pharm