

| M.P.P.K.V.V. C. LTD. INDORE CIRCLE | | | | | | | | | | | | | | | | | |
|------------------------------------|-------------------|---------------------|------------------------------------|--------------------------------|-------------------------------------|--|-----------------------------|------------------|-------|-------------------|--|--------------------------|-------------------------|--|---|---|---|
| S.N o | Name of Circle | NAME OF DIVISION | Name of EHV S/s or 33/11 KV S/s | Line KV Capacity (33 or 11) | Name of 33 KV / 11 KV feeder | Group (for 33KV) / Category (for 11 KV) | Planned shutdown | | | | DATE- 03.10.2019 | | | | | | |
| | | | | | | | Date of Planned Shutdown | Duration From | to | Total Duration | Reason for Planned Shutdown (Maintenance/Erection work/ FSP / Safety purpose etc.) | Shutdown Approved by- | Approval Granted to- | Alternate Supply Arrangements are available or not (Yes/No) | It has been Reported on Whatsapp Group | Demand in MW affected due to Shutdown. | Remark(Are as affected) |
| 1 | INDORE CITY | South Division | 220KV SOUTH ZONE | 33KV | 33KV PAGNISPAGA | CHQ | 02.10.2019 | 7:00 | 12:00 | 5:00 | LINE MAINTENANCE WORK | SE CITY | AE (HTM) | Yes | Yes | NIL | NIL |
| 2 | INDORE CITY | South Division | Tejaji nagar | 11 kv | Shivdham | CHQ | 03.10.2019 | 8:00 | 12:00 | 4:00 | 4no. Pole Erection work By Kshema power Under IPDS at Khandwa road | SE CITY | AE (HTM) | No | Yes | 0.7 | Pepar Declared |
| 3 | INDORE CITY | North | 33/11 kv Electronic com | 11 kv | 11 kv EC-1 | CHQ | 03.10.2019 | 9:00 | 9:30 | 0:30 | for jumper disconnected work of HT Consumer m/s ITI government college (Yard maintenance & AB Switch work) (2000 Shutdown Charge paid) | SE CITY | AE (HTM) | NO | Yes | 0.35 | Nanda nagar, Ankosh system, |
| 4 | INDORE CITY | North | 33/11 kv Electronic com | 11 kv | 11 kv EC-1 | CHQ | 03.10.2019 | 13:00 | 13:30 | 0:30 | AFTER WORK JUMPER CONNECTED | SE CITY | AE (HTM) | NO | Yes | 0.35 | Nanda nagar, Ankosh system, |
| 5 | INDORE CITY | North | 33/11 kv Khatipura | 11 kv | 11 kv sector D | CHQ | 03.10.2019 | 6:00 | 6:30 | 0:30 | For Tree Branch Remove work at near flora packaging & DTR Jumper work | SE CITY | AE (HTM) | NO | Yes | 0.45 | Sector D,& Shukla brothers khet |
| 6 | INDORE CITY | North | 33/11 kv Kabit Khedhi | 11 kv | 11 kv Chandra Gupt | CHQ | 03.10.2019 | 7:00 | 9:30 | 2:30 | for Metro Train project work at MR-10 Chouraha | SE CITY | AE (HTM) | NO | Yes | 0.5 | MR-10 Sukhliya C Sector |
| 7 | INDORE CITY | North | 33/11 kv sector c | 11 kv | 11 kv shivam gas | CHQ | 03.10.2019 | 6:00 | 6:30 | 0:30 | For Tree Branch Remove work double circuit line | SE CITY | AE (HTM) | NO | Yes | 0.25 | Sector D, Paras Udyog |
| 8 | INDORE CITY | North | 33/11 kv Vijay nagar | 11 kv | 11 kv Scheme No. 78 | CHQ | 03.10.2019 | 08:00 | 11:00 | 03:00 | for Feeder Bifurcation work by STC Team | SE CITY | AE (HTM) | NO | Yes | 0.65 | Schm.No.78, Prestige Public school |
| 9 | INDORE CITY | North | 33/11 kv Vijay nagar | 33 kv | 33 kv Scheme no. 78 1st & 2nd | CHQ | 03.10.2019 | 10:00 | 11:00 | 01:00 | for Safety Purpose work on 11 kv Scheme No. 78 | SE CITY | AE (HTM) | NO | Yes | 0.85 | 33/11 kv Scheme No 78 Grid Affected |
| 10 | INDORE CITY | EAST | KEH | 33KV | 33KV VANADNA NAGAR 2 OUTGOING | CHQ | 03.10.2019 | 6:30 | 9:30 | 3:00 | LINE MAINTENANCE & TREE CUTTING WORK | SE CITY | AE (HTM) | Yes | Yes | NIL | NIL |
| 11 | INDORE CITY | EAST | Satya-sai | 11kv | Velocity | CHQ | 03.10.2019 | 9:00 | 10:00 | 1:00 | 11 kv extation bracket work (5% supervisen charges.) | SE CITY | AE (HTM) | NO | Yes | 0.45 | MAHIDPUR WALA, VELLOCITY SINEMA AND MAHAK VATIKA, ARAWAL SHOW ETC. |
| 12 | INDORE CITY | Central | 220 / 33kv south zone | 33 kv | Bijalpur - 1 & 2 | VIII | 03.10.2019 | 09:00 | 15:00 | 06:00 | Due to Counductor Replacement Under Departmental Work | SE CITY | AE (HTM) | Yes | Yes | NIL | No Area Affected |
| 13 | INDORE CITY | Central | 220 / 33kv south zone | 33 kv | Pithampur & Harsola | VIII | 03.10.2019 | 09:00 | 15:00 | 06:00 | Due to Counductor Replacement Under Departmental Work | SE CITY | AE (HTM) | Yes | Yes | NIL | 4 no Ht Conn. Affected |
| 14 | INDORE CITY | Central | Rau | 11 KV | PTR no 1 | CHQ | 03.10.2019 | 08:30 | 09:30 | 01:00 | Due to PTR maintenance Work by STM | SE CITY | AE (HTM) | No | Yes | 0.45 | 11 KV Royal park,Rangwasa,Rau-2 Affected |
| 15 | INDORE CITY | Central | Rau | 11 KV | PTR no 2 | CHQ | 03.10.2019 | 09:30 | 10:30 | 01:00 | Due to PTR maintenance Work by STM | SE CITY | AE (HTM) | No | Yes | 0.5 | 11 KV Pigdamber IP, Piigdamber Rural, Rau-1 Affected |
| 16 | INDORE CITY | Central | Housing Board | 33 KV | panther -1 I/C | CHQ | 03.10.2019 | 12:00 | 12:30 | 00:30 | Due to VCB tasting Work by STM | SE CITY | AE (HTM) | Yes | Yes | NIL | Feeder Chang Over |
| 17 | INDORE CITY | Central | Housing Board | 33 KV | Silicon City O/G | CHQ | 03.10.2019 | 12:30 | 13:00 | 00:30 | Due to VCB tasting Work by STM | SE CITY | AE (HTM) | Yes | Yes | NIL | Feeder Chang Over |
| 18 | INDORE CITY | Central | New York City | 11 KV | PTR no 1 | CHQ | 03.10.2019 | 13:30 | 14:00 | 00:30 | Due to PTR maintenance Work by STM | SE CITY | AE (HTM) | No | Yes | 0.25 | Feeder no 1 & 2 Affected |
| 19 | INDORE CITY | Central | Gumasta nagar | 11 KV | Main no 3 | CHQ | 03.10.2019 | 17:30 | 18:00 | 00:30 | Due to VCB tasting Work by STM | SE CITY | AE (HTM) | No | Yes | 0.45 | 11 KV Sirpur & Dwarkapuri Affected |
| 20 | INDORE CITY | Central | Rau | 11 KV | Pigdamber Rural | CHQ | 03.10.2019 | 10:00 | 10:15 | 00:15 | Due to Jumper Open For AB Switch Repairing Work | SE CITY | AE (HTM) | No | Yes | 0.25 | Irgation Area Affected |
| 21 | INDORE CITY | Central | Rau | 11 KV | Pigdamber Rural | CHQ | 03.10.2019 | 12:00 | 12:15 | 00:15 | Due to Jumper Reconnected After Work | SE CITY | AE (HTM) | No | Yes | 0.2 | Irgation Area Affected |
| 22 | INDORE CITY | Central | Pragati Nagar | 11 KV | Prabhu Nagar | CHQ | 03.10.2019 | 08:00 | 08:30 | 00:30 | Due to Jumper Open For 11 KV Pole Shifat Shri pankaj Ojha Vigyan Nagar Agenst 5 % Super Vision Project. | SE CITY | AE (HTM) | No | Yes | 0.35 | 1 no DTR Affected |
| 23 | INDORE CITY | Central | Pragati Nagar | 11 KV | Prabhu Nagar | CHQ | 03.10.2019 | 11:00 | 11:30 | 00:30 | Due to Jumper Reconnected After Work | SE CITY | AE (HTM) | No | Yes | 0.35 | 1 no DTR Affected |
| 24 | INDORE CITY | WEST | 132 NORTH ZONE | 33KV | 33KV SANGAM NAGAR-2 | CHQ | 03.10.2019 | 6:00 | 6:30 | 0:30 | FOR 33KV SANGAM NAGAR-02 BUSBAR ISOLATOR REPAIR WORK. | SE CITY | AE (HTM) | YES | Yes | NIL | NIL |
| 25 | INDORE CITY | WEST | CITY CONTROL ROOM | 11KV | 11 MAIN NO.-02 | CHQ | 03.10.2019 | 6:40 | 6:55 | 0:15 | FOR 11 MAIN -2 VCB Y PHASE POLE I/C SIDE CLAMP RED HOT WORK. | SE CITY | AE (HTM) | NO | Yes | 0.7 | 11KV SHI VILASH, SANWER ROAD) |
| 26 | INDORE CITY | WEST | BAJAJ KHANA | 11KN | 11 MAIN | CHQ | 03.10.2019 | 7:05 | 7:20 | 0:15 | FOR B PHASE CT OIL LEACKERGE WORK. | SE CITY | AE (HTM) | NO | Yes | 0.45 | 11KV BAJAJ KHANA, MTC) |
| 28 | INDORE CITY | WEST | CITY CONTROL ROOM | 11KV | POLOGROUND- 02 | CHQ | 03.10.2019 | 14:00 | 14:30 | 0:30 | FOR VBC TRIP TEST WORK BY STM. | SE CITY | AE (HTM) | NO | Yes | 0.35 | Rest House, Raj Shri Eng. Ronak Pent, Pakija Festion, Super Rabar, Khatri Suplayar, Decolight & LT Consumer. |
| 29 | INDORE CITY | WEST | KILA MAIDAN | 11KN | 11 MAIN | CHQ | 03.10.2019 | 15:00 | 15:30 | 0:30 | FOR VBC TRIP TEST WORK BY STM. | SE CITY | AE (HTM) | NO | Yes | 0.45 | 11KV CHATRAPATI LAXMIBAI |
| 30 | INDORE CITY | WEST | KILA MAIDAN | 11KV | CHATRAPATI NAGAR | CHQ | 03.10.2019 | 15:30 | 16:00 | 0:30 | FOR VBC TRIP TEST WORK BY STM. | SE CITY | AE (HTM) | NO | Yes | 0.45 | Kandilpura, Laxmibai Nagar FayarBigrediyar, Bheru Tempal, DalalBag, Chhatrapati Nagar, Agrasen Nagar, Mahavir Bag, Jain Swetamber (HTC), Piliyakhan, Sanbhagiya Office. |
| 31 | INDORE CITY | WEST | GANDHI NAGAR | 33KV | 33KV GAMBHIR I/C | CHQ | 03.10.2019 | 16:30 | 17:00 | 0:30 | FOR VBC TRIP TEST WORK BY STM. | SE CITY | AE (HTM) | Yes | Yes | NIL | NIL |
| 32 | INDORE CITY | WEST | RAJMOHALLA | 11KV | FORT-02 | CHQ | 03.10.2019 | 15:00 | 15:30 | 0:30 | FOR TREE CUTTING WORK AT MAHESH NAGAR CM HELPLINE COMPLAIN NO-9161184 CONSUMER NAME. RAM KRISHNA GUPTA. | SE CITY | AE (HTM) | NO | Yes | 0.45 | Dilasan Achar, Rajmohalla Harijan Colony, Mahesh Nagar Bagicha, Panchkuya, Gangotri Vihar, Ramnagar Bheru Tempal, Ramnagar Tower. |
| 33 | INDORE CITY | WEST | BANGARDA | 11KV | SUPER CORRIDOR | CHQ | 03.10.2019 | 09:00 | 12:00 | 03:00 | Due to 2 No. DTR Charging work NEAR SUPER CORRIDOR Under IPDS | SE CITY | AE (HTM) | NO | Yes | 0.7 | Pepar Declared |
| 34 | INDORE CITY | WEST | CITY CONTROL ROOM | 11KV | BUDHANIA | CHQ | 03.10.2019 | 09:00 | 12:00 | 03:00 | Due to 3 No. Pole Eracton & 3 Span Counductor Stringing Work at budhania Under IPDS | SE CITY | AE (HTM) | NO | Yes | 0.45 | Pepar Declared |
| 35 | INDORE CITY | WEST | GANDHINAGAR | 11KV | BADA BAGARDA | CHQ | 03.10.2019 | 09:00 | 12:00 | 03:00 | Due to 3 No. Pole Eracton & 3 Span Counductor Stringing Work at bada bangarda Under IPDS | SE CITY | AE (HTM) | NO | Yes | 0.35 | Pepar Declared |
| 36 | INDORE CITY | WEST | GANDHINAGAR | 11KV | DEVDHARAM | CHQ | 03.10.2019 | 09:00 | 12:00 | 03:00 | Due to 2 No. Pole Eracton & 2 No. DTR Charging,Near devdharam Under IPDS | SE CITY | AE (HTM) | NO | Yes | 0.35 | Pepar Declared |
| 37 | INDORE CITY | WEST | NAGIN NAGAR | 11KV | RAJ NAGAR | CHQ | 03.10.2019 | 09:00 | 12:00 | 03:00 | Due to 2 No. DTR Charging work NEAR Damodar nagar Under IPDS | SE CITY | AE (HTM) | NO | Yes | 0.45 | Pepar Declared |
| 38 | INDORE CITY | WEST | SANGAM NGR. | 11KV | I.D. A. 51 | CHQ | 03.10.2019 | 09:00 | 12:00 | 03:00 | Due to 3 No. Pole Eracton & 3 Span Counductor Stringing Work at Schame No. 51 Under IPDS | SE CITY | AE (HTM) | NO | Yes | 0.45 | Pepar Declared |