

M.P.P.U.V. C. LTD. INDORE CIRCLE																
DATE: 11.08.2019																
SNo	Name of Circle	NAME OF SHEDS	Name of SHY 12 or 25/33 KV S/S	Line KV Capacity (ET or 11)	Name of 33 KV / 11 KV feeder	Group (for 230V) / Category (for 11 KV)	Date of Planned Shutdown	Duration of Planned Time	Total Duration	Reason for Planned Shutdown (Disturbance/Defective work / T/F / Safety purpose etc.)	Shutdown Approved by	Approval Granted to	Alternate Supply Arrangements are available or not (Yes/No)	It has been Reported on Whatsapp Group	Demand in MW affected due to Shutdown	Remark(s) (Area affected)
1	INDORE CITY	Central	Banashahli	11 kv	A/B & Mhow	CBO	11.08.2019	08:00	03:00	Due to Line Shutdown Work under Smart City Project	SE CITY	AE (ETM)	NO	YES	0.00	PAPER DISCLOSED
2	INDORE CITY	Central	Rajendra nagar	11 kv	Main no 2	CBO	11.08.2019	10:00	00:30	Due to Isolator Change Test Hot Work at Grid	SE CITY	AE (ETM)	NO	YES	0.05	
3	INDORE CITY	Central	Hemachand	11 kv	Feeder no 2	CBO	11.08.2019	11:00	00:20	Due to Isolator Change Test Hot Work at Grid	SE CITY	AE (ETM)	YES	YES	0.05	
4	INDORE CITY	WEST	132 KV CHAMBER	33 kv	1 C INDUSTRIAL	CBO	11.08.2019	08:00	02:00	Due to 33 KV Line Maintenance work	SE CITY	AE (ETM)	NO	YES	1.2	
5	INDORE CITY	WEST	SEHMER NO 105	11KV	SEH NO 105-06	CBO	11.08.2019	17:00	12:30	Due to VCB Fuse Problem work By STM	SE CITY	AE (ETM)	NO	YES	0.05	
6	INDORE CITY	WEST	SEHMER NO 105	11KV	SEH NO 105-02	CBO	11.08.2019	17:30	10:00	Due to VCB Spring Problem work By STM	SE CITY	AE (ETM)	NO	YES	0.5	
7	INDORE CITY	WEST	SANGAM NAGAR	11KV	SANGAM NAGAR	CBO	11.08.2019	09:30	10:00	Due to VCB C.T. Replacement work By STM	SE CITY	AE (ETM)	NO	YES	0.40	
8	INDORE CITY	WEST	GANDHI NAGAR	11KV	GANDHI NAGAR	CBO	11.08.2019	11:00	12:30	Due to VCB C.T. Replacement work By STM	SE CITY	AE (ETM)	NO	YES	0.35	
9	INDORE CITY	WEST	GANDHI NAGAR	11KV	10MVA PTR NO. 1 (G/R, RESIDENT, BANGARDA, DEVDHARAM)	CBO	11.08.2019	12:00	12:30	Due to VCB Testing work By STM	SE CITY	AE (ETM)	NO	YES	0.05	
10	INDORE CITY	WEST	SECTOR A	11KV	SECTOR A	CBO	11.08.2019	08:00	11:00	2 no. DTR Augmentation work near Pandur Polymer Under IPDS	SE CITY	AE (ETM)	NO	YES	0.00	
11	INDORE CITY	WEST	SECTOR A	11KV	AVANTIKA NAGAR	CBO	11.08.2019	08:00	11:00	2 no. DTR Augmentation work near Mansel Pagar & Success Park Under IPDS	SE CITY	AE (ETM)	NO	YES	0.70	
12	INDORE CITY	WEST	CITY CONTROL ROOM	11KV	POLIGORIND-01	CBO	11.08.2019	08:00	11:00	2 no. DTR Augmentation work near Bunkar Area Keshav Under IPDS	SE CITY	AE (ETM)	YES	YES	0.65	
13	INDORE CITY	WEST	CITY CONTROL ROOM	11KV	POLIGORIND-02	CBO	11.08.2019	08:00	11:00	Safety Purpose work on 11 kv Poligorind -1 Feeder	SE CITY	AE (ETM)	NO	YES	0.75	
14	INDORE CITY	South Division	Pada Industrial	33 kv	Pada Industrial D/G	CBO	11.08.2019	07:00	10:00	2 No. Pole Location & Conductor replacement work Near Industrial Area Under IPDS	SE CITY	AE (ETM)	YES	YES	0.2	
15	INDORE CITY	South Division	Pada Industrial	33 kv	Keshav Indus	CBO	11.08.2019	07:00	10:00	2 No. Pole Location & Conductor replacement work Near Industrial Area Under IPDS	SE CITY	AE (ETM)	NO	YES	1.60	
16	INDORE CITY	South Division	Nayabada	33 kv	Nayabada -2	VOB	11.08.2019	06:00	06:30	33 kv Indira complex no 2 1/C & O/G side Isolator Run test side B-phase Change and hot work	SE CITY	AE (ETM)	YES	YES		
17	INDORE CITY	South Division	Indira Complex	11 kv	11 kv main no 2	CBO	11.08.2019	06:00	07:00	11KV Main no 2 Isolator change test hot work	SE CITY	AE (ETM)	NO	YES	0.00	
18	INDORE CITY	North	MANGALYA	11 kv	11 kv SR FEEDER	CBO	11.08.2019	11:00	11:00	Due to 11 kv VCB Replacement work Near Shikhar Area	SE CITY	AE (ETM)	NO	YES	0.00	
19	INDORE CITY	North	MANGALYA	11 kv	11 kv SR FEEDER	CBO	11.08.2019	11:00	11:30	Due to New H.T. Breaker Connection jumper work	SE CITY	AE (ETM)	NO	YES	0.6	
20	INDORE CITY	North	MANGALYA	11 kv	11 kv SR FEEDER	CBO	11.08.2019	11:00	11:30	Due to New H.T. Breaker Connection jumper work	SE CITY	AE (ETM)	NO	YES	0.50	
21	INDORE CITY	North	132 kv Chamber	33 kv	33 kv main Indus	IB	11.08.2019	07:00	08:00	Due to Isolator Break work of 33 kv Main Feeder	SE CITY	AE (ETM)	NO	YES	0.4	
22	INDORE CITY	North	132 kv Chamber	33 kv	33 kv main Indus	CBO	11.08.2019	08:00	08:30	Due to VCB Testing Work By STM	SE CITY	AE (ETM)	NO	YES	0.30	
23	INDORE CITY	North	132 kv Chamber	33 kv	33 kv R-1	CBO	11.08.2019	09:30	09:00	Due to VCB C.T. Replacement work By STM	SE CITY	AE (ETM)	NO	YES	0.7	
24	INDORE CITY	North	200 kv North Zone	33 kv	33 kv Zone 1st	IB	11.08.2019	10:00	17:00	For Conductor Replacement work by SVC Team	SE CITY	AE (ETM)	NO	YES	0.4	
25	INDORE CITY	North	200 kv North Zone	33 kv	33 kv Section C	IB	11.08.2019	10:00	17:00	For Conductor Replacement work by SVC Team	SE CITY	AE (ETM)	YES	YES	0.30	
26	INDORE CITY	North	132 kv Jai Phari	11 kv	11 kv Jai Phari	CBO	11.08.2019	10:00	17:00	For Conductor Replacement work by SVC Team	SE CITY	AE (ETM)	NO	YES	0.60	
27	INDORE CITY	North	132 kv Jai Phari	11 kv	11 kv Jai Phari	CBO	11.08.2019	10:00	17:00	For Conductor Replacement work by SVC Team	SE CITY	AE (ETM)	NO	YES	0.52	
28	INDORE CITY	North	132 kv Jai Phari	11 kv	11 kv Jai Phari	CBO	11.08.2019	10:00	17:00	For Conductor Replacement work by SVC Team	SE CITY	AE (ETM)	NO	YES	0.5	
29	INDORE CITY	North	132 kv Jai Phari	11 kv	11 kv Jai Phari	CBO	11.08.2019	10:00	17:00	For Conductor Replacement work by SVC Team	SE CITY	AE (ETM)	NO	YES	0.50	
30	INDORE CITY	North	132 kv Jai Phari	11 kv	11 kv Jai Phari	CBO	11.08.2019	10:00	17:00	For Conductor Replacement work by SVC Team	SE CITY	AE (ETM)	NO	YES	0.50	
31	INDORE CITY	EAST	132 KVA SATYA SAI	22 KV	BOMBAY HOSPITAL	IB	11.08.2019	06:30	10:30	TREE CUTTING WORK BY NAGARGANGA	SE CITY	AE (ETM)	YES	YES		
32	INDORE CITY	EAST	NAGARGANGA	11KV	MIL AURA 2	CBO	11.08.2019	10:00	10:30	Due to VCB C.T. Replacement work By STM	SE CITY	AE (ETM)	NO	YES	0.7	
33	INDORE CITY	EAST	NAGARGANGA	11KV	MIL AURA 2	CBO	11.08.2019	10:00	10:30	Due to VCB C.T. Replacement work By STM	SE CITY	AE (ETM)	NO	YES		