

M.P.P.K.V.V. C. LTD. INDORE CIRCLE																		
S.No	Name of Circle	NAME OF DIVISION	Name of EHV S/s or 33/11 KV S/s	Line KV Capacity (33 or 11)	Planned shutdown		DATE- 24.11.2019				Reason for Planned Shutdown (Maintenance/Erection work/ FSP / Safety purpose etc.)	Shutdown Approved by -	Approval Granted to-	Alternate Supply Arrangements are available or not (Yes/No)	It has been Reported on Whatsapp Group	Demand in MW affected due to Shutdown.	Remark (Are as affected)	Remark (Areas affected)
					Group (for 33KV) / Category (for 11 KV)	Date of Planned Shutdown	Duration of From	to	Total Duration									
1	INDORE CITY	South Division	Palda industrial	11 kv	Khandelwal feeder	CHQ	24.11.2019	10:00	12:00	2:00	ME Replacement work & pole erection by STC	SE CITY	AE (Maint.)	No	YES	1.2		11 kv khandelwal feeder
2	INDORE CITY	South Division	Palda industrial	11 kv	Nayta Mundla	CHQ	24.11.2019	10:00	12:00	2:00	ME Replacement work	SE CITY	AE (Maint.)	No	YES	1.2		11 kvNayta mundala feeder
3	INDORE CITY	South Division	Palda Industrial	11 kv	Krishna pulses	CHQ	24.11.2019	8:00	12:00	4:00	4 No. Pole erection & Conductor stringing work by STC under IPDS	SE CITY	AE (Maint.)	No	YES	2.42		11 kv Krishna pulses
4	INDORE CITY	South Division	Palda industrial	11 kv	R D Uddyog Nagar	CHQ	24.11.2019	8:00	12:00	4:00	A.B. switch Installation work by kshama Power under IPDS	SE CITY	AE (Maint.)	No	YES	2.42		11 kv R D Uddyog Nagar
5	INDORE CITY	South Division	Palda industrial	11 kv	Kalindi	CHQ	24.11.2019	8:00	12:00	4:00	A.B. switch Installation work by kshama Power under IPDS	SE CITY	AE (Maint.)	No	YES	2.42		11 kv Kalindi
6	INDORE CITY	South Division	Khatiwalla Tank	11 kv	Bairathi Colony	CHQ	24.11.2019	6:30	7:00	0:30	I/C Isolatore R phase Red hot Work	SE CITY	AE (Maint.)	No	YES	0.74		11 kv Bairathi Colony
7	INDORE CITY	South Division	Khatiwalla Tank	11 kv	Mahakal feeder	CHQ	24.11.2019	7:00	7:30	0:30	B-phase CT clamp red hot work	SE CITY	AE (Maint.)	No	YES	0.46		11 kv Mahakal feeder
8	INDORE CITY	South Division	Sabji mandi	11 kv	Bijalpur	CHQ	24.11.2019	8:00	12:00	4:00	4 No. mid Span pole erection work BY kshama power under IPDS	SE CITY	AE (Maint.)	No	YES	2.42		11 kv Bijalpur.
9	Indore city	Central	Rajendra Nagar	11 KV	Annapurna	CHQ	24.11.2019	08:00	11:00	03:00	Due to DTR Installation & Charging Work at Dhanvantri nagar under IPDS	SE CITY	AE (Maint.)	No	YES	0.4		Rajendra nagar, dhhanvantri nagar, woman collage. Railway crossing takshila parisar
10	Indore city	Central	Rajmohalla	11 KV	Main no 1	CHQ	24.11.2019	06:30	06:50	00:20	Due to CT Red hot Work at grid	SE CITY	AE (Maint.)	No	YES	0.4		11 KV Fort-1 & 2 Affected
11	Indore city	Central	Pragati nagar	11 KV	Prabhu Nagar	CHQ	24.11.2019	07:00	07:20	00:20	Due to CT Red hot Work at grid	SE CITY	AE (Maint.)	No	YES	0.4		Prabhu Nagar, vigyan nagar, Saraswati nagar, umesh nagar devendra nagar & ETC
12	Indore city	Central	132/33 KV Rau	33 KV	Mhow	viii	24.11.2019	10:30	13:30	03:00	Due to 33 KV Line Maintenance After AB Switch & Line Shifting Work Under ERP Project 5 % Supervision Contractor Name. K K Tiwari ji	SE CITY	AE (Maint.)	Yes-	-	-		40 No's HT Con Affected
13	Indore city	Central	Rau	11 KV	Pigdamber IP	INDUSTRIAL	24.11.2019	10:30	11:30	01:00	Due to Sefty Perpose For 33 KV Line Crossing	SE CITY	AE (Maint.)	No	0.4	NA		Rau.mama Ji Ka Dhaba, ram Rahim Colony, HT Kisan Sheet grah & Etc
14	INDORE CITY	WEST	CITY CONTROL ROOM	11 KV	5MVA-1	CHQ	24.11.2019	8:00	8:30	0:30	FOR 11 kv jail road isolator red hot work, 11 kv main BUS BAR JUMPER RED HOT WORK	SE CITY	AE (Maint.)	No	YES	0.5		Jail Road, Urjaparisar & VIP
15	INDORE CITY	WEST	132 kv Chambal	33 KV	M.P. NAGAR-II	CHQ	24.11.2019	6:00	6:15	0:15	FOR 11 KV M.E. R-PHASE RED HOT WORK AT KILA MAIDAN S/s	SE CITY	AE (Maint.)	YES	YES	0.5		Jail Road, Urjaparisar & VIP
16	INDORE CITY	WEST	132 kv Chambal	33 KV	M.P. NAGAR-I	CHQ	24.11.2019	6:15	6:45	0:30	FOR 11 KV R-PHASE C.T. & PTR Y-PHASE RED HOT WORK AT KILA MAIDAN S/s	SE CITY	AE (Maint.)	YES	YES	0.5		Jail Road, Urjaparisar & VIP
17	INDORE CITY	WEST	Kila Maidan	33 KV	33 kv I/C M.P. NAGAR-I	CHQ	24.11.2019	6:15	6:45	0:30	FOR 11 KV R-PHASE C.T. & PTR Y-PHASE RED HOT WORK AT KILA MAIDAN S/s	SE CITY	AE (Maint.)	No	YES	0.5		Dental
18	INDORE CITY	WEST	RAJMOHALLA	11 KV	FORT-1	CHQ	24.11.2019	9:00	10:00	1:00	FOR BRACKET INSTALLATION WORK UNDER 5 % SUPERVISION AT HUKIM CHAND COLONY BY PANCHOLI	SE CITY	AE (Maint.)	No	YES	0.5		FORT-1
19	INDORE CITY	EAST	220KV-B.MARDANA	33KV	VANDANA NAGAR - 2	CHQ	24.11.2019	6:30	11:00	4:30	TREE CUTTING & INSULATOR REPALEMAINT WORK.	SE CITY	AE (Maint.)	YES.	YES	-		WILL BE SUPPLY CHANGEOVER AVALIBEL / LG GRID AFFECTED FROM (SHOUT ZONE)
20	INDORE CITY	EAST	MANORAMAGANJ GRID	33KV	DAILY COLLEGE- 1	CHQ	24.11.2019	6:30	11:00	4:30	TREE CUTTING & INSULATOR REPALEMAINT WORK.	SE CITY	AE (Maint.)	YES.	YES	-		WILL BE SUPPLY CHANGEOVER AVALIBEL / LG GRID AFFECTED FROM (SHOUT ZONE)
21	INDORE CITY	EAST	132KV-SATYA SAI	33KV	REDISSION	CHQ	24.11.2019	7:40	8:00	0:20	LOAD MANAGEMENT WORK.	SE CITY	AE (Maint.)	YES.	YES	-		WILL BE SUPPLY CHANGEOVER AVALIBEL
22	INDORE CITY	EAST	GANDHI HALL-II	33KV	OPH GRID	CHQ	24.11.2019	7:00	8:00	1:00	FOR YARD TREE CUTTING WORK.	SE CITY	AE (Maint.)	NO.	YES	0.45		11KV IDA & BUS STAND AFFECTED.
23	INDORE CITY	EAST	TUKOGANJ GRID	33KV	8MVA POWER X-MER NO.1	CHQ	24/11/2019	12:30:00	12:40:00	00:10:00	8MVA POWER X-MER NO.1 SUICA JEL REPLACEMENT WORK BY STM.	SE CITY	AE (Maint.)	NO.	YES	0.62		11KV MTH, NAYAPURA & SNEHATAGANI FEEDER AFFECTED.
24	INDORE CITY	EAST	TUKOGANJ GRID	33KV	5MVA POWER X-MER NO.2	CHQ	24/11/2019	13:30:00	14:00:00	00:30:00	5MVA POWER X-MER NO.2 SUICA JEL REPLACEMENT WORK BY STM.	SE CITY	AE (Maint.)	NO.	YES	0.42		11KV MG ROAD, SYAGANI & TEL ESSENTIAL FEEDER AFFECTED.
25	INDORE CITY	EAST	TUKOGANJ GRID	33KV	5MVA POWER X-MER NO.3	CHQ	24/11/2019	13:30:00	14:00:00	00:30:00	5MVA POWER X-MER NO.3 SUICA JEL REPLACEMENT WORK BY STM.	SE CITY	AE (Maint.)	NO.	YES	0.38		11KV NEW SYAGANI, KACHIMOHALA & REGAL TALKIES FEEDER AFFECTED.
26	INDORE CITY	EAST	MANORAMAGANJ	11KV	5MVA POWER -MER NO.3	CHQ	24/11/2019	15:00:00	15:30:00	00:30:00	5MVA POWER X-MER NO.3 CT WARING & CT INSATLL WORK BY STM.	SE CITY	AE (Maint.)	NO.	YES	0.42		11KV LALARAM NAGAR, XHARANA & TILAK NAGAR FEEDER AFFECTED.
27	INDORE CITY	EAST	MANORAMAGANJ GRID	11KV	LALARAM NAGAR	CHQ	24/11/2019	15:30:00	16:00:00	00:30:00	FOR CT INSATLL WORK BY STM.	SE CITY	AE (Maint.)	NO.	YES	0.69		MISHRA NAGAR, LALARAM NAGAR, SENT PULL SCHOOL , BADI GWALTOLI AND VARDIVHAR ETC
28	INDORE CITY	EAST	TAAJ NAGAR GRID	11KV	KALIKA MATA & RAJIV GRAM BARLA	CHQ	24/11/2019	16:30:00	17:00:00	00:30:00	11KV MAIN NO.1 CT WARING WORK BY STM.	SE CITY	AE (Maint.)	NO.	YES	0.48		KHAN KAMPAUND, DARGAH, JUM-JUM CHOURANA AND GARIB NAVAZ COLONY,HAJI COLONY, BABA FARID NAGAR, BANGALI COLONY AND PULICE INJF FTY
29	INDORE CITY	EAST	SC.NO.134	11KV	SECTOR-F	CHQ	24/11/2019	17:30:00	18:00:00	00:30:00	FOR CT WARING WORK BY STM.	SE CITY	AE (Maint.)	NO.	YES	0.64		SCHME NO. 134 , SECTOR F ETC.
30	INDORE CITY	EAST	TUKOGANJ GRID	11KV	SNEHLATAGANJ	CHQ	24/11/2019	12:30:00	13:30:00	01:00:00	FOR CT WARING & CT INSATLL WORK BY STM.	SE CITY	AE (Maint.)	NO.	YES	0.47		AGNIBAN PRESS, SNEHLATA GANJ , RALWAY MAL GODAM AND PASHU CHIKITSALAY
31	INDORE CITY	EAST	TUKOGANJ GRID	11KV	KACHIMOHALLA	CHQ	24/11/2019	14:00:00	14:30:00	00:30:00	FOR CT WARING & CT INSATLL WORK BY STM.	SE CITY	AE (Maint.)	NO.	YES	0.23		SIKHA MAHOLLA, LODHI MOHALLA, NAVELTY AND KACHIMOHALA
32	INDORE CITY	North	33/11 kv Modern	11 kv	11 KV CHOUTHASANSAR	CHQ	24.11.2019	10:00	17:00	07:00	for conductor Replacement work by STC Team	SE CITY	AE (Maint.)	no	YES	0.46		Sector E & shivkanth Nagar
33	INDORE CITY	North	33/11 kv SECTOR F	11 kv	11 KV ZEST PHARMA	CHQ	24.11.2019	10:00	17:00	07:00	FOR DP REPLACEMENT WORK complaint CM HELP LINE	SE CITY	AE (Maint.)	no	YES	0.65		Sector E & Bhavani
34	INDORE CITY	North	33/11 kv SECTOR F	11 kv	11 KV SUPREME ROLL	CHQ	24.11.2019	10:00	17:00	07:00	for conductor Replacement work by STC Team (RMU SUPPLY OFF	SE CITY	AE (Maint.)	no	YES	0.84		Ganeshdham colony, Sanwer main road, Orient wire, JP Papers
35	INDORE CITY	North	33/11 kv Sector E	11 kv	11 kv Rural	CHQ	24.11.2019	10:00	17:00	07:00	for conductor Replacement work by STC Team	SE CITY	AE (Maint.)	no	YES	0.68		Dharampuri Area
36	INDORE CITY	North	33/11 kv MAHAKAL	11 kv	11 KV BHAWANI NAGAR	CHQ	24.11.2019	10:00	17:00	07:00	FOR SEAFY PURPOSE	SE CITY	AE (Maint.)	no	YES	0.47		Sector F Industrial Area
37	INDORE CITY	North	33/11 kv MAHAKAL	11 kv	11 KV MEHANDI PUR BALAJI	CHQ	24.11.2019	10:00	17:00	07:00	for conductor Replacement work by STC Team	SE CITY	AE (Maint.)	no	YES	0.62		Sector F Industrial Area
38	INDORE CITY	North	33/11 kv MAHAKAL	11 kv	11 KV UJJAIN ROAD	CHQ	24.11.2019	10:00	17:00	07:00	FOR SEAFY PURPOSE	SE CITY	AE (Maint.)	no	YES	0.48		Sector F Industrial Area
39	INDORE CITY	North	220 north zone	33 kv	33 KV ZONAL 1ST	IX	24.11.2019	10:00	17:00	07:00	FOR SEAFY PURPOSE	SE CITY	AE (Maint.)	NO	YES	0.64		15 HT Consumer Affected
40	INDORE CITY	North	33/11 kv Sector E	11 kv	11 KV SECTOR E-1	CHQ	24.11.2019	10:00	17:00	07:00	for conductor Replacement work by STC Team	SE CITY	AE (Maint.)	no	YES	0.69		Dharampuri Area
41	INDORE CITY	North	33/11 kv Modern	11 kv	11 KV MARIMATA	CHQ	24.11.2019	10:00	17:00	07:00	for conductor Replacement work by STC Team	SE CITY	AE (Maint.)	no	YES	0.64		Sector E & shivkanth Nagar
42	INDORE CITY	North	33/11 kv Sector C	11 kv	11 KV SHIVAM GAS	CHQ	24.11.2019	10:00	17:00	07:00	for conductor Replacement work by STC Team	SE CITY	AE (Maint.)	no	YES	0.48		Sector E & shivkanth Nagar
43	INDORE CITY	North	220 north zone	33 kv	33 KV VIJAY NAGAR NO.1&2	CHQ	24.11.2019	10:00	17:00	07:00	FOR SEAFY PURPOSE	SE CITY	AE (Maint.)	YES	YES	-		SCHEME NO. 78 GRID & 2 HT CONSUMER
44	INDORE CITY	North	33/11 kv Modern	11 kv	11 KV B-1	CHQ	24.11.2019	10:00	17:00	07:00	for conductor Replacement work by STC Team	SE CITY	AE (Maint.)	no	YES	0.47		Sector E & shivkanth Nagar
45	INDORE CITY	North	220 north zone	33 kv	33 KV RAMAPHASPHET	CHQ	24.11.2019	10:30	12:30	02:00	for conductor Replacement work by STC Team	SE CITY	AE (Maint.)	yes	YES	-		15 HT Consumer Affected & MAHAKAL GRID AFFECTED
46	INDORE CITY	North	33/11 kv sector E	33 kv	33 kv Ramaphasphet o/g	CHQ	24.11.2019	10:30	12:30	02:00	for conductor Replacement work by STC Team	SE CITY	AE (Maint.)	no	YES	0.32		ht consumer

47	INDORE CITY	North	33/11 kv KHATIPURA	11 KV	11 KV SECTOR D	CHQ	24.11.2019	10:00	17:00	07:00	FOR SEAFY PURPOSE	SE CITY	AE(Maint.)	yes	YES	-		15 HT Consumer Affected
48	INDORE CITY	North	33/11 kv vijay nagar	11 KV	111 KV OLD VIJAY NAGAR	CHQ	24.11.2019	06:30	07:00	00:30	FOR I/C ISOLATOR RED HOT WORK OF 11 KV OLD VIJAY NAGAR	SE CITY	AE(Maint.)	NO	YES	0.69		Areas affected
49	INDORE CITY	North	33/11 kv vijay nagar	11 KV	11 KV MAIN NO 3	CHQ	24.11.2019	06:30	07:00	00:30	FOR I/C ISOLATOR RED HOT WORK OF 11 KV OLD VIJAY NAGAR	SE CITY	AE(Maint.)	NO	YES	0.45		11 KV RASOMA & AB ROAD & OLD VIJAY NAGAR
50	INDORE CITY	North	33/11 kv vijay nagar	11 KV	11 KV SICKA SCHOOL	CHQ	24.11.2019	07:00	07:20	00:20	FOR ME OIL LEAKAGE WORK	SE CITY	AE(Maint.)	NO	YES	0.42		Areas affected
51	INDORE CITY	North	33/11 kv mpsrtc	11 KV	11 KV MAIN NO 2	CHQ	24.11.2019	08:30	08:50	00:20	R-PHASE I/C ISOALTOR RED HOT WORK OF 11 KV MECHANIC NAGAR	SE CITY	AE(Maint.)	NO	YES	0.69		11 KV MECHANIC NAGAR & SHOPPING & ITI