

M.P.P.K.V.V. C. LTD. INDORE CIRCLE																		
S.N o	Name of Circle	NAME OF DIVISION	Name of EHV S/s or 33/11 KV S/s	Line KV Capacity	Name of 33 KV / 11 KV feeder	Planned shutdown		DATE- 26.07.2019		Total Duration	Reason for Planned Shutdown (Maintenance/Erection work/ FSP / Safety)	Shutdown Approved	Approval Granted to-	Alternate Supply Arrangements are	It has been Reported on	Demand in MW affected due to	Remark(Areas affected)	Remark (Areas affected)
						Group (for 33KV) / Category (for 11 kv)	Date of Planned Shutdown	Duration of From	to									
1	INDORE CITY	WEST	KILA MAIDAN	11 kv	CHATRAPATI NAGAR	CHQ	26.07.2019	07:00	10:00	03:00	2 POLE ERECTION & 1 DTR AUG. AT CHTRAPATI NAGAR UNDER IPDS	SE CITY	AE(Maint.)	NO	Yes	0.68	PAPER DECLARED	Kandilpura, Laxmibai Nagar FayarBigrediyar, Bheru Tempal, DalalBag, Chhatrapati Nagar, Agrasen Nagar, Mahavir Bag, Jain Swetamber (HTC), Piliyakhan, Sanbhagiya Office.
2	INDORE CITY	WEST	CITY CONTROL ROOM	11 kv	TILAKPATH	CHQ	26.07.2019	07:00	10:00	03:00	1 SPAN CONDUCTOR STRINGING & 1 DTR AUG. AT PANTHVED COLONY UNDER IPD	SE CITY	AE(Maint.)	NO	Yes	0.5	PAPER DECLARED	GPH Compound, Swadesh Press, Narayan Bagh, Malhar Aashram, Chandan Apart., Panth Vaidh Colony, Jatti Colony, Tapsya Apart., Etc.
3	INDORE CITY	South Division	Mechanic Nagar	11 kv	Sidharth Nagar	CHQ	26.07.2019	07:00	10:00	03:00	4 No. Pole Erection work Near A.B. road under IPDS	SE CITY	AE(Maint.)	NO	Yes	0.65	PAPER DECLARED	Sidharth Nagar Area or feeder
4	INDORE CITY	South Division	Univercity	11 kv	Indrapuri	CHQ	26.07.2019	07:00	10:00	03:00	4 No. Pole Erection work Near A.B. road under IPDS	SE CITY	AE(Maint.)	NO	Yes	0.8	PAPER DECLARED	Water tank, monica plaza, 329 indrapuri colony, 299 indrapuri colony,
5	INDORE CITY	South Division	Sadhu Vaswani	11 kv	5 MVA no. 1	CHQ	26.07.2019	16:00	16:30	00:30	Oil Temperature Meter checked by STM	SE CITY	AE(Maint.)	No	Yes	0.42		11kv Navlakha complex , Sadhuwasvani , Lohamandi
6	INDORE CITY	South Division	Sabji mandi	33 kv	Narang cold stores O/G	CHQ	26.07.2019	17:00	17:30	00:30	33 kv VCB Test work by STM	SE CITY	AE(Maint.)	Yes	Yes	Nil		Nil
7	INDORE CITY	South Division	Sabji Mandi	11 kv	Gayatri Nagar	CHQ	26.07.2019	17:30	18:00	00:30	11 kv feeder VCB not on/off scada control panel work by STM	SE CITY	AE(Maint.)	No	Yes	0.72		11 kv Gayatri nagar feeder
8	INDORE CITY	North	33/11 kv Scheme no 78	11 kv	11 kv main	CHQ	26.07.2019	05:30	05:45	00:15	for i/c isolator red hot work	SE CITY	AE(Maint.)	NO	Yes	0.45		11 kv Feeder no 1 & 2 & 3
9	INDORE CITY	North	33/11 kv Khatipura	11 kv	11 kv main	CHQ	26.07.2019	06:30	06:45	00:15	for grid S/S red hot work	SE CITY	AE(Maint.)	NO	Yes	0.5		11 kv khatipura & Agrawal com & sector D
10	INDORE CITY	North	33/11 kv MPSRTC	11 kv	11 kv main no. 2	CHQ	26.07.2019	07:40	08:00	00:20	B-phase I/c Isolator Red hot work of 11 kv main no. 2	SE CITY	AE(Maint.)	NO	Yes	0.25		11 kv Shopping Com & machenic nagar & ITI
11	INDORE CITY	North	33/11 kv Shilnath	11 kv	11 kv main	CHQ	26.07.2019	06:45	07:15	00:30	for R-phase I/C Isolator Red hot of 11 kv Kulkarni Bhatta & Y-phase I/C Isolator & Ct Red hot of 11 kv Shivaji nagar	SE CITY	AE(Maint.)	NO	Yes	0.65		11 kv Shivshakti nagar & shivaji nagar & over Bridge & kulkarni bhatta
12	INDORE CITY	North	33/11 kv kabit Khedi	11 kv	11 kv Shayam nagar	CHQ	26.07.2019	06:00	06:15	00:15	for CT red hot work	SE CITY	AE(Maint.)	NO	Yes	0.8		Shyam Nagar, MR-10 Road, Lavkush vihar, Jineshwar School, Sabri nagar sabji mandi, Bandhan Garden
13	INDORE CITY	North	33/11 kv sector F	11 kv	11 kv Supreme Roll	CHQ	26.07.2019	06:30	10:00	03:30	line maintenance & tree cutting work	SE CITY	AE(Maint.)	NO	Yes	0.65	PAPER DECLARED	Sector F Industrial Area
14	INDORE CITY	Central	Nagin Nagar	11 kv	Rani palace	CHQ	26.07.2019	07:00	10:00	03:00	1 NO.DTR Charging & 2 Span Conductor Straging Work near Kakad mata manidr Road Under IPDS	SE CITY	AE(Maint.)	NO	Yes	0.9	PAPER DECLARED	Bhawnipur. Pooja Hospital, Shri Ram vatika, Annapurna road, Mishra nagar, Annapurna nagar, & ETC
15	INDORE CITY	Central	Pragati nagar	11 kv	Parmanu nagar	CHQ	26.07.2019	07:00	10:00	03:00	3 Span Conductor Stringing & mid Span Pole Erection Work Sahakar nagar Reti Mandir Under IPDS	SE CITY	AE(Maint.)	NO	Yes	0.65	PAPER DECLARED	Bhawnipur. Pooja Hospital, Shri Ram vatika, Annapurna road, Mishra nagar, Annapurna nagar, & ETC
16	INDORE CITY	Central	Rajmohalla	11 kv	AIR	CHQ	26.07.2019	06:45	07:15	00:30	Due to 1 no Tree Cutting At Grid	SE CITY	AE(Maint.)	NO	Yes	0.5		Area Affected Releted to this Feeder
17	INDORE CITY	EAST	33/11KV VANDNA NAGAR	11 kv	11KV SAKET NAGAR	CHQ	26.07.2019	06:30	10:00	03:30	line maintenance & tree cutting work	SE CITY	AE(Maint.)	NO	Yes	0.65	PAPER DECLARED	SAI NATH COLONY, GOYAL NAGAR , MAN BHAVAN NAGAR, TELEPHONE EX.AND SHAKUNTALA HOSP
18	INDORE CITY	EAST	GOYAL NAGAR	11KV	GOYAL VIHAR	CHQ	26.07.2019	10:30	11:00	00:30	11kv Feeder CT REPLACEMENT BY STM	SE CITY	AE(Maint.)	NO	Yes	0.65		RADHA KRUSHAN COLONY , MAHARASHTRA BANK , SHAHNAI 2 AND PREM BANDHAN GARDEN ETC
19	INDORE CITY	EAST	BTC GRID	33 KV	MG2 IN COMMING	CHQ	26.07.2019	08:00	08:30	00:30	CONTROL RELY PENAL NOT ON/OFF PROBLEM WORK ATTEND BY STM	SE CITY	AE(Maint.)	NO	Yes	1		11KV CITY CENTER ,BASKETBALL & 56 SHOPE FEEDER AFFECTED
20	INDORE CITY	EAST	VANDNA NAGAR GRID	33 KV	VANDANA NAGAR IN COMMING	CHQ	26.07.2019	09:30	10:30	01:00	CT WIREING & CONTROL RELY PENAL NOT ON/OFF PROBLEM ATTEND BY STM	SE CITY	AE(Maint.)	Yes	Yes	NIL		NIL