| | M.P.P.K.V.V. C. LTD. INDORE CIRCLE Planned shutdown DATE- 04.08.2019 | | | | | | | | | | | | | | | | |
|----------|--|--------------------|--------------------------|------------------------|--|-------------------------|--------------------------|-------------|----------|---|------------------|----------------------|---|-------------------------------|------------------------------|-------------------|---|
| | | NAME OF | Name of EHV S/s | Line KV | Name of 33 KV / | Group (for 33KV) / | Date of | Duration of | Total | Reason for Planned Shutdown | Shutdown | Approval | Alternate Supply | It has been | Demand in MW | Remark(Area | |
| S.No | Name of Circle | DIVISION | or 33/11 KV S/s | Capacity (33 or 11) | 11 KV feeder | Category (for 11 KV) | Planned Shutdown | From to | Duration | (Maintenance/Erection work/ FSP / Safety purpose etc.) | Approved by - | Granted to- | Arrangements are available or not (Yes/No) | Reported on Whatsapp Group | affected due to Shutdown. | s affected) | Remark(Areas affected) |
| 1 | INDORE CITY | Central | Rau | 11 KV | Rau-2 | СНО | 04.08.2019 | 8:00 11:00 | 3:00 | 2 No. DTR Charging & 5 No Span Guarding Near Rua Over Bridge to Cancer Hospital Under IPDS | SE CITY | AE (HTM) | NO | YES | 0.8 | PAPER DECLARED | Rau, Saria Ward, Swastik Vihar, Shramik Colony,Kanha Park, Cancer Hospital, Shyam Sangam, Cat Road, trasure Fantesty & ETC |
| 2 | INDORE CITY | Central | Navda Panth | 11 KV | Sinhasa IP | CHQ | 04.08.2019 | 8:00 11:00 | 3:00 | 8 no Pole Eraction Work Near Bank basti Under IPDS Porject | SE CITY | AE (HTM) | NO | YES | 0.7 | PAPER DECLARED | Gram bank, Gram Sinhasa, Dhar Road, & ETC |
| 3 | INDORE CITY | Central | Gumasta nagar | 11 KV | Sirpur | СНО | 04.08.2019 | 8:00 11:00 | 3:00 | DTR renovaction & 2 no DTR Jumper Work At Green park Office & Sec-1 Under IPDS | SE CITY | AE (HTM) | NO | YES | 0.7 | PAPER DECLARED | Sirpur,Ambar nagar, Green park, Noorani nagar, Dhar Road, Chandan nagar, aam wala road, Chandu Wla Road, mishara Wala Ro0ad 7 Etc |
| | INDORE CITY | Central | Footi kothi | 11 KV | PTR no 1 | CHQ | 04.08.2019 | 5:30 5:45 | 0:15 | Due to VCB Pole Clamp Red Hot Work | | AE (HTM) | NO | YES | 1.3 | | 11 KV Ahirkhedi, Footi kothi, Vidur nagar Affected |
| | INDORE CITY | Central | Footi kothi | 11 KV | Main no 2 | CHQ | 04.08.2019 | | 0:15 | Due to Isolator Red hot Work | | AE (HTM) | NO | YES | 1 | | 11 KV prajapt Nagar, Gwala Colony, Parivahan nagar |
| - | INDORE CITY | Central | Housing Board | 11 KV | Feeder no 2 | CHQ | 04.08.2019 | | 0:15 | Due to ME Jumper Red Hot Work at Grid | | AE (HTM) | NO | YES | 0.7 | | Area affected Releted to This Feeder |
| 7 | INDORE CITY | Central Central | Rajmohalla Rajmohalla | 11 KV | Main no 1 Fort-1 | CHQ | 04.08.2019 04.08.2019 | | 0:30 | Due to VCB tasting Work by STM Due to VCB trip tast by STM | | AE (HTM) AE (HTM) | NO NO | YES YES | 1.2 0.8 | | 11 KV Fort 1 & 2 Affected West Division Area Affected |
| | INDORE CITY | Central | Rajmohalla | 11 KV | AIR | CHQ | 04.08.2019 | | 0:30 | Due to VCB trip tast by STM Due to VCB trip tast by STM | | AE (HTM) | NO NO | YES | 0.7 | | Area affected Releted to This Feeder |
| 10 | INDORE CITY | Central | Gumasta Nagar | 11 KV | Main no 1 | CHQ | 04.08.2019 | 12:30 13:00 | 0:30 | Due to VCB trip tast by STM | | AE (HTM) | NO | YES | 1 | | 11 KV Dhar Road, Dravin Nagar, IDA-2 Affected |
| 11 | INDORE CITY | Central | Pragati Nagar | 11 KV | Siddhipuram | CHQ | 04.08.2019 | 17:00 17:30 | 0:30 | Due to VCB trip tast by STM | SE CITY | AE (HTM) | NO | YES | 0.9 | | Area affected Releted to This Feeder |
| 12 | INDORE CITY | Central | Pragati Nagar | 11 KV | 5 MVA No 2 | CHQ | 04.08.2019 | 17:30 18:00 | 0:30 | Due to CT Wairing tast by STM | SE CITY | AE (HTM) | NO | YES | 1.5 | | 11 KV Sudama nagar, Parmanu nagar, Buddha nagar, Pragati nagar, D-Mart- Sch no 135 |
| 13 | INDORE CITY | South Division | Palda Industrial | 11 kv | R.D. Udyog Nagar | CHQ | 04.08.2019 | 7:00 10:00 | 3:00 | 4 no.Pole Erection work under IPDS work at Udhyog nagar | SE CITY | AE (HTM) | NO | YES | 1.58 | PAPER DECLARED | 11 kv R.D. Udyog Nagar Feeder |
| - | INDORE CITY | South Division | Navlakha Palda | 11 kv | Navlakha no.1 Khandelwal | CHQ | 04.08.2019 | 7:00 10:00 | 3:00 | 11 kv Line Maintenance work by HT Gang | SE CITY | AE (HTM) | NO | YES | 1.3 | | NAGAR WATER TANK, NIDHI APPT, SAWARAF APPT, 58 MANISH BAGH, 71 AGRAWAL NAGAR, BOMBAY MOTORS |
| | INDORE CITY | South Division | industrial 220 kv EHV | 11 kv | feeder Raiendra nagar | CHQ | 04.08.2019 | 7:00 8:00 | 1:00 | 1 no.DTR Charging work by STC 33 kv Line Pole Dismentle work at IT Park | | AE (HTM) | NO | YES | 0.67 | | 11 kv Khandelwal feeder |
| | INDORE CITY | South Division | south zone 220 kv EHV | 33 kv | & Pagnispaga Navlakha no. 1 | VIII | 04.08.2019 | 7:00 8:00 | 1:00 | Chouraha 33 kv Line Pole Dismentle work at IT Park | SE CITY | AE (HTM) | Yes | YES | Nil | | Nil |
| 17 | INDORE CITY | South Division | south zone | 33 kv | & 2 | VIII | 04.08.2019 | 8:00 9:00 | 1:00 | Chouraha 11 kv Jumper open & DTR Charging work by | SE CITY | AE (HTM) | Yes | YES | Nil | | Nil |
| 18 | INDORE CITY | South Division | Mayur nagar | 11 kv | Dhanlaxmi | CHQ | 04.08.2019 | 8:00 8:30 | 0:30 | STC at Udhyog nagar Area | SE CITY | AE (HTM) | No | YES | 0.72 | | BALAJI UDYOG,SUMIT PULSES,MAYUR NAGAR,RIDDHI SIDDHI |
| | INDORE CITY | South Division | Mayur nagar Khatiwala | 11 kv | Dhanlaxmi | CHQ | 04.08.2019 | | 0:30 | After Jumper Closed | SE CITY | AE (HTM) | No | YES | 0.56 | | BALAJI UDYOG,SUMIT PULSES,MAYUR NAGAR,RIDDHI SIDDHI |
| 20 | INDORE CITY | South Division | Tank MANORAMAG | 33 kv | Rajendra nagar | VIII | | 16:00 16:30 | 0:30 | 33 kv CT checked by STM | SE CITY | AE (HTM) | Yes | YES | Nil | PAPER | Nil GEETA BHAVAN . SHEKH HATIM HOSPITAL. GATER KAILASH AND PWD |
| 21 | INDORE CITY | EAST | ANJ RAILWAY | 11KV | KHAJRANA | CHQ | 04.08.2019 | 6:30 10:30 | 4:00 | TREE CUTTING & MAINTENANCE WORK. | SE CITY | AE (HTM) | NO. | YES | 0.9 | DECLARED | OFFICE ETC. YASHWANT PLAZA, SP OFFICE, Y.N. ROAD, SBI BANK AND DHENU MARKET |
| 22 | INDORE CITY | EAST | RESERVATION | 11KV | S.P. OFFICE SUBHASH | CHQ | | 10:00 10:30 | 0:30 | FOR CT CIRCUIT WORK. | SE CITY | AE (HTM) | NO. | YES | 0.4 | | TASHWANI PLAZA, SP OFFICE, T.N. ROAD, SBI BANK AND DHENU MARKET ETC. Gadra Khedi, Palhar Nagar. Sahu Nagar. Ramchandra Nagar Chouraha. Sadhna |
| \vdash | INDORE CITY | WEST | NAGAR SANGAM | 11 kv | MARG- 1 | CHQ | | 5:15 5:30 | 0:15 | FOR R & B PHASE CT RED HOT WORK. | | AE (HTM) | NO | YES | 1.2 | | Gadra Kneur, Painar Nagar, Sanu Nagar, Kamcnandra Nagar Chourana, Sadina Nagar, Ratlam Tower, Monika Iskrim, Snah Swits. LIC, Siment Goduwn, Rukhmani Nagar, Suvidhi, Akhand Nagar, Amrakunj, |
| 24 | INDORE CITY | WEST | NAGAR SANGAM | 11 kv | AIRODRUM- 1 SANGAM | CHQ | 04.08.2019 | 5:30 5:45 | 0:15 | FOR R & B PHASE CT RED HOT WORK. | SE CITY | AE (HTM) | NO | YES | 0.8 | | Sanwariya Nagar, Om Bihar, Shriyantr Nagar, Sahu Nagar, Krishn Nagar. Sangam Nagar, Riksha Stand. Laxmanpura, Gomti Nagar, Holmark School, IDL |
| 25 | INDORE CITY | WEST | NAGAR | 11 kv | NAGAR 8MVA PTR NO | CHQ | 04.08.2019 | 5:45 6:00 | 0:15 | FOR R PHASE CT RED HOT WORK. | SE CITY | AE (HTM) | NO | YES | 0.9 | | School. |
| 26 | INDORE CITY | WEST | CITY CONTROL ROOM | 11 kv | 3 (POLOGROUND 1 & 2, IT BUILDING) | СНО | 04.08.2019 | 8:00 8:30 | 0:30 | FOR 33KV PTR R PHASE CT RED HOT WORK BY STM & 11MAIN NO3 ISOLATOR RED HOT WORK ATTEND. | SE CITY | AE (HTM) | NO | YES | 1.3 | | All HT & LT Consumer, Jawahar Eais, Chandan Gurment, Pricizan Giyar, Print Wel Offset. |
| 27 | INDORE CITY | WEST | SANGAM NAGAR | 11 kv | 11 MAIN NO3 (RAMBALI, COMM. GROUND) | СНО | 04.08.2019 | 9:00 9:30 | 0:30 | FOR VCB MAINTENANCE WORK BY STM. | SE CITY | AE (HTM) | NO | YES | 1 | | R.K. Ind. & Commercial Ground Feeder to Relatted LT Consumer. |
| 28 | INDORE CITY | North | 220 North Zone | 33 kv | 33 kv Vijay nagar No. 1 & 2 | VIII | 04.08.2019 | 08:00 10:00 | 02:00 | for Seaty Purpose Conductor Striking work of crazycat HT Consumer All So Permit Taken by 220 North Zone | SE CITY | AE (HTM) | NO | YES | 1.5 | | Sector C Grid Affected & HT Consumer Affected |
| 29 | INDORE CITY | North | 220 North Zone | 33 kv | 33 kv Sector C | IX | 04.08.2019 | 08:00 16:00 | 08:00 | for Conductor Replacement work by STC Team | SE CITY | AE (HTM) | NO | YES | 1 | | Only HT Consumer |
| 30 | INDORE CITY | North | 220 North Zone | 33 kv | 33 kv Zonal 1st | IX | 04.08.2019 | 10:00 17:00 | 07:00 | for Conductor Replacement work by STC Team | SE CITY | AE (HTM) | NO | YES | 1.2 | | 14 no only ht consumer |
| 31 | INDORE CITY | North | 33/11 kv Modern | 11 kv | 11 kv B-1 | CHQ | 04.08.2019 | 10:00 16:00 | 06:00 | for Conductor Replacement work by STC Team | SE CITY | AE (HTM) | NO | YES | 0.6 | | Sector F Industrial Area |
| 32 | INDORE CITY | North | 33/11 kv Mahakal | 11 kv | 11 kv Ujjain Road | CHQ | 04.08.2019 | 10:00 10:30 | 00:30 | jumper Disconnected work (Conductor Replacement work) For Seafty Purpose | SE CITY | AE (HTM) | NO | YES | 0.8 | | Ujjain Road Area |
| 33 | INDORE CITY | North | 33/11 kv Mahakal | 11 kv | 11 kv Ujjain Road | CHQ | 04.08.2019 | 16:00 16:30 | 00:30 | after work Jumper connected | SE CITY | AE (HTM) | NO | YES | 0.8 | | Ujjain Road Area |
| 34 | INDORE CITY | North | 33/11 kv Modern | 11 kv | 11 kv Choutha Sansar | CHQ | 04.08.2019 | 10:00 16:00 | 06:00 | for Conductor Replacement work by STC Team | SE CITY | AE (HTM) | NO | YES | 0.8 | | Sector F Industrial Area |
| 35 | INDORE CITY | North | 33/11 kv Sector F | 11 kv | 11 kv Zest Pharma | CHQ | 04.08.2019 | 10:00 16:00 | 06:00 | for Conductor Replacement work by STC Team | SE CITY | AE (HTM) | NO | YES | 0.7 | | Jesth Pharma, Sector Industria Area |
| 36 | INDORE CITY | North | 33/11 kv Sector F | 11 kv | 11 kv MR-10 | CHQ | 04.08.2019 | 15:00 16:00 | 01:00 | for STC Team work | SE CITY | AE (HTM) | NO | YES | 0.9 | | Industrial Area, Sector F |
| 37 | INDORE CITY | North | 33/11 kv Loha Mandi | 11 kv | 11 kv Lasudiya naka | CHQ | 04.08.2019 | 06:00 09:00 | 03:00 | 5 span Gaurding Work Near Lasudiya naka Under IPDS | SE CITY | AE (HTM) | NO | YES | 0.7 | | Electronic complex parisar |
| 38 | INDORE CITY | North | 33/11 kv Kabit Khedi | 11 kv | 11 kv Bhanghra | CHQ | 04.08.2019 | 6:00 9:00 | 3:00 | NEW LINE CONDUCTOR STINGING WORK NEAR KABIT KHEDI GREED UNDER IPDS | SE CITY | AE (HTM) | NO | YES | 0.8 | PAPER DECLARED | Bhangarh village, Kabit khedi, |
| 39 | INDORE CITY | North | 33/11 kv Kabit Khedi | 11 kv | 11 kv Chandra Gupt | CHQ | 04.08.2019 | 6:00 9:00 | 3:00 | CRROSING FOR 11 kv Bhanghra FEEDER SO SAFETY PERPOS | SE CITY | AE (HTM) | NO | YES | 0.9 | PAPER DECLARED | MR-10 Sukhliya C Sector |
| 40 | INDORE CITY | North | 33/11 kv Kabit Khedi | 11 kv | 11 kv Parag nagar | CHQ | 04.08.2019 | 6:00 9:00 | 3:00 | CRROSING FOR 11 kv Bhanghra FEEDER SO SAFETY PERPOSR | SE CITY | AE (HTM) | NO | YES | 0.7 | PAPER DECLARED | Parag Nagar, Royal Bunglow, Swasth nagar |
| 41 | INDORE CITY | North | 33/11 kv Khatipura | 11 kv | 11 kv Agrawal Com | CHQ | 04.08.2019 | 13:00 14:00 | 1:00 | For DTR Replacement work at Agrawal Com | SE CITY | AE (HTM) | NO | YES | 0.8 | | Agrawal compound |
| 42 | INDORE CITY | North | 220/33 KV MANGLIYA | 33 KV | 33 KV MAHALAXMI FEEDER | VIII | 04.08.2019 | 9:00 10:30 | 1:30 | 5%SUPERVISION WORK FOR NEW HT CONNECTION JENITH EXIM | SE CITY | AE (HTM) | YES | YES | Nil | | 8 NOHT CONSUMERS, ALREADY PERMITTED BUT DUE TO RAIN PERMIT NOT GIVEN |