

M.P.P.K.V.V. C. LTD. INDORE CIRCLE																		
S.N o	Name of Circle	NAME OF DIVISION	Name of EHV S/s or 33/11 KV S/s	Line KV Capacity (33 or 11)	Name of 33 KV / 11 KV feeder	Planned shutdown		DATE- 28.07.2019			Reason for Planned Shutdown (Maintenance /rection work/ FSP / Safety purpose etc.)	Shutdown Approved by -	Approval Granted to-	Alternate Supply Arrangements are available or not (Yes/No)	It has been Reported on Whatsapp Group	Demand in MW affected due to Shutdown.	Remark(Are as affected)	Remark(Areas affected)
						Group (for 33KV) / Category (for 11 KV)	Date of Planned Shutdown	From	to	Total Duration								
1	INDORE CITY	WEST	SECTOR-A	11 kv	5 MVA PTR NO.-1 (SUNDAR NAGAR, RURAL)	CHQ	28.07.2019	15:00	15:30	00:30	FOR 5 MVA PTR HV LV SIDE CLAMP RED HOT ATTEND WORK BY STM.	SE CITY	AE(Maint.)	NO	Yes	0.85		11kv SUNDAR NAGAR, RURAL
2	INDORE CITY	WEST	132 NORTH ZONE	33 KV	33KV INDU.-A	CHQ	28.07.2019	07:00	07:15	00:15	FOR JUMPER CLOSED MUKTA ENTERPRISES HT CONSUMER SECTOR-A.	SE CITY	AE(Maint.)	NO	Yes	0.45		Industrial Area
3	INDORE CITY	WEST	CITY CONTROL ROOM	11 kv	5 MVA PTR NO.-3 ( POLOGROUND-1&2, IT BUILDING)	CHQ	28.07.2019	06:30	06:45	00:15	TREE CUTTING WORK AT S/s	SE CITY	AE(Maint.)	NO	Yes	0.7		11KV POLOGROUND- 1&2, IT BUILDING)
4	INDORE CITY	WEST	AIRPORT	11 kv	HI LINK	CHQ	28.07.2019	05:20	05:35	00:15	FOR Y PHASE CT CLAMP RED HOT WORK	SE CITY	AE(Maint.)	NO	Yes	0.8		HI-Link Area
5	INDORE CITY	WEST	ZINSI HAT	11 kv	5 MVA PTR NO.-3	CHQ	28.07.2019	05:45	06:00	00:15	FOR OUTGOING ISOLATOR Y PHASE CLAMP RED HOT WORK	SE CITY	AE(Maint.)	NO	Yes	0.5		11kv Loharpatti-1 & 2
6	INDORE CITY	WEST	SECTOR-A	11 kv	SECTOR-A	CHQ	28.07.2019	07:00	09:00	02:00	1 No. DTR Aug. Near Mangal Paper Under IPDS	SE CITY	AE(Maint.)	NO	Yes	0.35	PAPER DECLARE D	All LT Consumer & Mungad Ahu, Meta Tubey, Sciye Line, Indore Naitred, Quajer Eng., Ast Vinayak, Tirupati Printo Pek, Rajput Ind.
7	INDORE CITY	WEST	SECTOR-A	11 kv	AVANTIKA NAGAR	CHQ	28.07.2019	07:00	09:00	02:00	1 No. DTR Aug. Near Modi Wala Under IPDS	SE CITY	AE(Maint.)	NO	Yes	0.2	PAPER DECLARE D	Avantika Ngar Area
8	INDORE CITY	WEST	CITY CONTROL ROOM	11 kv	POLOGROUND-02	CHQ	28.07.2019	07:00	10:00	03:00	3 No. DTR Charging Near Shriram Udhog Under IPDS	SE CITY	AE(Maint.)	NO	Yes	0.5	PAPER DECLARE D	REST House, Raj Shri Eng. Ronak Pent, Pakija Festion, Super Rabar, Khatri Suplayar, Decolight & LT Consumer.
9	INDORE CITY	North	132 kv North Zone	33 kv	33 kv Zonal 1st	IX	28.7.2019	10:00	17:00	07:00	For Conductor Replacement work By STC	SE CITY	AE(Maint.)	yes	Yes	Yes		Nil
10	INDORE CITY	North	132 kv North Zone	33 kv	33 kv Sector C	IX	28.7.2019	10:00	17:00	07:00	For Conductor Replacement work By STC & Tree Cutting work	SE CITY	AE(Maint.)	yes	Yes	Yes	PAPER DECLARE D	Nil
11	INDORE CITY	North	33/11 kv sector F	11 kv	11 kv Supreme Roll	Ind.	28.7.2019	10:00	17:00	07:00	For Conductor Replacement work By STC	SE CITY	AE(Maint.)	NO	Yes	0.65		Sector F Industrial Area
12	INDORE CITY	North	33/11 kv sector F	11 kv	11 kv MR-10	Ind.	28.7.2019	10:00	17:00	07:00	For Conductor Replacement work By STC	SE CITY	AE(Maint.)	NO	Yes	0.8		Industrial Area, Sector F
13	INDORE CITY	North	33/11 kv sector F	11 kv	11 kv Zest pharma	Ind.	28.7.2019	10:00	17:00	07:00	For Conductor Replacement work By STC	SE CITY	AE(Maint.)	NO	Yes	0.9		Jesth Pharma, Sector Industria Area
14	INDORE CITY	North	33/11 kv Mahakal	11 kv	11 kv Ujjain Road	CHQ	28.7.2019	10:00	17:00	07:00	For Conductor Replacement work By STC	SE CITY	AE(Maint.)	NO	Yes	0.65		Ujjain Road Area
15	INDORE CITY	North	33/11 kv electronic com	33 k v	33 kv Bhartitelineaate	CHQ	28.7.2019	05:30	06:00	00:30	For Isolator red hot work	SE CITY	AE(Maint.)	NO	Yes	0.35		releted Area
16	INDORE CITY	North	33/11 kv Scheme no. 78	11 kv	11 kv Feeder no 3	CHQ	28.7.2019	06:30	07:00	00:30	For Isolator red hot work	SE CITY	AE(Maint.)	NO	Yes	0.4		Sch. No. 78 Area
17	INDORE CITY	North	220/33 Bicholi Mardana	33 KV	33 KV sanchar Nagar-II	CHQ	28.7.2019	08:00	08:15	00:15	Due To Jumper Disconnect At Vistara Grid for Maintanance work by colonizer	SE CITY	AE(Maint.)	NO	Yes	0.65		Vistara Colony
18	INDORE CITY	North	220/33 Bicholi Mardana	33 KV	33 KV sanchar Nagar-II	CHQ	28.7.2019	12:00	12:15	00:15	Due To Jumper connect At Vistara Grid After Maintanance work by colonizer	SE CITY	AE(Maint.)	NO	Yes	0.65		Vistara Colony
19	INDORE CITY	North	220/33 KV MANGLIYA	33 KV	33 KV MAHALAXMI FEEDER	CHQ	28.7.2019	09:00	10:30	01:30	5%SUPERVISION WORK FR NEW HT CONNECTION JENITH EXIM	SE CITY	AE(Maint.)	NO	Yes	0.7		HT CONSUMERS
20	INDORE CITY	North	33/11 kv electronic com	11 kv	11 kv Readymed Com	CHQ	28.7.2019	07:00	08:00	01:00	For breket installation work of consumer J.J. fashion under 5% supervision by rajesh pancholi cont.	EE Sir North	AE SAAB	no				Readymade complex parisar
21	INDORE CITY	South Division	Palda Industrial	11 kv	Krishna pulses & Kalindi	CHQ	28.7.2019	07:00	10:00	03:00	4 no. Pole Erection & Conductor replacement work near Kalindi town by Kshama power Under IPDS	SE CITY	AE(Maint.)	No	Yes	0.95	PAPER DECLARE D	11 kv Krishna pulses feeder
22	INDORE CITY	South Division	Palda Industrial	33 kv	Palda Industrial O/G	CHQ	28.7.2019	07:00	10:00	03:00	3 no. Pole Erection & Conductor replacement work near Kalindi town by Kshama power Under IPDS	SE CITY	AE(Maint.)	Yes	Yes	Nil	PAPER DECLARE D	Nil
23	INDORE CITY	South Division	University	11 kv	Ekta Nagar	CHQ	28.7.2019	07:00	10:00	03:00	3 no. Pole Erection & Line Maintenance work near Ekta nagar under IPDS	SE CITY	AE(Maint.)	No	Yes	0.45	PAPER DECLARE D	Soniya gandhi nagar, rahul gandhi nagar, ganesh nagar-1, jeet nagar, jeet nagar-2, kamdhenu park colony-1
24	INDORE CITY	South Division	220 kv south zone	33 kv	Indira complex no. 1 & 2	CHQ	28.7.2019	07:00	08:00	01:00	33 kv Line Loose Gaurding tighting work at Bilawali Talab	SE CITY	AE(Maint.)	Yes	Yes	Nil		Nil
25	INDORE CITY	South Division	Mount burg	11 kv	Main no.1	CHQ	28.7.2019	06:30	07:00	00:30	11 kv Mount burg feeder I/C side Y-phase Isolator Clamp red hot work	SE CITY	AE(Maint.)	No	Yes	0.43		11 kv Mount barg & Nayta mundla feeder & Related Areas
26	INDORE CITY	South Division	220 kv EHV south zone	33 kv	South zone no.2	CHQ	28.7.2019	08:00	08:30	00:30	33 kv feeder 3 no. CT & R,Y,B, phase I/C Isolator clamp red hot work at Navlakha Grid	SE CITY	AE(Maint.)	Yes	Yes	Nil		Nil
27	INDORE CITY	Central	Rajmohalla	11 kv	AIR & Mhow	CHQ	28.07.2019	07:00	07:30	00:30	Due to 1 no Tree Cutting Work at Grid	SE CITY	AE(Maint.)	No	Yes	0.45		Dhanwantri apartment, MOG Line, Joshi Mohilla
28	INDORE CITY	Central	Pragati Nagar	11 kv	main no 2	CHQ	28.07.2019	06:00	06:15	00:15	Due to Isolator Red hot Work	SE CITY	AE(Maint.)	No	Yes	0.65		11 Kv parmanu nagar, Sch no 135, Buddha nagar, D-mart. Sudama nagar, Pragati nagar Affected
29	INDORE CITY	Central	Pragati Nagar	33 kv	Annapura-1 I/C	CHQ	28.07.2019	06:20	06:35	00:15	Due to Isolator Red hot Work	SE CITY	AE(Maint.)	Yes	Yes	Nil		11 Kv Siddhipuram & Prabhu nagar Affected
30	INDORE CITY	Central	Rau	11 kv	All Feeder	CHQ	28.07.2019	10:00	10:30	00:30	Due to AB Switch & CT Red hot Work at Grid	SE CITY	AE(Maint.)	No	Yes	0.5		11KV PIGDAMBER-RURAL, PIGDAMMBER LP ,RAU-1 , RANGWASA ,RAU -2 ,ROYAL PARK
31	INDORE CITY	EAST	MAHALAXMI	11KV	TULSI NAGAR	CHQ	28.07.2019	07:00	07:30	00:30	FOR CT REPLACEMENT WORK	SE CITY	AE(Maint.)	No	Yes	0.65		TULASI NAGAR NAMRATA GARDEN,WWW SKY SHOP, ANKUR AANGAN AND RR AVENUE ETC.
32	INDORE CITY	EAST	MAHALAXMI	11KV	MAHALAXMI	CHQ	28.07.2019	07:30	08:00	00:30	FOR CT REPLACEMENT WORK	SE CITY	AE(Maint.)	No	Yes	0.5		MAHALAXMI NAGAR, R-SECTOR, PIONEAR COLLAGE ETC.