										DA	M.P.P.K.V.V. C. LTD. IN	DORE CIR	CLE					
S.No	Name of Circle	NAME OF	Name of EHV S/s or 33/11	Line KV Capacity	Name of 33 KV / 11 KV feeder	Group (for 33KV) / Category (for 11	Date of Planned Shutdown	Dura From	tion of	Total Duration	TE- 23.07.2019 Reason for Planned Shutdown (Maintenance/Erection work/ FSP / Safety	Shutdown Approved	Approval Granted to-	Alternate Supply Arrangements are available	It has been Reported on	Demand in MW affected due to	Remark(Area s affected)	Remark(Areas affected)
1	INDORE CITY	Central	Gumasta nagar	11 kv	Dravin nagar	CHQ	23.07.2019	07:00		03:00	1 No. NEW DTR Charging & 3 SPAN CONDUCTOR STRINGING NEAR NAKODA CHOK Under IPDS	SE CITY	AE(Maint.)	NO	Yes	0.65	PAPER DECLARE D	Nakoda Chook, Vaishnav Collage, Dravin Nagar ,Kut-Kut Bhawan & ETC
2	INDORE CITY	Central	Gumasta nagar	11 kv	Sirpur & Dhar Road	CHQ	23.07.2019	07:00	10:00	03:00	6 SPAN Conductor Straging Work Near Green Park Under IPDS	SE CITY	AE(Maint.)	NO	Yes	0.5	PAPER DECLARE D	Nooarni nagar, Green park Ambar nagar, Chandan nagar, Sirpur, Chandan Nagar Square, Aam Wala road, Loha Wala Gate, Chandu Wala Road & ETC
3	INDORE CITY	Central	Pragati Nagar	11 kv	Pragati nagar	CHQ	23.07.2019	07:00	09:00	02:00	2 NO. POLE ERECTION WORK NEAR PANI KI TANKI Work Under IPDS	SE CITY	AE(Maint.)	NO	Yes	0.45	PAPER DECLARE D	Pragati nagar, Krishna nagar, Tiwari Nagar, Rajendra nagar, P[arashar nagar & ETC
4	INDORE CITY	Central	Rau	11 kv	Pigdamber IP & Rural	CHQ	23.07.2019	07:00	09:00	02:00	3 SPAN Guarding Work NEAR NARMADA COLONY Under IPDS	SE CITY	AE(Maint.)	NO	Yes	0.65	PAPER DECLARE D	Near rau Grid, Kamal nagar, Satya Sai nagar, mama ji ka Dhaba, Near PNB Dhaba, Dugra Nagar, Sai Vihar Colony, Maa Padmawati Colony, Shri Krishna Peradise Phase 1 & 2
5	CITY	Central	Bijalpur	11 kv	Setelight & Bilawali	CHQ	23.07.2019	07:00	10:00	03:00	Tree Cutting & line Maintenance Work	SE CITY	AE(Maint.)	NO	Yes	0.6	PAPER DECLARE D	Setelight Town Ship, Haidary Town Ship, Maskin E Sefiya, Shivala Part 1 & 2 Gram Bilawali, New Bijalpur & Mundi
6	INDORE CITY INDORE	Central	Bijalpur Pragati	11 kv	Sanjay nagar	CHQ	23.07.2019		12:00	01:00	1 no Mid span Pole Erectionon 33kv Rau work by STC	SE CITY	AE(Maint.)	NO	Yes	0.65		Setelight Town Ship, Haidary Town Ship, Maskin E Sefiya, Shivala Part 1 & 2 Gram Bilawali, New Bijalpur & Mundi 11 KV parmanu nagar, Buddha nagar, Sudama nagar, Pragati
7	CITY	Central	Nagar Pragati	11 kv	Main no 2	CHQ	23.07.2019		05:20	00:20	Due to Isolator Red Hot Work at Grid	SE CITY	AE(Maint.)	NO	Yes	0.75		nagar, D-Mart,IDA-135 Affected
8	CITY	Central	Nagar Gumasta	11 kv	main no 1	CHQ	23.07.2019	05:25	05:45	00:20	Due to Isolator Red Hot Work at Grid Due to 8 MVA PTR Jumper Reparing	SE CITY	AE(Maint.)	NO	Yes	0.65		11 KV Siddhipuram & Prabhu nagar Affected
9	CITY	Central	nagar	11 kv	Main no 3	CHQ	23.07.2019	06:00	06:20	00:20	Work at Grid	SE CITY	AE(Maint.)	NO	Yes	0.7	DARRE	11 KV Sirpur & Dwarkapuri Affected
10	INDORE CITY	South Division	Tejaji nagar	11 kv	Shivdham	CHQ	23.07.2019	07:00	10:00	03:00	For Feeder bifurcationConductor Stringing work by STC at Khandwa road	SE CITY	AE(Maint.)	No	Yes	1.6	PAPER DECLARE D	khandwa road , khandwa naka sant nagar
11	INDORE CITY	South Division	220 kv EHV south zone	33 kv	Rajendra nagar	CHQ	23.07.2019	07:00	10:00	03:00	For Safety purpose work on 11kv Shivdham For 11kv triveni feeder brust cable	SE CITY	AE(Maint.)	Yes	Yes	Nil	PAPER DECLARED PAPER	Nil
12	INDORE CITY	South Division	Karbala	11 kv	Prem nagar	CHQ	23.07.2019	07:00	10:00	03:00	change work by STC at Prem nagar colony Under IPDS	SE CITY	AE(Maint.)	No	Yes	1.61	DECLARE D	18 GOPAL BAGH TOWER, LADKANA NAGAR, 55 PREM NAGAR, 2 B PREM NAGAR
13	INDORE CITY	South Division	Mayur nagar	11 kv	Nemawar road	CHQ	23.07.2019	07:00	07:30	00:30	11 kv Line Jumper Open WORK (Due to heavy rain new 11kv line damage	SE CITY	AE(Maint.)	No	Yes	0.68		mayur nagar ,shiv nagar , nemawar road
14	CITY	South Division	Mayur nagar	11 kv	Nemawar road	CHQ	23.07.2019	10:00	10:30	00:30	After Jumper Reconnection work	SE CITY	AE(Maint.)	No	Yes	0.72		mayur nagar ,shiv nagar , nemawar road
15	CITY	South Division	Sabji Mandi	11 kv	Bijalpur	CHQ	23.07.2019	10:00	10:30	00:30	200 KVA Failed DTR Replacement work At amitesh nagar	SE CITY	AE(Maint.)	No	Yes	0.49		Man Vihar,Pavan Putra Nagar,Patidar Enterprises, Ntg Appt
16	CITY	South	Univercity	11 kv	Main no.2	CHQ	23.07.2019	06:00	06:30	00:30	11 kv Main no.2 Y-phase VCB Boom clamp red hot work 11 kv Loha Mandi feeder I/C Isolator	SE CITY	AE(Maint.)	No	Yes	1.3		11 kv khatiwala tank ,Van vibhag , Anand Nagar feeder
17	INDORE CITY INDORE	South Division South	Sadhuwasv ani	11 kv	mian no. 1	CHQ	23.07.2019	06:30	07:00	00:30	B-phase Clamp red hot work	SE CITY	AE(Maint.)	No	Yes	0.86		11kv LOHA MANDINAV.COMPLEXSADHU WASWANI
18	CITY	Division	Karbala Mechanic	11 kv	Triveni feeder	CHQ	23.07.2019		09:30	00:30	11 kv CT VCB work by STM 11 kv Main no. CT Circuit work by	SE CITY	AE(Maint.)	Nil	Yes	0.62		TRIVENI NAGAR , RAJMAHAL COLONY .
19	CITY	Division	Nagar	11 kv	Main no. 1	CHQ	23.07.2019	10:00		00:30	STM 200 KVA Failed DTR Replacement	SE CITY	AE(Maint.)	No	Yes	0.75		11 kv Aditya nagar & Sidharth Nagar feeder or related Area
20	CITY	Division	NAKA 33/11 kv	11 kv	vinayak 11 kv Sector E	CHQ	23.07.2019		09:30	00:30	work line maintenance & tree cutting work	SE CITY	AE(Maint.) AE(Maint.)	No NO	Yes	0.75	PAPER	11 kv Aditya nagar & Sidharth Nagar feeder or related Area
	CITY		Sector E 132 kv		33 kv Vandana						for I/C Isolator Red hot work of 33						DECLARED	Sector E & Bhavani
22	CITY	North	Satay Sai 132 kv	33 kv	nagar	CHQ	23.07.2019		05:45	00:15	kv Vandana nagar for I/C R-phase brekar nut red hot	SE CITY	AE(Maint.)	yes	Yes	Nil		NIL
23	CITY	North	Electronic com 33/11 kv	33 kv 11 kv	33 kv ESI 1st 8 MAV PTR no . 3	CHQ	23.07.2019		06:00	00:15	work Y-phase O/G isolator red hot work	SE CITY	AE(Maint.) AE(Maint.)	yes NO	Yes	Nil 0.85		NIL 11KV Rasoma & AB road & old Vijay nagar
25	CITY INDORE	North	vijay nagar 33/11 kv	11 kv	11 kv New loha	CHQ	23.07.2019		06:45	00:15	for O/G isolator red hot work	SE CITY	AE(Maint.)	NO	Yes	0.6		
26	CITY INDORE CITY	North	33/11 kv kabit Khedi	11 kv	mandi 11 kv Shaym nagar	CHQ	23.07.2019		07:15	00:15	for b-phase CT red hot work	SE CITY	AE(Maint.)	NO	Yes	0.5		New loha mandi, Shyam Nagar, MR-10 Road, Lavkush vihar, Jineshwar School, Sabri naear sabii mandi. Bandhan Garden
27	INDORE CITY	WEST	BAJAJ KHANA	11 kv	11KV MAIN- (11 BAJAJ KHANA, 11 MTC)	СНО	23.07.2019	06:00	06:20	00:20	FOR 11 MAIN VCB POLE AND R Phase CT CLAMP, 11 MAIN BAJAJ KHANA AND 11 MTC AB SWICTH RED HOT ATTEND.	SE CITY	AE(Maint.)	NO	Yes	0.5		nagar sabi mandi, Bandhan Garden Mata Mandir, Bambai Bazar, Bajaj Khana Chouk, Bora Bakhal, Jamat Khana, Sarafa Thana, Shakar Bazar.
28	INDORE CITY	WEST	CITY CONTROL ROOM	11 kv	11 MAIN 1ST (11KV V.I.P, URJA PARISAR, JAIL ROAD)	CHQ	23.07.2019	08:00	08:30	00:30	FOR 11KV VIP B Phase CT REPLACEMENT WORK BY STM.	SE CITY	AE(Maint.)	NO	Yes	0.65		MTC Office, Neem Wali Mata, Dhut Ind., Vishisht Collage, (Iprotech. HTC).Hiting Room, IT Bilding, CMD Office, MTRU, MT Bilding.
29	INDORE CITY	EAST	K.E.H.	11KV	МҮН	CHQ	23.07.2019	06:30	07:00	00:30	for ab switch red hot attend work.	SE CITY	AE(Maint.)	NO.	Yes	0.5		MYH, CHACH NEHRU, CANCER HOSPITAL ETC.
30	INDORE CITY	EAST	KHAJRANA	11KV	BANGALI SQUARE.	CHQ	23.07.2019	07:00	07:25	00:25	for isolator red hot attend work.	SE CITY	AE(Maint.)	NO.	Yes	0.65		RIDHI-SIDHI VIHAR, MAYUR HOSPITAL ,BSNL OFFFICE AND MAYUR NAGAR ETC.
31	INDORE CITY	EAST	VANDNA NGR.	11KV	MAHADEV TOTLA	CHQ	23.07.2019	08:00	08:20	00:20	for vcb red hot attend work. By STM	SE CITY	AE(Maint.)	NO.	Yes	0.8		RAM MANDIR SAINATH COLONY, MAHAVEER NAGAR , SAVIND NAGAR AND KANDIA MAIN ROAD ETC.
32	INDORE CITY	EAST	SATYA SAI	11KV	PRESS COMPLEX OLD	CHQ	23.07.2019	11:00	11:30	00:30	for vcb on & off problem work by stm	SE CITY	AE(Maint.)	NO.	Yes	0.75		DEWAS NAKA , DOORSANCHAR, ORBITE MALL AND PU-4 ETC.
33	INDORE CITY INDORE	EAST	SANJNA PARK VANDNA	11KV	SANJNA PARK & MILAN HEIGHTS	CHQ	23.07.2019		18:30	00:30	11kv main vcb on & off problem work by stm for vcb on & off problem work by	SE CITY		NO.	Yes	1		SANJANA PARK COMLETLY,MILAN HIGHTS ETC. RAM MANDIR SAINATH COLONY, MAHAVEER NAGAR ,
34	CITY	EAST	NGR.	11KV	MAHADEV TOTLA	CHQ	23.07.2019	19:00	19:30	00:30	stm	SE CITY	AE(Maint.)	NO.	Yes	0.9		SAVIND NAGAR AND KANDIA MAIN ROAD ETC.
35	INDORE CITY INDORE	EAST	PRESS COMPLEX PRESS	11KV	SHREE NAGAR NEW PRESS	CHQ	23.07.2019		16:30	00:30	for vcb on & off problem work by stm 11kv main no.2 vcb on & off problem	SE CITY	AE(Maint.)	NO.	Yes	0.6		CHAMELI PARK , ARCHANA MEDICAL ,TILAK NAGAR AND VINOBA NAGAR ETC. PRESS COM,NAV BHARAT , NICT AND PREE PRESS,TILAK
36	CITY	EAST	COMPLEX	11KV	COMPLEX & PRABHAT KIRAN	CHQ	23.07.2019		17:00	00:30	work by stm		AE(Maint.)	NO.	Yes	0.8		NAGAR AND VINOBA NAGAR ETC.
37	INDORE CITY	EAST	COMPLEX	33KV	TULSI NAGAR	CHQ	23.07.2019	17:00	17:30	00:30	33kv incomming side vcb spring charge problem work by stm.	SE CITY	AE(Maint.)	Yes	Yes	0.9		not feeder affected.