M.P.P.K.V.V. C. LTD. INDORE CIRCLE																		
	_																	
S.N			Name of EHV S/s or 33/11 KV S/s	Line KV Capacity (33 or 11)		Group (for 33KV) / Category (for 11 KV)	Date of Planned Shutdown		tion of		ATE- 11.11.2019 Reason for Planned Shutdown (Maintenance/Erection work/ FSP / Safety purpose etc.)	Shutdown Approved by	Approval Granted to-	Alternate Supply Arrangements are available or not (Yes/No)		Demand in MW affected due to Shutdown.	Remark(Are	Remark(Areas affected)
1	INDORE CITY	WEST	220KV NORTH ZONE	11 KV	SANGAM NAGAR-3	CHQ	11.11.2019	06:00	06:30	00:30	B-PHASE ME WIREING	SE CITY	AE (HTM)	NO	YES	0.65		11kv Budhania,boriya & bhangda,DEVDHARAM, DENTAL COLLAGE
2	INDORE CITY	WEST	BANGARDA	11 KV	SUPER CORRIDOR	CHQ	11.11.2019	09:00	12:00	03:00	1NO. DTR AUG. WORK NEARHI-LINK PETROL PUMP AREA UNDER IPDS	SE CITY	AE (HTM)	NO	YES	0.5		SUPER CORRIDOR AREA
3	INDORE CITY	WEST	GANDHINAGAR	11 KV	BUDHANIA	CHQ	11.11.2019	09:00	12:00	03:00	SAFETY PURPOSE WORK ON 11KV SUPER CORRIDOR FEEDER	SE CITY	AE (HTM)	NO	YES	0.5		BUDHANIA AREA
4	INDORE CITY	CENTRAL	REVENU NAGAR	11 KV	MAHAVER NAGAR	CHQ	11.11.2019	08:00	11:00	03:00	POST MONSOON MAINTENANCE & TREE CUTTING WORK	SE CITY	AE(Maint.	No	YES	0.45		MAHAVER NAGAR AREA
5	INDORE CITY	South Division	Tejaji nagar	11 kv	shivdham	CHQ	11.11.2019	08:00	12:00	04:00	3 no. Pole Erection work under Kshema power IPDS work at Khandwa road	SE CITY	AE(Maint.	No	YES	0.79		khandwa road , khandwa naka sant nagar
6	INDORE CITY	South Division	Sadhuwaswani	11KV	Lohamandi	СНО	11.11.2019	07:00	11:00	04:00	Tree cutting & Line Maintenance work	SE CITY	AE(Maint.)	No	YES	0.64		Loha Mandi, Rajkamal Tower, 90 B Sneh Nagar, Sheel Nagar, State Bank Mandi,
7	INDORE CITY	EAST	BTC	11KV	CITY CENTER	СНQ	11.11.2019	06:30	09:00	02:30	TREE CUTTING & MAINTENANCE WORK.	SE CITY	AE(Maint.	No	YES	0.45		BTC , KASLIWAL HONDA , LAXMI TOWER AND CITY CENTER ETC.
8	INDORE CITY	EAST	132KV-SATYA SAI	33KV	BOMBAY HOSPITAL	CHQ	11.11.2019	10:00	12:00	02:00	TREE CUTTING & MAINTENANCE WORK.	SE CITY	AE(Maint.	YES.	YES	NIL		WILL BE SUPPLY CHANGEOVER AVALIBEL.