

M.P.P.K.V.V. C. LTD. INDORE CIRCLE																				
S.No	Name of Circle	NAME OF DIVISION	Name of EHV S/s or 33/11 KV S/s	Line KV Capacity (33 or 11)	Name of 33 KV / 11 KV feeder	Group (for 33KV) / Category (for 11 KV)	Planned shutdown			DATE- 08.12.2019			Reason for Planned Shutdown (Maintenance/Erection work/ FSP / Safety purpose etc.)	Shutdown Approved by :-	Approval Granted to:-	Alternate Supply Arrangements are available or not (Yes/No)	It has been Reported on Whatsapp Group	Demand in MW affected due to Shutdown.	Remark(Are as affected)	Remark(Areas affected)
							Date of Planned Shutdown	Duration of From to	Total Duration											
1	INDORE CITY	South Division	Daily College	11 kv	Moosakhedi & Industrial	CHQ	08.12.2019	07:00	07:30	00:30	11 kv Line Jumper Open Due to 1 Span Conductor Stringing work at Musakhedi areas Kshama power Under <b>IPDS</b>	SE CITY	AE(Maint.)	No	Yes	0.52		Bheel Colony,99 Moosakhedi Main Road, North Moosakhedi, Azad Nagar Kali Pulla ,Nanak Overseas, Purani LakhaniUdyog Nagar,		
2	INDORE CITY	South Division	Daily College	11 kv	Moosakhedi & Industrial	CHQ	08.12.2019	12:00	12:30	00:30	After Jumper Reconnection work Under <b>IPDS</b>	SE CITY	AE(Maint.)	No	Yes	0.46		Bheel Colony,99 Moosakhedi Main Road, North Moosakhedi, Azad Nagar Kali Pulla ,Nanak Overseas, Purani Lakhani, Jagdish Industries, 531 Udyog Nagar, Sheetal Inustries, Om Industries, 48 Udyog Nagar,		
3	INDORE CITY	South Division	Palda Industrial	11 kv	R.D. Udyog Nagar	CHQ	08.12.2019	08:00	12:00	04:00	5 Span Conductor stringing work & DTR Renovation work at Udhug nagara Nayta mundla under <b>IPDS</b>	SE CITY	AE(Maint.)	No	Yes	1.24		11 Kv R.D. Udyog Nagar Feeder		
4	INDORE CITY	South Division	Palda Industrial	33 kv	Palda Industrial O/G	CHQ	08.12.2019	08:00	12:00	04:00	4 Span Conductor stringing work & DTR Renovation work near palda under <b>IPDS</b>	SE CITY	AE(Maint.)	Yes	Yes	Nil		Nil		
5	INDORE CITY	Central	Rau	11 KV	Rangwasa	CHQ	08.12.2019	08:00	12:00	04:00	Due to 11 KV Pole Erection & DP Structure Renovation Work Near Rangwasa Under <b>IPDS</b>	SE CITY	AE(Maint.)	No	Yes	0.4		Rau. Industrial Area, Cancer Care Hospital. Ht Conn. ETC		
6	INDORE CITY	North	LOHA MNADI	11 KV	LASUDIYA NAKA	CHQ	08.12.2019	08:00	12:00	04:00	2 No. DTR RENOVATION NEAR WORK SHIVANI WATA ( PANCHAL COMPOUND) UNDER <b>IPDS</b>	SE CITY	AE(Maint.)	NO	Yes	0.42		PANCHAL COMPOUND & LASUDIYA TALAB MAIN ROAD		
7	INDORE CITY	North	MANGLIYA	11 KV	11KV SFEEDER	CHQ	08.12.2019	08:00	11:00	03:00	4 SPAN CONDUCTOR STRINGING WORK NEAR SR COMPOUND UNDER <b>IPDS</b>	SE CITY	AE(Maint.)	NO	Yes	0.39		LASUDIYA MORI & SR COMPOUND		
8	INDORE CITY	North	33/11 Kv MODERN	11 kv	11 KV C-1	CHQ	08.12.2019	10:30	17:30	07:00	2 No. pole erection work of SEEMA POWER FACTORY Under <b>IPDS</b>	SE CITY	AE(Maint.)	NO	Yes	0.25		Sector C Industrial Area		
9	INDORE CITY	North	33/11 Kv SECTOR E	11 kv	11 KV SAGAR FEEDER	CHQ	08.12.2019	10:00	10:30	00:30	FOR JUMPER DISCONNECTED WORK OF DTR RENOVATION WORK UNDER <b>IPDS</b>	SE CITY	AE(Maint.)	NO	Yes	0.35		1 NO DTR AFFECTED		
10	INDORE CITY	North	33/11 Kv SECTOR E	11 kv	11 KV SAGAR FEEDER	CHQ	08.12.2019	15:00	15:30	00:30	AFTER WORK JUMPER CONNECTED UNDER <b>IPDS</b>	SE CITY	AE(Maint.)	NO	Yes	0.46		1 NO DTR AFFECTED		
11	INDORE CITY	North	33/11 kv SECTOR C	11 kv	11 KV SHIVAM GAS	CHQ	08.12.2019	10:00	17:00	07:00	FOR CONDUCTOR REPLACEMENT WORK BY <b>STC</b>	SE CITY	AE(Maint.)	NO	Yes	0.32		Sector D, Paras Udyog		
12	INDORE CITY	North	33/11 Kv MAHAHAL	11 kv	11 KV MEHANDI PUR	CHQ	08.12.2019	10:00	17:00	07:00	FOR CONDUCTOR REPLACEMENT WORK BY <b>STC</b>	SE CITY	AE(Maint.)	NO	Yes	0.28		Sector D, Paras Udyog		
13	INDORE CITY	North	33/11 Kv MAHAHAL	11 kv	11 KV BHAWANI NAGAR	CHQ	08.12.2019	10:00	14:00	04:00	FOR SAFETY PURPOSE BY <b>STC</b>	SE CITY	AE(Maint.)	NO	Yes	0.64		Sector D, Paras Udyog		
14	INDORE CITY	North	220 NORTH ZONE	33 KV	33 KV ZONAL 1ST	IX	08.12.2019	10:00	17:00	07:00	FOR SAFETY PURPOSE BY <b>STC</b>	SE CITY	AE(Maint.)	NO	Yes	0.42		14 HT CONSUMER AFFECTED		
15	INDORE CITY	North	33/11 Kv SECTOR E	11 kv	11 KV SECTOR E-1	CHQ	08.12.2019	10:00	17:00	07:00	FOR CONDUCTOR REPLACEMENT WORK BY <b>STC</b>	SE CITY	AE(Maint.)	NO	Yes	0.3		Sector E & shivikantn Nagar		
16	INDORE CITY	North	33/11 Kv SECTOR E	11 kv	11 KV SECTOR E	CHQ	08.12.2019	10:00	17:00	07:00	FOR SAFETY PURPOSE BY <b>STC</b>	SE CITY	AE(Maint.)	NO	Yes	0.15		Sector E & Bhavani		
17	INDORE CITY	North	220 NORTH ZONE	33 KV	33 KV VIJAY NAGAR 1&2	VII	08.12.2019	10:00	17:00	07:00	FOR CONDUCTOR REPLACEMENT WORK BY <b>STC</b>	SE CITY	AE(Maint.)	NO	Yes	0.65		2 HT CONSUMER AFFECTED & SCHEME NO. 78		
18	INDORE CITY	North	33/11 Kv MODERN	11 kv	11 KV B- 1	CHQ	08.12.2019	10:00	17:00	07:00	FOR CONDUCTOR REPLACEMENT WORK BY <b>STC</b>	SE CITY	AE(Maint.)	NO	Yes	0.72		Sector F Industrial Area		
19	INDORE CITY	North	33/11 Kv MODERN	11 kv	11 KV CHOUTHASANSAR	CHQ	08.12.2019	10:00	17:00	07:00	FOR SAFETY PURPOSE BY <b>STC</b>	SE CITY	AE(Maint.)	NO	Yes	0.34		Sector F Industrial Area		
20	INDORE CITY	North	33/11 Kv MODERN	11 kv	11 KV MARIMATA	CHQ	08.12.2019	10:00	17:00	07:00	FOR SAFETY PURPOSE BY <b>STC</b>	SE CITY	AE(Maint.)	NO	Yes	0.2		Ganeshdham colony, Sanwer main road, Orient wire, JP Papers		
21	INDORE CITY	North	33/11 Kv SECTOR F	11 kv	11 KV ZEST PHARMA	CHQ	08.12.2019	10:00	17:00	07:00	FOR D P RENOVATION WORK BY <b>STC</b>	SE CITY	AE(Maint.)	NO	Yes	0.65		Jesth Pharma, Sector Industrial Area		
22	INDORE CITY	North	33/11 Kv MODERN	11 kv	11 KV RURAL	CHQ	08.12.2019	10:00	17:00	07:00	FOR SAFETY PURPOSE BY <b>STC</b>	SE CITY	AE(Maint.)	NO	Yes	0.42		Maruti Nagar		
23	INDORE CITY	West	City Control Room	11 KV	Pologround- I	CHQ	08.12.2019	11:00	12:00	01:00	Due to 100 KVA DTR Charging work Kunal Marketing at Pologround by <b>STC</b>	SE CITY	AE(Maint.)	NO	Yes	0.2		Pologround		
24	INDORE CITY	Central	Rajmohalla	11 KV	AIR	CHQ	08.12.2019	07:00	12:00	05:00	Due to Line Shifting Work For Road Widening Work At Jaipur Colony to Gorakund Under <b>Smart City Project</b>	SE CITY	AE(Maint.)	No	Yes	0.4	NA	Vardhman Nagar,Arjun Pura, Dargha Square, Silawat Pura, balda Colony, Chatripura, & Etc		
25	INDORE CITY	South Division	220 kv south zone	33 kv	Daily college no. 1 & 2	CHQ	08.12.2019	07:00	11:00	04:00	33 kv Line maintenance & Tree cutting work	SE CITY	AE(Maint.)	Yes	Yes	0.34		11 kv Silver Spring F - 1 & 11 kv feeder		
26	INDORE CITY	Central	Gumasta nagar	11 KV	IDA-1	CHQ	08.12.2019	08:00	11:00	03:00	Due to Post mansoon Tree Cutting & Line maintenance Work	SE CITY	AE(Maint.)	No	Yes	0.4		GNT Market, Mali Mohalla. Sch no 71 Sec A labhriya Bheru & ETC		
27	INDORE CITY	West	132 kv Chambal	33 kv	M.P. NAGAR-I & II	CHQ	08.12.2019	07:00	12:00	05:00	Due to Post mansoon Tree Cutting & Line maintenance Work	SE CITY	AE(Maint.)	Yes	Yes	-		1 No. H.T. Consumer Affected		
28	INDORE CITY	EAST	132KV-SATYA SAI	33KV	BOMBAY HOSPITAL	CHQ	08.12.2019	10:00	12:00	02:00	LINE MAINTENANCE & TREE CUTTING WORK.	SE CITY	AE(Maint.)	yes.	Yes	-		WILL BE SUPPLY CHANGEOECER AVALIBEL.		
29	INDORE CITY	South Division	Daily College	11 kv	Main no. 3	CHQ	08.12.2019	06:30	07:00	00:30	11 kv Industrial feeder O/G R-phase Isolator clamp red hot work at yard	SE CITY	AE(Maint.)	No	Yes	0.72		11 kv feeder Stadium , Industrial		
30	INDORE CITY	South Division	Palda Industrial	11 kv	Main no. 2	CHQ	08.12.2019	07:30	08:00	00:30	11 kv main no.2 CT R,Y-phase red hot work & Isolator /ME clamp red hot work at yard	SE CITY	AE(Maint.)	No	Yes	1.29		11 kv Khandel wal , Vinayak , Kalindi feeder		
31	INDORE CITY	South Division	220 kv south zone	33 kv	Indira complex no. 2	CHQ	08.12.2019	08:00	08:30	00:30	33 kv feeder Y-phase VCB Pole Clamp red hot work at Indira complex grid	SE CITY	AE(Maint.)	No	Yes	0.83		11 kv All feeder		
32	INDORE CITY	Central	Housing Board	11 KV	Feeder no 1	CHQ	08.12.2019	06:30	07:00	00:30	Due to ME Bushing Red hot Work at Grid	SE CITY	AE(Maint.)	No	Yes	0.4		Housing Board Colony		
33	INDORE CITY	Central	Rau	11 KV	Rau-2	CHQ	08.12.2019	06:30	07:00	00:30	Due to ME Bushing Red hot Work at Housing Board Feeder no 1 For Safety Purpose	SE CITY	AE(Maint.)	No	Yes	0.4		Rau ,Shramik Colony, Sarla Wad, Swastik Vihar, kanha park, Cancer Hospital & Etc		
34	INDORE CITY	Central	Annapurna	11 KV	Main no 1	CHQ	08.12.2019	07:15	07:45	00:30	Due to Y- Phase Isolator Clamp Red Hot Work	SE CITY	AE(Maint.)	No	Yes	0.4		11 KVV paraspar nagar & Dashara maidan Affected		
35	INDORE CITY	Central	Footi Kothi	11 KV	Vidur Nagar	CHQ	08.12.2019	14:30	16:00	01:30	Due to Isolator Replacement & Repairing Work at Grid	SE CITY	AE(Maint.)	No	Yes	0.4		Cat Road, Rishi nagar, Digvijay Multy,Hawabangla Road & Etc		
36	INDORE CITY	North	33/11 Kv UG	11 kv	11 KV OLD PALASIYA	CHQ	08.12.2019	06:30	07:00	00:30	R-PHASE I/C ISOLATOR RED CLAMP HOT WORK	SE CITY	AE(Maint.)	NO	Yes	0.68		Shopping complex, Industry House, Onam Plaza, Sanjivni nursing home, Hotel Anantaa, RK Puram colony, sanjay udyan, Dev nagar.		
37	INDORE CITY	North	220 NORTH ZONE	33 KV	33 KV SECTOR C	CHQ	08.12.2019	06:30	07:00	00:30	DUE TO R-PHASE ME I/C CLAMP RED HOT WORK OF 33 KV SECTOR C	SE CITY	AE(Maint.)	YES	Yes	-		HT CONSUMER		
38	INDORE CITY	EAST	BTC	11KV	56 SHOP	CHQ	08.12.2019	06:30	07:30	01:00	FOR 11 KV FEEDER ME INSTALLATION WORK	SE CITY	AE(Maint.)	NO.	Yes	0.67		56 SHOPS, DALPHIN HOSPITAL,GNAGOUR SWEETS AND CHAIN SINGH KA BAGEECH ETC.		
39	INDORE CITY	EAST	SATYA SAI	11KV	VELOCITY	CHQ	08.12.2019	07:30	08:30	01:00	FOR 11 KV FEEDER ME INSTALLATION WORK	SE CITY	AE(Maint.)	NO.	Yes	0.24		MAHIDPUR WALA, VELOCITY SINEMA AND MAHAQ VATIKA, ARAWAL SHOW ETC.		
40	INDORE CITY	EAST	132KV-SATYA SAI	33KV	TULSI NAGAR	CHQ	08.12.2019	08:30	10:00	01:30	FOR ME & CT AND AB SWITCH RED HOT ATTEND WORK.	SE CITY	AE(Maint.)	yes.	Yes			WILL BE SUPPLY CHANGEOECER AVALIBEL.		
41	INDORE CITY	EAST	RAILWAY RESERVATION	33KV	8MVA POWER X-MER	CHQ	08.12.2019	09:00	10:00	01:00	8MVA POWER X-MER MAINTENANCE WORK BY <b>STM</b>	SE CITY	AE(Maint.)	NO.	Yes	64		11KV S.P. OFFICE & CHHOTI GWALTOLI AFFECTED.		
42	INDORE CITY	EAST	KEH GRID	33KV	10MVA POWER X-MER	CHQ	08.12.2019	10:30	11:30	01:00	10 MVA POWER X-MER MAINTENANCE WORK BY <b>STM</b>	SE CITY	AE(Maint.)	NO.	Yes	0.35		11KV MYH , R.N.T & NEHRU PARK AFFECTED.		
43	INDORE CITY	EAST	GOYAL NAGAR	33KV	5 MVA POWER X-MER NO.1	CHQ	08.12.2019	13:00	14:00	01:00	5 MVA POWER X-MER NO.1 MAINTENANCE WORK BY <b>STM</b>	SE CITY	AE(Maint.)	yes.	Yes	-		WILL BE SUPPLY CHANGEOECER AVALIBEL.		

44	INDORE CITY	EAST	GOYAL NAGAR	33KV	5 MVA POWER X-MER NO.2	CHQ	08.12.2019	14:00	15:00	01:00	5 MVA POWER X-MER NO.2 MAINTENANCE WORK BY <b>STM.</b>	SE CITY	AE(Maint.)	yes.	Yes	-	WILL BE SUPPLY CHANGEDOCER AVALIBEL.
45	INDORE CITY	EAST	GOYAL NAGAR	11KV	BIJLI NGR.	CHQ	08.12.2019	15:00	15:30	00:30	FOR 11 KV VCB ON-OFF PROBLEM WORK BY <b>STM.</b>	SE CITY	AE(Maint.)	NO.	Yes	0.25	LOKHANDWALA , BANGALI CHOURHA, BIJALI NAGAR AND ANCHAL NAGAR ETC