

| M.P.P.K.V.V. C. LTD. INDORE CIRCLE | | | | | | | | | | | | | | | | | | |
|------------------------------------|-------------------|---------------------|------------------------------------|--------------------------------|---------------------------------|--|-----------------------------|------------------|----------|-------------------|---|---------------------------|-------------------------|--|---|--|--|--|
| S.N o | Name of Circle | NAME OF DIVISION | Name of EHV S/s or 33/11 KV S/s | Line KV Capacity (33 or 11) | Name of 33 KV / 11 KV feeder | Group (for 33KV) / Category (for 11 KV) | Date of Planned Shutdown | Planned shutdown | | | Reason for Planned Shutdown (Maintenance/Erection work/ FSP / Safety purpose etc.) | Shutdown Approved by - | Approval Granted to- | Alternate Supply Arrangements are available or not (Yes/No) | Demand in MW affected due to Shutdown. | | Areas affected | |
| | | | | | | | | From | to | Total Duration | | | | | | | | |
| 1 | INDORE CITY | EAST | SHALIMAR PALM | 11KV | HOTEL TASSALI | CHQ | 06.01.2019 | 7:30:00 | 7:50:00 | 0:20:00 | FOR X-MER JUMPER CONNECTED WORK. | SE CITY | AE(Maint.) | NO. | 1 | | AKASH HOSPITAL, HOTL TASALI , SAMPAT AVENUE AND BLUE WATER PARK | |
| 2 | INDORE CITY | EAST | VANDNA NGR. | 11KV | VANDNA NGR. | CHQ | 06.01.2019 | 7:00:00 | 7:20:00 | 0:20:00 | FOR GIRD RED HOT ATTEND WORK. | SE CITY | AE(Maint.) | NO. | 0.85 | | SWARN VATIKA , PARICHARIKA NAGAR, GEETA NAGAR , PADMAVATI COLON AND GIRDHAR NAGAR ETC. | |
| 3 | INDORE CITY | EAST | MAHALAXMI | 33KV | 8MVA POWER X-MER | CHQ | 06.01.2019 | 10:00:00 | 10:15:00 | 0:15:00 | 8MVA POWER X-MER NO.2 OIL TOPPING WORK BY STM. | SE CITY | AE(Maint.) | NO. | 2 | | 11KV TULSI NAGAR FEEDER AFFECTED. | |
| 4 | INDORE CITY | EAST | MAHALAXMI | 33KV | 10MVA POWER X-MER | CHQ | 06.01.2019 | 10:15:00 | 10:30:00 | 0:15:00 | 10MVA POWER X-MER NO.4 OIL TOPPING WORK BY STM. | SE CITY | AE(Maint.) | NO. | 2 | | 11KV GOYAL AVENUE & NIPANIYA FEEDER AFFECTED. | |
| 5 | INDORE CITY | EAST | TUKOGANJ | 33KV | 8MVA POWER X-MER | CHQ | 06.01.2019 | 15:20:00 | 15:50:00 | 0:30:00 | 8MVA POWER X-MER NO.1 OIL LEKAGE WORK BY STM. | SE CITY | AE(Maint.) | YES. | NIL | | WILL BE SUPPLY CHANGEOVER AVALIBEL. | |
| 6 | INDORE CITY | EAST | TUKOGANJ | 33KV | GANDHI HALL - II | CHQ | 06.01.2019 | 16:00:00 | 16:30:00 | 0:30:00 | 33KV INCOMMING SIDE CT REPLACEMAINT WORK BY STM. | SE CITY | AE(Maint.) | YES. | NIL | | WILL BE SUPPLY CHANGEOVER AVALIBEL. | |
| 7 | INDORE CITY | Central | Bijalpur | 11KV | Setelight | CHQ | 06.01.2019 | 10:30 | 12:30 | 2:00:00 | Due to ERP Project Line Shif. Work P/D Shutdown | SE CITY | AE(Maint.) | No | 0.5 | | Setelight, town Ship, Haidary Town Ship. Maskin E Sefiya, Shivalaya Colony | |
| 8 | INDORE CITY | Central | Rau | 11KV | Rau-2 | CHQ | 06.01.2019 | 11:00 | 14:00 | 3:00:00 | Due to IPDS Work After AB Switch open P/D Shutdown | SE CITY | AE(Maint.) | No | 1.1 | | Rau, Shramik Colony, Sari Ward, Swastik Vihar,Kanha Park Shyam Sangam, Cat Road, Cancer Hospital, Surya | |
| 9 | INDORE CITY | Central | Footi Kothi | 11KV | Prajapat Nagar | CHQ | 06.01.2019 | 10:00 | 12:00 | 2:00:00 | Due to ERP Project Line Shif. Work P/D Shutdown | SE CITY | AE(Maint.) | No | 0.7 | | Mandir, Traesure Fatensty ,A,M,B Foods & ETC | |
| 10 | INDORE CITY | Central | Footi Kothi | 11KV | Gwala Colony | CHQ | 06.01.2019 | 10:00 | 12:00 | 2:00:00 | Due to ERP Project Line Shif. Work P/D Shutdown | SE CITY | AE(Maint.) | No | 0.4 | | Prajapat nagar, Shanti nath Puri, Sai baba Nagar, Dwarkapuri,Aakash nagar, HT Conn, Anand Foods | |
| 11 | INDORE CITY | Central | 220 KVA South Zone | 33KV | Bijalpur, 1 & 2 | VIII | 06.01.2019 | 10:00 | 14:00 | 4:00:00 | Due to Line Maintenance & Double Jumpering Work | SE CITY | AE(Maint.) | Yes | NIL | | Sch no 71 Sec D, Ring Road, Gwala Colony | |
| 12 | INDORE CITY | Central | Revenue nagar | 11KV | 8 MVA no 1 | | 06.01.2019 | 13:00 | 13:20 | 0:20:00 | Due to VCB tasting Work by STM | SE CITY | AE(Maint.) | No | 1.2 | | No Area Affected | |
| 13 | INDORE CITY | Central | Footi Kothi | 11KV | Gwala Colony | CHQ | 06.01.2019 | 14:00 | 14:20 | 0:20:00 | Due to VCB tasting Work by STM | SE CITY | AE(Maint.) | No | 0.4 | | 11 KV Feeder Chang Over | |
| 14 | INDORE CITY | South Division | Indracomplex | 11 kv | Shankar bagh | CHQ | 06.01.2019 | 6:30:00 | 6:45:00 | 0:15:00 | 11 kv Feeder O/G side Isolator r-phase clamp & Male female connect replacement work | SE CITY | AE(Maint.) | No | 0.39 | | Sch no 71 Sec D, Ring Road, Gwala Colony | |
| 15 | INDORE CITY | South Division | Indira Complex | 11 kv | 5 MVA no. 3 | _ | 06.01.2019 | 6:30:00 | 6:45:00 | 0:15:00 | 5 MVA Transformer no. 3 Y-phase CT I/C side red hot work | SE CITY | AE(Maint.) | No | 0.72 | | Shankar Bagh ,Kalali Mohalla , Dhobi Ghat | |
| 16 | INDORE CITY | South Division | Khatiwala tank | 11 kv | 5 MVA no. 2 | _ | 06.01.2019 | 7:30:00 | 7:45:00 | 0:15:00 | 11 kv Main no.2 Y-phase CT I/C & O/G side clamp red hot work | SE CITY | AE(Maint.) | No | 0.67 | | Janki nagar ,opp. Vishal tower-1 , opp. Vishal tower-2 ,indra complex ,opp. Krishna boys hostel , ida quarter,darga ke piche, ida quarter, nr radio colony, jank dal mil,shariff dal mil, billariya quarter, teen ekka, visarjan ashram, rnt marg, agrasen trading | |
| 17 | INDORE CITY | North | 132 KV NORTH ZONE | 33 KV | 33 KV RAMAPHASPHE | IX | 06.01.2018 | 12:00:00 | 15:00:00 | 3:00:00 | FOR CONDUCTOR AUGAMTENTION WORK | SE CITY | AE(Maint.) | YES | NIL | | 11 kv Virsawarkar ,saifee feeder or area SAIFE NAGAR GARDEN, OPP. SAIF NAGAR,VINAR APPT | |
| 18 | INDORE CITY | North | 132 KV NORTH ZONE | 33 KV | 33 KV SANGHAM NAGAR 3 & 4 | VIII | 06.01.2018 | 12:00:00 | 15:00:00 | 3:00:00 | FOR CONDUCTOR AUGAMTENTION WORK | SE CITY | AE(Maint.) | YES | NIL | | ONLY HT CONSUMER AFFECTED | |
| 19 | INDORE CITY | North | 132 KV NORTH ZONE | 33 KV | 33 KV SANWER FEEDER | VIII | 06.01.2018 | 12:00:00 | 15:00:00 | 3:00:00 | FOR CONDUCTOR AUGAMTENTION WORK | SE CITY | AE(Maint.) | YES | NIL | | ONLY HT CONSUMER AFFECTED | |
| 20 | INDORE CITY | North | 33/11 KV KHATIPURA | 11 KV | 11 KV SECTOR D | CHQ | 06.01.2018 | 10:30:00 | 10:50:00 | 0:20:00 | FOR FIALED TRANSFORMER REPLACEMENT WORK (AMERGENCY PLANNED | SE CITY | AE(Maint.) | NO | 0.85 | | ONLY HT CONSUMER AFFECTED | |
| 21 | INDORE CITY | North | 33/11 KV VIJAY NAGAR | 11 KV | 11 kv MAIN NO. 1 | CHQ | 06.01.2018 | 8:50:00 | 9:20:00 | 0:30:00 | FOR VCB WORK BY STM TEAM | SE CITY | AE(Maint.) | NO | 1.5 | | Sector D& Shukla brothers khet | |
| 22 | INDORE CITY | North | 132 KV NORTH ZONE | 33 KV | 33 KV SECTOR C | IX | 06.01.2018 | 12:00:00 | 15:00:00 | 3:00:00 | FOR CONDUCTOR AUGAMTENTION WORK | SE CITY | AE(Maint.) | YES | NIL | | 11 KV 54 & SUKHLIYA | |
| 23 | INDORE CITY | North | 33/11 KV MODERN | 11 KV | 11 KV C-2 | CHQ | 06.01.2018 | 12:00:00 | 15:00:00 | 3:00:00 | FOR IPDS WORK | SE CITY | AE(Maint.) | NO | 0.85 | | ONLY HT CONSUMER AFFECTED | |
| 24 | INDORE CITY | North | 33/11 KV MANGLIYA | 11 KV | 11 KV SDA COMPUND | CHQ | 06.01.2018 | 13:00:00 | 14:00:00 | 1:00:00 | FOR IPDS WORK | SE CITY | AE(Maint.) | NO | 1 | | Sector C Industrial Area | |
| 25 | INDORE CITY | North | 33/11 KV MAHALAXMI | 11 KV | 11 KV NIPANIYA | CHQ | 06.01.2018 | 12:00:00 | 13:00:00 | 1:00:00 | FOR IPDS WORK | SE CITY | AE(Maint.) | NO | 0.5 | | RAHUL GHANDI NAGAR & SDA COMP. | |
| | | | | | | | | | | | | | | | | | NIPANIYA GAV | |