

M.P.P.K.V.V. C. LTD. INDORE CIRCLE																				
S.No	Name of Circle	NAME OF DIVISION	Name of EHV S/s or 33/11 KV S/s	Line KV Capacity (33 or 11)	Name of 33 KV / 11 KV feeder	Planned shutdown				DATE- 05.12.2019				Shutdown Approved by	Approval Granted to:	Alternate Supply Arrangements are available or not (Yes/No)	It has been Reported on Whatsapp Group	Demand in MW affected due to Shutdown.	Remark(Are as affected)	Remark(Areas affected)
						Group (for 33KV) / Category (for 11 KV)	Date of Planned Shutdown	Duration of From	to	Total Duration	Reason for Planned Shutdown (Maintenance/ Erection work/ FSP / Safety purpose etc.)									
1	INDORE CITY	Central	Pragati nagar	11 KV	Siddhipuram	CHQ	05.12.2019	08:00	11:00	03:00	Due to 2 No. DTR Augmentation Work at Siddhipuram Colony Under IPDS	SE CITY	AE(Maint.)	No	YES	0.4	Paper Declared	Vaishali nagar Ahilya nagar, Braj Vihar Colony, Siddhipuarm & Etc		
2	INDORE CITY	Central	Annapurna	11 KV	Paraspar nagar	CHQ	05.12.2019	08:00	11:00	03:00	2 Span conductor stringing & 1 No. DTR Charging work at Lucky beakery, Road crossing Under IPDS	SE CITY	AE(Maint.)	No	YES	0.74	Paper Declared	Paraspar nagar, pricanco Colony, Gopur Square, Sahjivan nagar, & Etc		
3	INDORE CITY	EAST	SATYA SAI	11KV	BHAGAT SINGH	CHQ	05.12.2019	10:00	10:30	00:30	1 No. DTR CHARGING WORK BEHIND HDFC BANK UNDER IPDS	SE CITY	AE(Maint.)	NO.	YES	0.45		METRO TOWER, SATYA SAI SCHOOL, GUJARATI SCHOOL, TOTAL HELPS AND PRESTIGE INSTITUTE ETC.		
4	INDORE CITY	EAST	PRESS COMPLEX	11KV	SHREE NAGAR	CHQ	05.12.2019	12:00	12:30	00:30	1 No. DTR CHARGING WORK NEAR MAIN GOURDEN UNDER IPDS	SE CITY	AE(Maint.)	NO.	YES	0.36		SHRI NAGAR, RAVI NAGAR, CHAMELI PARK , PRIYDARSHINI COLONY VINOBA NAGAR ETC.		
5	INDORE CITY	EAST	VANDNA NGR.	11KV	RAVINDRA NGR. /PIPLIYAHANA	CHQ	05.12.2019	13:30	14:00	00:30	1 No. DTR CHARGING WORK NEAR MUKTI DHAM UNDER IPDS	SE CITY	AE(Maint.)	NO.	YES	0.28		CHAMELI PARK , ARCHANA MEDICAL, TILAK NAGAR AND VINOBA NAGAR ETC.		
6	INDORE CITY	EAST	TAAJ NAGAR	11KV	RAJIV GRAM BARLA	CHQ	05.12.2019	14:30	15:30	01:00	EXTATION BREACKET 5% SUPERVISION WORK NEAR PANI KI TANKI BY CONTACTOR ISHRAR	SE CITY	AE(Maint.)	NO.	YES	0.67		HAJI COLONY, BABA FARID NAGAR, BANGALI COLONY AND PULICE LINE ETC.		
7	INDORE CITY	Central	Silicon City	11 KV	Main no 2	CHQ	05.12.2019	13:00	14:00	01:00	Due to Isolator Repairing Work At Grid	SE CITY	AE(Maint.)	No	YES	0.4		11 KV Feeder no 3 Affected		
8	INDORE CITY	Central	Silicon City	11 KV	Main no 3	CHQ	05.12.2019	14:00	15:00	01:00	Due to Isolator Repairing Work At Grid	SE CITY	AE(Maint.)	No	YES	0.68		11 KV Feeder no 4 & 5 Affected		
9	INDORE CITY	South	Navlakha	33 kv	Indra complex no .2	CHQ	05.12.2019	06:30	07:00	00:30	Due to B- Phase Bus Side Isolator Clamp Red Hot Work at Yard	SE CITY	AE(Maint.)	Yes	YES	Nil		Nil		
10	INDORE CITY	South	Indra complex	11 kv	Jaora compound	CHQ	05.12.2019	07:00	10:00	03:00	Due to Tree cutting & Line maintenance work	SE CITY	AE(Maint.)	No	YES	1.34		11 kv jaora compound		
11	INDORE CITY	South	LG	11 kv	Shivaji vatica	CHQ	05.12.2019	10:30	13:00	02:30	Due to Tree cutting & Line maintenance work	SE CITY	AE(Maint.)	No	YES	1.45		11 kv shivaji vatica		
12	INDORE CITY	North	VIJAY NAGAR	11 KV	11 KV SICCKA SCHOOL	CHQ	05.12.2019	15:00	16:00	01:00	FOR NEW HT CONNECTION WORK OF M/S UIGHT FITNESH	SE CITY	AE(Maint.)	No	YES	0.68		11 KV SICCKA SCHOOL		
13	INDORE CITY	EAST	MANORMAGANJ GRID	33 KV	8 MVA PTR No.2	CHQ	05.12.2019	06:30	07:30	01:00	33 KV CT REPL. WORK AND MILL AREA 1, 2 ISOLATER MAINTANANCE WORK	SE CITY	AE(Maint.)	NO.	YES	0.95		MILL AERA 1, 2 FEEDER ARE ATTECTED		
14	INDORE CITY	EAST	SATYA SAI	11KV	VELOCITY	CHQ	05.12.2019	10:00	11:00	01:00	11 KV FEEDER M.E. REPLACEMENT WORK	SE CITY	AE(Maint.)	NO.	YES	0.67		VELOCITY SHOROOM AND DEVKI NAGAR		