

M.P.P.K.V.V. C. LTD. INDORE CIRCLE																		
S.No	Name of Circle	NAME OF DIVISION	Name of EHV S/s or 33/11 KV S/s	Line KV Capacity (33 or 11)	Planned shutdown			DATE- 12.09.2019 & 13.09.2019			Reason for Planned Shutdown (Maintenance/Erection work/ FSP / Safety purpose etc.)	Shutdown Approved by -	Approval Granted to-	Alternate Supply Arrangements are available or not (Yes/No)	It has been Reported on Whatsapp Group	Demand in MW affected due to Shutdown.	Remark(Areas affected)	Remark(Areas affected)
					Name of 33 KV / 11 KV feeder	Group (for 33KV) / Category (for 11 KV)	Date of Planned Shutdown	Duration of From	to	Total Duration								
1	INDORE CITY	WEST	PAGNIS PAGA	11KV	11 MIAN-01 (HARSIDDHI , PIPLI BAZAR)	CHQ	12.09.2019	05:30	06:00	00:30	FOR 11KV HARSIDDHI 1/C+ O/G ISOLATOR JUMPER RED HOT WORK.	SE CITY	AE(Maint.)	No	YES	0.45		11kv HARSIDDHI & PIPLI BAZAR)
2	INDORE CITY	WEST	NAGIN NAGAR	11KV	VIJAYSHREE NSGSR	CHQ	12.09.2019	10:00	11:00	01:00	FOR 100KVA DTR REPLACEMENT AT NAGIN NAGAR NARMADA WATER TANK NEAR BADE CUA.	SE CITY	AE(Maint.)	No	YES	0.25		Near Grid, VijayShri Nagar, Maruti Palace, Old Wine Shop, JayShri Nagar, Annu Aata Chaki, Tejaji Tempal, Mata Tempal, Rajnagar Munna Elec., Watar Tank Nagin Nagar.
3	City circle	South Division	Palda Industrial	11 kv	Krishna pulses	CHQ	12.09.2019	06:00	06:30	00:30	11 kv feeder O/G Isolator B-phase I/C Clamp red hot work at Yard	SE CITY	AE(Maint.)	No	YES	0.46		11 kv Krishna pulses feeder & related Areas
4	City circle	South Division	Sabji Mandi	11 kv	Rajendra Nagar	CHQ	12.09.2019	06:30	07:00	00:30	11 kv feeder B-phase CT Clamp red hot work at Yard	SE CITY	AE(Maint.)	No	YES	0.52		Bijalpur Chouraha, Kesharbag Road ,Tata Tower , Amitesh Nagar. Atg Appt Amitesh Ngar.
5	City circle	South Division	Palda industrial	11 kv	Kalindi feeder	CHQ	13.09.2019	08:00	12:00	04:00	2 Span Conductor Stringing work By IPDS at Bypass road	SE CITY	AE(Maint.)	No	YES	2.12	PAPER DECLERD	Kalindi Feeder , Bypass road