

| M.P.P.K.V.V. C. LTD. INDORE CIRCLE | | | | | | | | | | | | | | | | | | | | |
|------------------------------------|----------------|------------------|--------------------------------|-----------------------------|-------------------------------|--|--------------------------|------------------|-------|------------------|--|---------|--|----------------------|----------------------|---|--|---------------------------------------|---|------------------------|
| S.No | Name of Circle | NAME OF DIVISION | Name of HV S/s or 33/11 KV S/s | Line KV Capacity (11 or 13) | Name of 33 KV / 11 KV feeder | Group (for 13KV / Category (for 11 KV) | Planned shutdown | | | DATE- 03.09.2019 | | | Reason for Planned Shutdown (Maintenance/Erection work /FSP / Safety purpose etc.) | Shutdown Approved by | Approval Granted to: | Alternate Supply Arrangements are available or not (Yes/No) | It has been Reported on Whatsapp group | Demand in MW affected due to Shutdown | Remark(Are as affected) | Remark(Areas affected) |
| | | | | | | | Date of Planned Shutdown | Duration of From | To | Total Duration | | | | | | | | | | |
| 1 | INDORE CITY | WEST | 220 SOUTH ZONE | 33KV | 33 KV NAULAKHA - 02 | CHQ | 3.09.2019 | 07:00 | 11:00 | 04:00 | FOR GANESH UTSAV /HANKI ROUTE MAINTENANCE WORK. | SE CITY | AE(Maint.) | YES | YES | Nil | | | Nil | |
| 2 | INDORE CITY | WEST | PAGNIS PAGA | 11KV | PIPLI NBAZAR | CHQ | 3.09.2019 | 07:00 | 11:00 | 04:00 | FOR GANESH UTSAV /HANKI ROUTE MAINTENANCE WORK. | SE CITY | AE(Maint.) | NO | YES | 0.25 | | | Pipli Bazar, Ram Laxman Bazar, Yasoda Mata Mandir, Imambada, Gopal Mandir Nakoda Tower, Samosa Corner, Atala Bazar. | |
| 3 | INDORE CITY | WEST | PAGNIS PAGA | 11KV | YASHWANT ROAD | CHQ | 3.09.2019 | 07:00 | 11:00 | 04:00 | FOR GANESH UTSAV /HANKI ROUTE MAINTENANCE WORK. | SE CITY | AE(Maint.) | NO | YES | 0.35 | | | Flower Market, Gandhi Bhawan, GuruDwara, Kanungo Bakhal, State Bank Rajwada, Bata Shorom, Shani Tempal, Salvi Bakhal, Old Wain Shop, Tai Ki Gali, Sindh Karanchi, RamLaxman Muthi, Mohanpura, Nagarchi Bakhal, Dhan Gali, Gitanjali Anant, Agra Hotel. | |
| 4 | INDORE CITY | WEST | PAGNIS PAGA | 11KV | KRISHNAPURA | CHQ | 3.09.2019 | 07:00 | 11:00 | 04:00 | FOR GANESH UTSAV /HANKI ROUTE MAINTENANCE WORK. | SE CITY | AE(Maint.) | NO | YES | 0.25 | | | Chadrabhaga Pul, Kabuter Khana, Sona Kohinoor, Resham Wala Len, LaxmiNarayan Tempal, Mangal Sadan, Pandri Nath Police Station, Pandri Nath Tempal. | |
| 5 | INDORE CITY | WEST | MP NAGAR | 11KV | VRINDAVAN | CHQ | 3.09.2019 | 12:00 | 13:00 | 01:00 | FOR 100KVA DTR REPLACEMENT WORK AT GOVIND COLONY | SE CITY | AE(Maint.) | NO | YES | 0.65 | | | Valmiki Nagar, Sanjay Furniture, Maharana Pratap Nagar, Water Tank Valmiki Nagar, Govind Colony, Malw Bharti, Kali Bawdi Branch, Ahilya Nagar. | |
| 6 | INDORE CITY | WEST | COTY CONTROL ROOM | 11KV | POLOGROUND-01 | CHQ | 3.09.2019 | 05:30 | 06:00 | 00:30 | FOR O/G ISOLATER B PHASE REPIER WORK ATTEND. | SE CITY | AE(Maint.) | NO | YES | 0.35 | | | All HT & LT Consumer, Jawahar Eais, Chandan Gurment, Pricizan Giyar, Print Wel Offset. | |
| 7 | INDORE CITY | WEST | SCH 155 | 11KV | 11MAIN (11KV 155- NO-1,2,3,4) | CHQ | 3.09.2019 | 06:40 | 07:00 | 00:20 | FOR B PHASE CT O/G SIDE CLAM RED HOT WORK. | SE CITY | AE(Maint.) | NO | YES | 0.35 | | | 11KV 155 FEEDER NO.1 &2,3,4 | |
| 8 | INDORE CITY | WEST | SECTOR-A | 11KV | SECTOR-A | CHQ | 3.09.2019 | 07:10 | 07:25 | 00:15 | FOR I/C ISOLATER B PHASE CLAMP RED HOT WORK. | SE CITY | AE(Maint.) | NO | YES | 0.25 | | | All LT Consumer & Mungad Aliu, Meta Tubey, Scye Line, Indore Natred, Quajer Eng, Ast Vinayak, Tirupati Printo Pek, Rajput Ind. | |
| 9 | INDORE CITY | WEST | SECTOR-A | 11KV | SUNDAR NAGAR | CHQ | 3.09.2019 | 07:25 | 07:40 | 00:15 | FOR B PHASE O/G CLAMP RED HOT WORK. | SE CITY | AE(Maint.) | NO | YES | 0.5 | | | Ramnagar, Bajran Nagar, Vijayvargyi Nagar, Om Eat Bhatta, Sundar Nagar, Jagdish Nagar, Prince Nagar, Roshan Nagar, Pushpa Nagar, Piru Pahalwan Rishi Nagar, Kushvash Shree Nagar. | |
| 10 | INDORE CITY | WEST | PAGNIS PAGA | 11KV | PTR NO 1,2,3 (1BY1) | CHQ | 3.09.2019 | 07:00 | 11:00 | 04:00 | FOR MAINTENANCE WORK & RED HOT WORK BY STM | SE CITY | AE(Maint.) | NO | YES | 0.6 | | | 11KV MOTTIABALLA, PALSIKAR, HARRSIDDIHI, PIPLI BAZAAR, YASWANT ROAD, KRASHNPURA | |
| 11 | INDORE CITY | WEST | KILA MAIDAN | 11KV | CHATRAPATI NAGAR | CHQ | 3.09.2019 | 09:00 | 12:00 | 03:00 | FOR 3 SPAN CONDUCTOR STRINGING WORK AT CHATRAPATI NAGAR UNDER IPDS. | SE CITY | AE(Maint.) | NO | YES | 0.45 | PAPER DECLARED | | Kandilpura, Laxmibai Nagar FayarBigdriyar, Bheru Tempal, DalalBag, Chhatrapati Nagar, Agrasen Nagar, Mahavir Bag, Jain Sweetamber (HTC), Piliyakhan, Sanbhagiya Office. | |
| 12 | INDORE CITY | WEST | SANGAM NAGAR | 11KV | SUBHASH MARG- 01&02 | CHQ | 3.09.2019 | 09:00 | 12:00 | 03:00 | FOR RMU CHARGING WORK BY MEGA WIN UNDER IPDS WORK. | SE CITY | AE(Maint.) | NO | YES | 0.5 | PAPER DECLARED | | Gadra Khedi, Palhar Nagar, Sahu Nagar, Ramchandra Nagar Chouraha, Sadhna Nagar, Ratlam Tower, Monika Iskrim, Snah Swits. | |
| 13 | INDORE CITY | WEST | SANGAM NAGAR | 11KV | KAVERI NAGAR | CHQ | 3.09.2019 | 09:00 | 12:00 | 03:00 | FOR 1 NO DTR CHARGING WORK AT YOGESH MEHTA HOME UNDER IPDS. | SE CITY | AE(Maint.) | NO | YES | 0.4 | PAPER DECLARED | | Sch. No. 51 Mim. Area, Rajput Wala, Shubham Nagar, Kavery Nagar, Mama Patty, Leck Palace, Garib Nawaj, Mahavir Nagar, Saket Dham, Shrinath Vilhar, Shubham Palace, Kedar Nagar, Poonam Wala. | |
| 14 | INDORE CITY | WEST | SANGAM NAGAR | 11KV | SANGAM NAGAR | CHQ | 3.09.2019 | 09:00 | 12:00 | 03:00 | FOR1 NO. DTR CHARGING WORK NEAR LAXMANPURA UNDER IPDS. | SE CITY | AE(Maint.) | NO | YES | 0.35 | PAPER DECLARED | | Sangam Nagar, Riksha Stand, Laxmanpura, Gonti Nagar, Holmark School, IDL School. | |
| 15 | INDORE CITY | North | 33/11 kv Electronic.com | 11 kv | 11 kv EC-1 & Nanda nagar | CHQ | 03.09.2019 | 06:30 | 11:00 | 04:30 | line maintenance & tree Cutting work | SE CITY | AE(Maint.) | NO | YES | 0.5 | PAPER DECLARED | | Nanda nagar, Ankoish system. | |
| 16 | INDORE CITY | North | 33/11 kv 114 | 11 kv | 11 kv Sant nagar | CHQ | 03.09.2019 | 14:00 | 16:00 | 02:00 | for Conductor Stringing work by STC Team | SE CITY | AE(Maint.) | NO | YES | 0.65 | | | Sant Nagar, Rajpal Toyota, 12 bunglow, Patel motors | |
| 17 | INDORE CITY | North | 33/11 kv Khatipura | 33 KV | 33 KV Sector D O/G | CHQ | 03.09.2019 | 13:00 | 13:30 | 00:30 | For ME Change work of HT Consumer Modern Lab Load Increase | SE CITY | AE(Maint.) | NO | YES | 0.5 | | | Only HT Consumer | |
| 18 | INDORE CITY | North | 33/11 kv Khatipura | 33 KV | 33 KV Sector D O/G | CHQ | 03.09.2019 | 17:00 | 17:30 | 00:30 | After Work Jumper Connect | SE CITY | AE(Maint.) | NO | YES | 0.5 | | | Only HT Consumer | |
| 19 | INDORE CITY | North | 33/11 kv MPSRTC | 11 kv | 11 kv ITI | CHQ | 03.09.2019 | 11:00 | 13:00 | 02:00 | For Vidhayak Ramesh Mendola work DTR Maintenance | SE CITY | AE(Maint.) | NO | YES | 0.65 | | | Area Affected | |
| 20 | INDORE CITY | North | 33/11 kv 114 | 5MVA | 5MVA PTR No.2 | CHQ | 03.09.2019 | 17:00 | 17:30 | 00:30 | For VCB Work By STM Team | SE CITY | AE(Maint.) | NO | YES | 1 | | | Lal Banglow & Sant Nagar | |
| 21 | INDORE CITY | Central | Rau | 11 kv | Pigdamber IP & Rural | CHQ | 03.09.2019 | 08:00 | 11:00 | 03:00 | Due to3 No. DTR Charging , Jumping & Guarding Tighting Work at Near Rau Grid kanal nagar, Satyasia nagar, Near mama Ji Ka Dhaba Under IPDS | SE CITY | AE(Maint.) | NO | YES | 0.4 | PAPER DECLARED | | Rau, Mama ka Dhaba,ram rahim Colony, Kishan Sheet Grah, Jhumar Ghat, Shri Krishna Paradise, Maa padmawati Colony & ETC | |
| 22 | INDORE CITY | Central | Rajmohalla | 11 kv | AIR & Mhow | CHQ | 03.09.2019 | 08:00 | 11:00 | 03:00 | Due to 2 No.DTR Aug. at Samajwad nagar;MOG Line, Balda Colony Under IPDS | SE CITY | AE(Maint.) | No | YES | 0.65 | PAPER DECLARED | | Samaj Wad Nagar, Swastik Nagar, MOG Line Balda Colony, Cloth Market, taran Pushkar & ETC | |
| 23 | INDORE CITY | Central | Revenue nagar | 11 kv | Usha nagar | CHQ | 03.09.2019 | 08:00 | 11:00 | 03:00 | Due to DP Pole Erection & DTR Installation at Usha rage Maglik Parisar Near Usha nagar Under IPDS | SE CITY | AE(Maint.) | No | YES | 0.5 | PAPER DECLARED | | Usha Nagar, Usha nagar EXT, Mhow Naka, mahalaxmi mandir & Etc | |
| 24 | INDORE CITY | Central | Annarpurna | 11 kv | Paraspur nagar | CHQ | 03.09.2019 | 08:00 | 11:00 | 03:00 | 2 Span Conductor Stringing Work at Road Crossing Near Chankya Puri Square under IPDS | SE CITY | AE(Maint.) | No | YES | 0.35 | PAPER DECLARED | | Pricanco Colony, Sudama nagar, Paraspur nagar, Gopur Sqrae, Sahjiwan nagar & ETC | |
| 25 | INDORE CITY | Central | Rajmohalla | 33 KV | Rajmohalla Zonal | CHQ | 03.09.2019 | 13:00 | 13:30 | 00:30 | Due to Isolator Red Hot Work At Gumasta nagar Grid | SE CITY | AE(Maint.) | Yes | YES | Nil | | | 11 KV Dhar Road, Dravin nagar, IDA-2 Affected | |
| 26 | INDORE CITY | Central | 220 South Zone | 33 KV | Rau | VIII | 03.09.2019 | 06:30 | 07:00 | 00:30 | Due to I/C Isolator Red hot Work at Rajendra nagar S/S | SE CITY | AE(Maint.) | Yes | YES | Nil | | | No Area Affected | |
| 27 | INDORE CITY | Central | Annarpurna | 11 kv | Paraspur nagar | CHQ | 03.09.2019 | 12:30 | 13:00 | 00:30 | Due to VCB Trip Tasting Work by STM | SE CITY | AE(Maint.) | NO | YES | 0.4 | | | Pricanco Colony, Sudama nagar, Paraspur nagar, Gopur Sqrae, Sahjiwan nagar & ETC | |
| 28 | INDORE CITY | Central | Rajendra nagar | 11 kv | Main no 2 | CHQ | 03.09.2019 | 13:30 | 14:00 | 00:30 | Due to CT Replacement Work by STM | SE CITY | AE(Maint.) | NO | YES | 0.35 | | | 11 KV AIR & vaishali nagar Affected | |
| 29 | INDORE CITY | Central | Rajendra nagar | 11 kv | Main no 1 | CHQ | 03.09.2019 | 14:30 | 15:00 | 00:30 | Due to CT Replacement Work by STM | SE CITY | AE(Maint.) | No | YES | 0.95 | | | 11 Kv Annapura & Sukniwas Affected | |
| 30 | INDORE CITY | Central | Bijalpur | 11 kv | Bilawali | CHQ | 03.09.2019 | 16:00 | 16:30 | 00:30 | Due to CT Replacement Work by STM | SE CITY | AE(Maint.) | NO | YES | 0.25 | | | Datta Cold Storage, Mohammadi Town Ship, Ghapti gram ,Gram Bilawali & Etc | |
| 31 | INDORE CITY | South Division | Univercty | 11 kv | Khandwa naka | CHQ | 03.09.2019 | 07:00 | 10:00 | 03:00 | 2 No.Pole Erection work by Kshema power under IPDS scheme work at Khandwa naka road areas | SE CITY | AE(Maint.) | No | YES | 1.73 | PAPER DECLARED | | SOYABEAN CENTER, NANAK NAGAR, 1SHIVAM NAGAR, | |
| 32 | INDORE CITY | South Division | Navlakha | 33 kv | Indira complex no. 1 | CHQ | 03.09.2019 | 06:00 | 06:30 | 00:30 | 33 kv feeder Bas side AB switch B-phase Nabh clamp red hot work | SE CITY | AE(Maint.) | Yes | YES | Nil | | | Nil | |
| 33 | INDORE CITY | South Division | Navlakha 1 | 11 kv | Chitawad | CHQ | 03.09.2019 | 06:30 | 07:00 | 00:30 | 11 kv feeder ME R-phase I/C or O/G side clamp red hot work at Yard | SE CITY | AE(Maint.) | No | YES | 0.42 | | | CHITAWAD , NEMAWAR ROAD , SAJAN NAGAR PETROLPUMP, | |
| 34 | INDORE CITY | South Division | Navlakha | 11 kv | Main no. 1 | CHQ | 03.09.2019 | 06:30 | 07:00 | 00:30 | 11 kv main no.1 R-phase CT clamp red hot work | SE CITY | AE(Maint.) | No | YES | 0.62 | | | Mahadev dal mil, 62 prakash nagar, 107 prakash nagar, b-5 shiv kripa colony, sajan nagar dal mil, kalyan dal mil, brejhashwari tower, kk udvog nagar, kalyan dal mil ke pass | |
| 35 | INDORE CITY | South Division | Indira Complex | 33 kv | Bas Cupler | CHQ | 03.09.2019 | 07:00 | 07:30 | 00:30 | 33 kv bas bar side I/C Isolator Y-phase clamp red hot work at Yard | SE CITY | AE(Maint.) | NO | YES | 1.34 | | | Janki nagar .opp. Vishal tower-1 , opp. Vishal tower-2 ,indra complex .opp. Krishna boys hostel , ida quarter,darga ke piche, ida quarter, nr radio colony, jank dal mil,sharif dal mil, billariva quarter, teen ekikka, visarian ashram, rit mara, agrasen trading | |
| 36 | INDORE CITY | South Division | Indira Complex | 11 kv | Main no. 3 | CHQ | 03.09.2019 | 07:00 | 07:30 | 00:30 | 11 kv main no. 3 B-phase CT Clamp red hot work | SE CITY | AE(Maint.) | No | YES | 0.42 | | | Sanwad nagar ,Indira complex Areas | |
| 37 | INDORE CITY | South Division | Universtiy | 33 kv | Pagnishpaga | CHQ | 03.09.2019 | 09:00 | 09:30 | 00:30 | 33 kv feeder B-phase VCB pole clamp red hot work at Yard | SE CITY | AE(Maint.) | Yes | YES | Nil | | | Nil | |
| 38 | INDORE CITY | EAST | 132KV CHAMBEL | 33KV | M.G. -1 & M.G.- 2 | CHQ | 03.09.2019 | 06:30 | 10:30 | 04:00 | LINE MAINTENANCE & TREE CUTTING WORK. | SE CITY | AE(Maint.) | Yes | YES | Nil | PAPER DECLARED | | CHANGE OVER WILL BE AVAILABLE | |
| 39 | INDORE CITY | EAST | 140 PANTHER LINE | 11KV | SC.NO.140 TANKI WALA GRID | CHQ | 03.09.2019 | 11:00 | 11:30 | 00:30 | 11KV MAIN NO.1 SIDE AB SWITCH BLOWN JUMPER ATTEND WORK. | SE CITY | AE(Maint.) | NO. | YES | 0.45 | | | SC.NO.140 TANKI WALA GRID | |
| 40 | INDORE CITY | EAST | VANDANA NAGAR II | 33KV | RAILWAY RES GRID | CHQ | 03.09.2019 | 10:00 | 10:20 | 00:20 | 33KV SIDE CT RED HOT ATTEND WORK. | SE CITY | AE(Maint.) | NO. | YES | 0.35 | | | RAILWAY RES GRID | |