

M.P.P.K.V.V. C. LTD. INDORE CIRCLE																		
	Planned shutdown										DATE- 06.12.2019							
S.No	Name of Circle	NAME OF DIVISION	Name of EHV S/s or 33/11 KV S/s	Line KV Capacity (33 or 11)	Name of 33 KV / 11 KV feeder	Group (for 33KV) / Category (for 11 KV)	Date of Planned Shutdown	Duration of From to		Total Duration	Reason for Planned Shutdown (Maintenance/Erection work/ FSP / Safety purpose etc.)	Shutdown Approved by -	Approval Granted to-	Alternate Supply Arrangements are available or not (Yes/No)	It has been Reported on Whatsapp Group	Demand in MW affected due to Shutdown.	Remark(Areas affected)	Remark(Areas affected)
1	INDORE CITY	Central	Rau	11 KV	Pigdamber IP & Rural	CHQ	06.12.2019	8:00	9:00	1:00	Due to 11 KV Line 1 No. pole Shifting Work Near Goal Chouraha Under 5 % Supervision BY Contractor PARIHAR	SE CITY	AE(Maint.)	No	YES	0.4		Rau mama ji ka Dhaba, Ram rahim Colony, Kisan Sheet, Jhumar Ghat, Shri Krishna Paradise Colony Maa padmawati Colony & Etc
2	Indore city	Central	Rajmohalla	11 KV	AIR	CHQ	06.12.2019	7:00	11:00	4:00	Due to 11 KV Line Shifting Work For road widening At Jairampur Colony to Gorakund Under Smart City Project	SE CITY	AE(Maint.)	No	YES	0.35		Vardhman Nagar,Arjun Pura, Dargha Square, Silawat Pura, balda Colony, Chatripura, & Etc
3	Indore city	Central	Pragati Nagar	11 KV	Sudama nagar	CHQ	06.12.2019	8:00	11:00	3:00	Due to Post monsoon Tree Cutting & Line maintenance Work	SE CITY	AE(Maint.)	No	YES	0.42		Surya Dev nagar, Satya Dev nagar Sudama nagar & Etc
4	Indore city	Central	Housing Board	11 KV	Feeder no 1	CHQ	06.12.2019	13:00	14:30	1:30	Due to I/C & O/G Isolator Repairing Work at Grid	SE CITY	AE(Maint.)	No	YES	0.62		Housing Board Colony Affected
5	INDORE CITY	Central	Housing Board	11 KV	Feeder no 2	CHQ	06.12.2019	14:30	15:30	1:00	Due to I/C Isolator Repairing Work at Grid	SE CITY	AE(Maint.)	No	YES	0.74		Housing Board Colony Affected
6	Indore city	North	S.Ch. No.-114	11 KV	Lal Banglow	CHQ	06.12.2019	8:30	11:30	3:00	Due to Tree cutting, Line maintenance work & 1 No. DTR & 2 No. Pole Erection work Near Govt. School Under IPDS	SE CITY	AE(Maint.)	No	YES	0.68		Lal Banglow
7	INDORE CITY	North	S.Ch. No.-114	11 KV	Army Quarter	CHQ	06.12.2019	11:30	12:00	0:30	Due to Tree cutting work near S/s	SE CITY	AE(Maint.)	No	YES	0.42		Army Quarter
8	INDORE CITY	North	S.Ch. No.-114	11 KV	Rajiv Vihar - I	CHQ	06.12.2019	11:30	12:00	0:30	Due to Tree cutting work near S/s	SE CITY	AE(Maint.)	No	YES	0.68		Rajiv Vihar - I
9	INDORE CITY	North	S.Ch. No.-114	11 KV	Rajiv Vihar - II	CHQ	06.12.2019	11:30	12:00	0:30	Due to Safety Purpose work on 11 kv Rajiv Vihar - I feeder	SE CITY	AE(Maint.)	No	YES	0.47		Rajiv Vihar - II
10	INDORE CITY	North	S.Ch. No.-136-II	11 KV	Feeder No. 4	CHQ	06.12.2019	6:30	7:00	0:30	Due to M.E. R-Phase Clamp red hot work	SE CITY	AE(Maint.)	No	YES	0.28		Feeder No. 4
11	INDORE CITY	North	Modern	11 KV	11 kv Main No. - 3	CHQ	06.12.2019	6:30	7:00	0:30	Due to 11 kv C.T. red hot work	SE CITY	AE(Maint.)	No	YES	0.6		Modern
12	INDORE CITY	South	Pagnis paga	11 kv	Motitabela	CHQ	06.12.2019	7:00	10:00	3:00	Tree cuting & Line Maintanance Work	SE CITY	AE(Maint.)	Yes	YES	1.89		motitabela ,manikbagh road, shishuvihar school and other area
13	INDORE CITY	South	univarcity	11 kv	khandwa naka	CHQ	06.12.2019	7:00	7:30	0:30	Y'phase CT clamp & O/G Isolator clamp red hot work at yard	SE CITY	AE(Maint.)	No	YES	0.65		IT Park chouraha, ring road and Other area
14	INDORE CITY	South	univarcity	11 kv	Main No. 2	CHQ	06.12.2019	7:30	8:00	0:30	"Y"phase AB switch clamp red hot work at yard	SE CITY	AE(Maint.)	No	YES	1.03		all feeder
15	INDORE CITY	South	Indira Complex	33 kv	indracomplex no.2 I/C	CHQ	06.12.2019	8:00	8:30	0:30	feeder "B"phase bus side isolator red hot work	SE CITY	AE(Maint.)	No	YES	nil		nil
16	INDORE CITY	South	New cloth market	11 kv	Feeder no. 2	CHQ	06.12.2019	12:30	13:00	0:30	VCB on/off checked By STM	SE CITY	AE(Maint.)	No	YES	0.71		11 kv Feeder No. 1
17	INDORE CITY	South	Chhawani	11 kv	Dawa Bazar	CHQ	06.12.2019	13:30	14:00	0:30	VCB on/off checked By STM	SE CITY	AE(Maint.)	No	YES	1.5		11 kv Dawa Bazar feeder
18	INDORE CITY	South	Indira Complex	33 kv	5 mva no 2	CHQ	06.12.2019	14:30	15:00	0:30	L V Side R Phase red hot work by STM	SE CITY	AE(Maint.)	No	YES	1.74		11 kv T S No 1& T.S. No. 2
19	INDORE CITY	South	Indira Complex	11 kv	Main No. 2	CHQ	06.12.2019	15:00	15:30	0:30	VCB on/off checked By STM	SE CITY	AE(Maint.)	No	YES	1.74		11 kv T S No 1& T.S. No. 2
20	INDORE CITY	South	Indira Complex	33 kv	OPH O/G	CHQ	06.12.2019	15:30	16:00	0:30	VCB on/off checked By STM	SE CITY	AE(Maint.)	Yes	YES	Nil		Nil
21	INDORE CITY	South	Mayur nagar	33 kv	5 MVA No. 1	CHQ	06.12.2019	16:30	17:00	0:30	HV & L V Side red hot work by STM	SE CITY	AE(Maint.)	No	YES	2.68		11 kv Ram Nagar , Firdosh Nagar , Pink Cty feeders
22	INDORE CITY	WEST	SANGAM NAGAR	33 kv	5 MVA no 1	CHQ	06.12.2019	9:00	10:00	1:00	For PTR Maintenance work by STM	SE CITY	AE(Maint.)	Yes	Yes	-		Supply Change Over
23	INDORE CITY	WEST	SANGAM NAGAR	33 kv	8 MVA no 2	CHQ	06.12.2019	10:00	11:00	1:00	For PTR Maintenance work by STM	SE CITY	AE(Maint.)	Yes	Yes	-		Supply Change Over
24	INDORE CITY	WEST	SANGAM NAGAR	33 kv	5 MVA no 3	CHQ	06.12.2019	12:00	13:00	1:00	For PTR Maintenance work by STM	SE CITY	AE(Maint.)	Yes	Yes	-		Supply Change Over
25	INDORE CITY	WEST	SANGAM NAGAR	33 kv	5 MVA no 4	CHQ	06.12.2019	13:00	14:00	1:00	For PTR Maintenance work by STM	SE CITY	AE(Maint.)	Yes	Yes	-		Supply Change Over
26	INDORE CITY	WEST	SANGAM NAGAR	33 kv	33 kv Nagin Nagar I/C	CHQ	06.12.2019	14:00	14:30	0:30	For B-Phase C.T. Replacement work by STM	SE CITY	AE(Maint.)	Yes	Yes	-		Supply Change Over
27	INDORE CITY	WEST	SANGAM NAGAR	33 kv	33 kv Airport Zonal I/C	CHQ	06.12.2019	14:30	15:00	0:30	For Y-Phase C.T. Replacement work by STM	SE CITY	AE(Maint.)	Yes	Yes	-		Supply Change Over