

M.P.P.K.V.V. C. LTD. INDORE CIRCLE																		
S.N o	Name of Circle	NAME OF DIVISION	Name of EHV S/s or 33/11 KV S/s	Line KV Capacity (33 or 11)	Name of 33 KV / 11 KV feeder	Planned shutdown		DATE-09.07.2019			Reason for Planned Shutdown (Maintenance/Erection work/ FSP / Safety purpose etc.)	Shutdown Approved by -	Approval Granted to-	It has been Reported on Whatsapp Group	Alternate Supply Arrangements are available or not (Yes/No)	Demand in MW affected due to Shutdown.	Remark(Areas affected)	Remark(Areas affected)
						Group (for 33KV) / Category (for 11 KV)	Date of Planned Shutdown	Duration of From	to	Total Duration								
1	INDORE CITY	WEST	GANDHI NAGAR	11 kv	BUDHANIYA	CHQ	09.07.2019	06:00:00	10:00:00	04:00:00	4 no. span Conductor stringing work under IPDS	SE CITY	AE(Maint.)	Yes	NO	0.85	Paper Declared	NAND BAAG, CHOTA BANGARDA, RAKHI NAGAR, HILINK RESIDENSI AND RELATED KSHETRA.
2	INDORE CITY	WEST	SECTOR-A	11 kv	SUNDAR NAGAR	CHQ	09.07.2019	06:00:00	10:00:00	04:00:00	1NO.DTR CHARGING & 1 NO. NEW DTR INSTALATION WORK NEAR JAGANATH NAGAR UNDER IPDS	SE CITY	AE(Maint.)	Yes	NO	0.6	Paper Declared	SUNDAR NAGAR, JAGANNATH NAGAR, NEW JAGANNATH NAGAR AND RELATED KSHETRA.
3	INDORE CITY	South Division	Navlakha	11 kv	Navlakha no.2	CHQ	09.07.2019	07:30:00	09:00:00	01:30:00	Tree Cutting & line Maintenance Work	SE CITY	AE(Maint.)	Yes	No	1.38	Paper Declared	11 kv Navlakha no.2 feeder & releted Aera
4	INDORE CITY	South Division	Khatiwala tank	11 kv	Saifee Nagar	CHQ	09.07.2019	06:30:00	08:30:00	02:00:00	Tree Cutting & line Maintenance & ME Clamp red hot work	SE CITY	AE(Maint.)	Yes	No	1.64	Paper Declared	Saife nagar garden, opp. Saif nagar,vinar appt
5	INDORE CITY	South Division	220 kv south zone	33 kv	Palda Industrial	VIII	09.07.2019	06:30:00	07:00:00	00:30:00	33 kv ME Y-phase clamp & B-phase O/G Isolator clamp red hot work	SE CITY	AE(Maint.)	Yes	Yes	Nil		Nil
6	INDORE CITY	South Division	Daily College	11 kv	Residency	CHQ	09.07.2019	06:00:00	06:30:00	00:30:00	11 kv B-phase CT Bushing Red hot work	SE CITY	AE(Maint.)	Yes	No	0.48		Residency water tank, pwd cothy st, colactor niwas, jim khana,
7	INDORE CITY	North	33/11 kv ELECTRONIC COM	11 kv	11 KV CLREK COLONY	CHQ	09.07.2019	06:00:00	10:00:00	04:00:00	line maintenance & tree cutting	SE CITY	AE(Maint.)	Yes	no	0.65	Paper Declared	Cleark colony, Gohar nagar, Lalgali, Choukse Dharmashala, Damru Ustad chouraha
8	INDORE CITY	North	132 KV Electronic com	33 kv	33 kv nagar Nigam	VIII	09.07.2019	13:00:00	14:30:00	01:30:00	for ME Replacement work of 33 kv HT consumer nagar nigam	SE CITY	AE(Maint.)	Yes	yes	NIL	NIL	NIL
9	INDORE CITY	North	33/11 kv Scheme no.136 1st	11 kv	11 kv main no. 2	CHQ	09.07.2019	06:00:00	06:15:00	00:15:00	for isolator red hot work main no. 2	SE CITY	AE(Maint.)	Yes	NO	0.65		11 kv Feeder no 1 & 2 & 3
10	INDORE CITY	North	33/11 kv Scheme no.136 1st	11 kv	11 kv Feeder no 2	CHQ	09.07.2019	06:15:00	06:30:00	00:15:00	FOR RED HOT WORK	SE CITY	AE(Maint.)	Yes	NO	0.8		Area Affected Releted to This Feeder
11	INDORE CITY	North	33/11 kv sector f	11 kv	11 kv main no. 2	CHQ	09.07.2019	06:15:00	06:30:00	00:15:00	FOR RED HOT WORK	SE CITY	AE(Maint.)	Yes	NO	0.95		11KV SUPRIMROLL, ZEST PHARMA
12	INDORE CITY	Central	Pragati nagar	11 kv	Parmanu nagar	CHQ	09.07.2019	07:00:00	10:00:00	03:00:00	3NO. DTR AUGMENTATION WORK NEAR CAT SQUIRE UNDER IPDS	SE CITY	AE(Maint.)	Yes	NO	1	Paper Declared	Area Affected Releted to This Feeder
13	INDORE CITY	Central	Rau	11 kv	Pigdamber IP & Rural	CHQ	09.07.2019	07:00:00	10:00:00	03:00:00	Due to IPDS pole Erection Work Near rau squire	SE CITY	AE(Maint.)	Yes	NO	0.85	Paper Declared	Area Affected Releted to This Feeder
14	INDORE CITY	Central	Gumasta nagar	11 kv	Dravin nagar	CHQ	09.07.2019	07:00:00	10:00:00	03:00:00	ONE NO. DTR INSTALLATION WORK NEAR DRAVID NAGAR UNDER IPDS	SE CITY	AE(Maint.)	Yes	NO	0.9	Paper Declared	Area Affected Releted to This Feeder
15	INDORE CITY	Central	Rau	11 kv	Main no-1 & Rau-1	CHQ	09.07.2019	11:00:00	11:30:00	00:30:00	Due to 2 no CT Replacement Work by STM	SE CITY	AE(Maint.)	Yes	NO	1		Area Affected Releted to This Feeder
16	INDORE CITY	EAST	SC.NO.140 TANKI WALA	11KV	SAMPAT FARM	CHQ	09.07.2019	06:30:00	10:00:00	03:30:00	LINE MAINTENANCE & TREE CUTTING WORK.	SE CITY	AE(Maint.)	Yes	NO	0.65	Paper Declared	JAIN COLLAGE, DHAGA FACTORY, BHURI TEKARI AND BLU WATER PARK ETC.
17	INDORE CITY	EAST	SC.NO.134	11KV	R.K. NURCERY	CHQ	09.07.2019	06:30:00	10:00:00	03:30:00	LINE MAINTENANCE & TREE CUTTING WORK.	SE CITY	AE(Maint.)	Yes	NO	0.75	Paper Declared	RK NURSERY, SHULABH BY PASS AND MRUDANG GANDEN , KASLIWAL HONDA ETC.
18	INDORE CITY	EAST	PRESS COMPLEX	11KV	SHREE NAGAR	CHQ	09.07.2019	06:30:00	10:00:00	03:30:00	LINE MAINTENANCE & TREE CUTTING WORK.	SE CITY	AE(Maint.)	Yes	NO	0.8	Paper Declared	CHAMELI PARK , ARCHANA MEDICAL ,TILAK NAGAR AND VINOBA NAGAR ETC.
19	INDORE CITY	CENTRAL	RAJMOHALLA	11 KV	MAHLARGANJ	CHQ	09.07.2019	08:00:00	08:30:00	00:30:00	11 KV MAHLARGANJ FEEDER 3 NO CT PI WORK BY STM	SE CITY	AE(Maint.)	Yes	NO	0.85		Area Affected Releted to This Feeder
20	INDORE CITY	SOUTH	MAYUR NAGAR	11 KV	NEMAWAR ROAD	CHQ	09.07.2019	09:00:00	09:30:00	00:30:00	11 KV NEMAWAR ROAD FEEDER VCB WORK BY STM	SE CITY	AE(Maint.)	Yes	NO	0.95		Area Affected Releted to This Feeder
21	INDORE CITY	SOUTH	MAYUR NAGAR	11 KV	MAIN NO 1	CHQ	09.07.2019	09:30:00	10:00:00	00:30:00	VCB NOT ON OF IN SCADA + CRP	SE CITY	AE(Maint.)	Yes	NO	0.75		Area Affected Releted to This Feeder
22	INDORE CITY	SOUTH	MAYUR NAGAR	11 KV	MAYUR NAGAR	CHQ	09.07.2019	10:00:00	10:30:00	00:30:00	11 KV MAYUR NAGAR ROAD FEEDER VCB WORK BY STM	SE CITY	AE(Maint.)	Yes	NO	1		Area Affected Releted to This Feeder
23	INDORE CITY	SOUTH	MAYUR NAGAR	33 KV	33 KV DAILY COLLEGE 2 O/G	CHQ	09.07.2019	10:30:00	11:00:00	00:30:00	VCB NOT ON OF IN SCADA + CRP	SE CITY	AE(Maint.)	Yes	NO	0.65		Area Affected Releted to This Feeder
24	INDORE CITY	SOUTH	UNIVARECITY	11 KV	MAIN NO 3	CHQ	09.07.2019	12:00:00	12:30:00	00:30:00	VCB NOT ON OF IN SCADA + CRP	SE CITY	AE(Maint.)	Yes	NO	0.7		Area Affected Releted to This Feeder
25	INDORE CITY	SOUTH	UNIVARECITY	11 KV	KHATIWALA TANK	CHQ	09.07.2019	12:30:00	13:00:00	00:30:00	VCB NOT TRIP ON FAULTY	SE CITY	AE(Maint.)	Yes	NO	0.8		Area Affected Releted to This Feeder
26	INDORE CITY	SOUTH	UNIVARECITY	33 KV	33 KV NAVLKKHA 1 +11 KV INDRAPURI	CHQ	09.07.2019	13:00:00	13:30:00	00:30:00	33 KV NAVLKKHA 1 FEEDER VCB NOT TRIP IN SCADA AND 11 KV INDRAPURINANDALALPURA FEEDER VCB CLOSSING COIL CHANGE WORK BY STM	SE CITY	AE(Maint.)	Yes	NO	0.95		Area Affected Releted to This Feeder