Planned shutdown								DATE-06.10.2019 M.P.P.K.V.V. C.171					INDORE CIRCLE		_	
S.N. Name of NAME OF	Name of EW S/s	Line KV Capacity	Name of 33 KV / 11	Group (for 33KV) /	Date of Planned	Duratio	n of		Reason for Planned Shutdown (Maintenance/Erection work/ PSP / Safety purpose etc.)	Stations	Approval	Alternate Supply Arrangements	It has been Reported	Demand is MW affected	Remark(Are	Bressrk(Arran sfected)
1 INDORE North	33/11 kv Mordan	11 kv	11 kv Marimata	CHQ	06.10.2019	10:00 1	7:00	07:00	For Conductor Replacement Work By STC Team	SE CITY	AE (HTM)	No	Yes	8à.0		Ganeshdham colony, Sanwer main road, Orient wire, JP Papers
2 INDORE North	33/11 kv Mordan	11 kv	11 kv B-1	CHQ	06.10.2019	10:00 1	7:00	07:00	For Conductor Replacement Work By STC Team	SE CITY	AE (HTM)	No	Yes	0.45		Sector F Industrial Area
3 INDORE North	33/11 kv Sector E	11 kv	11KV Sagar	CHQ	06.10.2019	10:00 1	7:00	07:00	For Conductor Replacement Work By STC Team	SE CITY	AE (HTM)	No	Yes	0.25		Sagar Industry, Sector B & E
4 INDORE North	33/11 kv Sector E	11 kv	11 kv Sector E	CHQ	06.10.2019	10:00 1	7:00	07:00	For Conductor Replacement Work By STC Team	SE CITY	AE (HTM)	No	Yes	0.4		Sector E & Bhavani
5 INDORE North	33/11 kv Sector E	11 kv	11 kv Sector E-1	CHQ	06.10.2019	10:00 1	7:00	07:00	For Conductor Replacement Work By STC Team	SE CITY	AE (HTM)	No	Yes	0.45		Sector E & shivlkanth Nagur
6 INDORE North	33/11 kv Sector E	11 kv	11 kv Rural	CHQ	06.10.2019	10:00 1	7:00	07:00	For Conductor Replacement Work By STC Team	SE CITY	AE (HTM)	No	Yes	0.5		Dharampuri Area
7 INDORE North	33/11 kv Sector F	11 kv	11 kv Supreme Roll	CHQ	06.10.2019	10:00 1	7:00	07:00	For Conductor Replacement Work By STC Team	SE CITY	AE (HTM)	No	Yes	0.85		Sector F Industrial Area
8 INDORE North	220 North Zone	33KV	33KV Zonal 1ST	CHQ	06.10.2019	12:00 1	5:00	03:00	For Conductor Replacement Work By STC Team	SE CITY	AE (HTM)	No	Yes	1		14 HT Consumer Affected
9 INDORE North	33/11 kv Mordan	11 kv	11 kv Choutha Sansar	CHQ	06.10.2019	10:00 1	7:00	07:00	For Conductor Replacement Work By STC Team	SE CITY	AE (HTM)	No	Yes	0.65		Sector F Industrial Area
10 INDORE North	33/11 kv Sector F	11 kv	11 kv Zest Pharma	CHQ	06.10.2019	10:00 1	7:00	07:00	For Conductor Replacement Work By STC Team	SE CITY	AE (HTM)	No	Yes	0.95		Jesth Pharma, Sector Industria Area
11 INDORE North	220 North Zone	33KV	33KV Sector C	CHQ	06.10.2019	10:00 1	7:00	07:00	For Conductor Replacement Work By STC Team	SE CITY	AE (HTM)	Yes	Yes	Nil		45 HT Consumer Affected
12 INDORE CITY North	33/11 kv Mahakal	11 kv	11 kv Ujjain Road	CHQ	06.10.2019	14:00 1	7:00	03:00	For Conductor Replacement Work By STC Team	SE CITY	AE (HTM)	No	Yes	0.75		Ujjain Road Area
13 INDORE North	33/11 kv Mahakal	11 kv	11 kv Bhawani Nagar	CHQ	06.10.2019	14:00 1	7:00	03:00	For Conductor Replacement Work By STC Team	SE CITY	AE (HTM)	No	Yes	0.65		Bhawani Nagar Area
14 INDORE North	220 North Zone	33KV	33KV INDUSTRIAL- B	CHQ	06.10.2019	10:00 1	7:00	07:00	For Conductor Replacement Work By STC Team	SE CITY	AE (HTM)	Yes	Yes	Nil		15 HT Consumer Affected
15 INDORE North	33/11 kv Sector E	11 kv	11KV Sector B	CHQ	06.10.2019	10:00 1	7:00	07:00	For Conductor Replacement Work By STC Team	SE CITY	AE (HTM)	No	Yes			Sector B Industrial Area, Jai Prakash Industry
16 INDORE South CITY Division	Sadhu Vaswani	11 kv	Main no.1	CHQ	06.10.2019	06:00 0	6:30	00:30	R-phase CT/Isolator clamp red hot work at Yard	SE CITY	AE (HTM)	No	Yes	0.76		Sadhuwaswani J.oha mandi , Navlakha complex
17 INDORE South CITY Division	Palda Industrial	11 kv	Vinayak	CHQ	06.10.2019	08:00 1	2:00	04:00	5 no. Pole Erection &3 Span conductor Stringing work by Kshema power Under IPDS at Udhyog Nagar	SE CITY	AE (HTM)	No	Yes	0.48	Pepar Declared	Vinayak , Samta nagar
18 INDORE South CITY Division	Palda Industrial	33 kv	Palda Industrial O/G	CHQ	06.10.2019	08:00 1	2:00	04:00	5 no. Pole Erection work by Kshema power Under IPDS at Udhvoe Nazar	SE CITY	AE (HTM)	Yes	Yes	Nil	Pepar Declared	M
19 INDORE South CITY Division	Palda Industrial	11 kv	10 MVA no. 2	CHQ	06.10.2019	13:00 1	3:30	00:30	Oil Leackage work by STM	SE CITY	AE (HTM)	No	Yes	0.83		Khandel wai , Vinayak , Kalindi feeder
20 INDORE South CITY Division	Palda industrial	11 kv	Khandelwal feeder	CHQ	06.10.2019	13:30 1	4:00	00:30	VCB Trip Test Work by STM	SE CITY	AE (HTM)	No	Yes	0.58		11 kv Khandelwal foeder
21 INDORE South CITY Division	University	11 kv	Ekta Nagar	CHQ	06.10.2019	14:30 1	5:00	00:30	11 kv feeder VCB Part replacement work by STM	SE CITY	AE (HTM)	No	Yes	0.67		Soniya gandhi nagar, rahul gandhi nagar, ganesh nagar-1, joet nagar, joet nagar-2, kamdhenu park colony-1
22 INDORE South CITY Division	Univarcity	11KV	Anand nagar	CHQ	06.10.2019	15:30 1	6:00	00:30	VCB Trip Test Work by STM	SE CITY	AE (HTM)	No	Yes	0.72		Asharam chouraha,dovi ahiliya hospital.45/b durga niwas,takkar niwas,takshi bhavan
23 INDORE South CITY Division	Univercity	11 kv	Indrapuri	CHQ	06.10.2019	16:00 1	6:30	00:30	VCB Trip Test Work by STM	SE CITY	AE (HTM)	No	Yes	0.65		Water tank, monica plaza, 329 lindrapuri colony, 299 lindrapuri colony,
24 City circle South Division	IG Grid	11 kv	Shivaji vatika	CHQ	06.10.2019	08:00	9:00	01:00	Line Erection work by Kshema power IPDS work at Shivaji vatika ke pass	SE CITY	AE (HTM)	No	Yes	0.84		Shivaji Vatika Stadiam Area,
25 City circle South Division	Indra complex	11 kv	Sanwad nagar	CHQ	06.10.2019	13:00 1	4:00	01:00	DTR Charging work by STC at Sanwad nagar Areas	SE CITY	AE (HTM)	No	Yes	0.42		Residancy radio colony, shaweli colony, ida quarter, darga ke piche,
26 INDORE Central	Revenue Nagar	11 KV	Madhuban	CHQ	06.10.2019	08:00 1	1:00	03:00	Due to Tree Cutting & Line Maintenance Work Under nost Monsoon	SE CITY	AE (HTM)	No	Yes	0.75		Ingation Area Affected
27 INDORE Central	Ahirkhedi	11 KV	Footi kothi	CHQ	06.10.2019	07:00 0	9:30	02:30	Due to 11 KV Pole Shirting Work Under 5 % Super Vision BY CONTACTOR JASPAL SINGH Near Sudama Nagar	SE CITY	AE (HTM)	No	Yes	0.65		Footi kothi Square, Vikram Square, Dwarkapuri, Near Sudama nagar & Etc
28 INDORE Central	Pragati Nagar	11 KV	Main no 2	CHQ	06.10.2019	17:00 1	7:30	00:30	Due to CT replacement Work by STM	SE CITY	AE (HTM)	No	Yes	0.76		11 KV Sudama nagar, parmanu nagar, Buddha nagar Affected
29 INDORE Central	Pragati Nagar	11 KV	Siddhipuram	CHQ	06.10.2019	17:00 1	7:30	00:30	Due to VCB Trip Test Work by STM	SE CITY	AE (HTM)	No	Yes	0.48		Vaishali nagar, Ahila nagar, grater vaishali nagar,Siddhipuuram & Etc
30 INDORE Central	Gumasta Nagar	11 KV	Main no 3		06.10.2019	13:00 1	3:30	00:30	Due to Main CT Replacement Work by STM	SE CITY	AE (HTM)	No	Yes	0.45		11 KV Sirpur & Dwarkapur Affected
31 INDORE Central	Gumasta Nagar	11 KV	Sirpur		06.10.2019	13:00 1	4:00	01:00	Due to Breaker testing Work by STM	SE CITY	AE (HTM)	No	Yes	0.5		Sirpur, Neorani nagar, Ambar nagar, Green park Colony & Etc
32 INDORE WEST	HEMILTON ROAD	11KV	HEMILTON ROAD	CHQ	06.10.2019	06:00 0	6:20	00:20	FOR O/G ISOLATOR & I/C SIDE Y- PHASE CLAMP RED HOT WORK.	SE CITY	AE (HTM)	NO NO	Yes	0.5		Akhada juna Tukogani, Bhika Bhai Patel, Telar Peor Gali, Indore Parisar Bank, Ganesh Kep, Shri Ram Market, Das Medical, Anna Pan Wala, Indore Hospital, Navin Photo Copy, Fesion Complex, Hamman Tempal. Rai Complex, ImamBada. Nihalbura. Gonal Tempal. Khaiuri Basar Main Road. Bhandari School. Morsali Gali. Madan-Chhagan Bada Saraf.
33 INDORE WEST	132 CHAMBLE	33KV	33KV L.T. INDUSTRIAL	CHQ	06.10.2019	08:00	8:30	00:30	FOR RED HOT POINT ATTEND WORK IN 132 CHAMBLE GRID.	SE CITY	AE (HTM)	YES	Yes	Nil		NIL
34 INDORE WEST	AIRPORT	11KV	HI LINK	CHQ	06.10.2019	14:30 1	5:30	01:00	FOR 200KVA FAILED DTR REPLACEMENT WORK AT GOKUL DHAM.	SE CITY	AE (HTM)	NO NO	Yes	0.35		Petrol Dipo Relaince, Indian Oil, Babu Murai Colony, Shakti Nagar, Khandelwal Pepar, Highlisk City, Utsav Angan, Leads Devlopers, Bahashri Chota Bangadda Pal Wala, Krishna Vihar, Medern City. Sebhay Estates. R.N. City. Hotel Amrit Green.
35 INDORE WEST	SECTOR-A	11KV	5 MVA PTR NO- 01	CHQ	06.10.2019	08:30 0	9:30	01:00	FOR CT REPLACEMENT & MAINTENANCE WORK BY STM.	SE CITY	AE (HTM)	NO NO	Yes	1		11KV SUNDAR NAGAR, RURAL)
36 CITY WEST	SECTOR-A	33KV	33 KV INDUSTRIAL-A	CHQ	06.10.2019	09:30 1	0:30	01:00	FOR 3 NO. CT REPLACEMENT WORK BY STM.	SE CITY	AE (HTM)	NO NO	Yes	1.2		16 HT CONSUMER AFFECTED
37 INDORE WEST	SECTOR-A	11KV	5 MVA PTR NO- 02	CHQ	06.10.2019	10:30 1	1:30	01:00	FOR PTR MAINTENANCE WORK BY STM.	SE CITY	AE (HTM)	NO NO	Yes	0.95		11 KV GOVIND NAGAR KHRCHA)
38 INDORE WEST	SECTOR-A	11KV	5 MVA PTR NO- 03	CHQ	06.10.2019	12:00 1	2:30	00:30	FOR VCB TRIP TEST WORK BY STM.	SE CITY	AE (HTM)	NO NO	Yes	0.85		11KV SECTOR-A, & AWANTIKA NAGAR)
39 INDORE EAST	SATYA SAI	11KV	OLD PRESS COMPLEX	CHQ	06.10.2019	07:00 0	8:00	01:00	FOR ISOLATOR REPAIRING WORK	SE CITY	AE (HTM)	NO NO	Yes	0.45		DEWAS NAKA, DOORSANCHAR, ORBITE MALL AND PU-4 ETC.
40 INDORE EAST	SCN0.134	11KV	R.K. NURCERY	CHQ	06.10.2019	08:30 0	9:30	01:00	FOR ISOLATOR REPAIRING WORK	SE CITY	AE (HTM)	NO NO	Yes	0.5		RK NURSERY, SHULABH BY PASS AND MRUDANG GANDEN , KASLIWAL HONDA ETC.