

M.P.P.K.V.V. C. LTD. INDORE CIRCLE																			
S.N o	Name of Circle	NAME OF DIVISION	Name of EHV S/s or 33/11 KV S/s	Line KV Capacity (33 or 11)	Name of 33 KV / 11 KV feeder	Planned shutdown			DATE- 15.10.2019			Reason for Planned Shutdown (Maintenance/Erection work/ PSP / Safety purpose etc.)	Shutdown Approved by -	Approval Granted to-	Alternate Supply Arrangements are available or not (Yes/No)	It has been Reported on Whatsapp Group	Demand in MW affected due to Shutdown.	Remark(Areas as affected)	Remark(Areas affected)
						Group (for 33KV) / Category (for 11 KV)	Date of Planned Shutdown	Duration of From to	Total Duration										
1	INDORE CITY	WEST	AIRPORT	11KV	11 MAIN NO.-01	CHQ	15.10.2019	07:00	07:15	00:15	FOR 11KV VIDHYADHAM I/C ISOLATOR R- PHASE RED HOT ATTEND WORK.	SE CITY	AE(Maint.)	NO	Yes	0.45		11KV VIDHYADHAM)	
2	INDORE CITY	WEST	SANGAM NAGAR	11KV	11 MAIN NO.-02	CHQ	15.10.2019	07:25	07:50	00:25	B -PHASE POLE RED HOT & B PHASE CT RED HOT ATTEND WORK.	SE CITY	AE(Maint.)	NO	Yes	0.5		11KV AERODRUM-01 & 02, 11KV SUBHASH MARG -01 FEEDER RELATED AREA.	
3	INDORE CITY	Central	Ahirkhedi	11 KV	Parivahan nagar	CHQ	15.10.2019	17:00	17:30	00:30	Due to CT Replacement Work by STM	SE CITY	AE(Maint.)	NO	Yes	0.45		Sai baba Nagar, Parivahan nagar, Aanand School, Shati Nath Puri	
4	INDORE CITY	South Division	Sabji mandi	11 kv	Main no. 4	CHQ	15.10.2019	06:00	06:30	00:30	I/C Isolator clamp & Bus side R,Y-phase Isolator clamp red hot work at vard	SE CITY	AE(Maint.)	No	Yes	1.2		Bijalpur , Gayatri nagar , Pawanputra nagar	
5	INDORE CITY	WEST	AIRPORT	11KV	B.S.F.	CHQ	15.10.2019	06:00	06:30	00:30	FOR VCB TRIP TEST WORK BY STM	SE CITY	AE(Maint.)	NO	Yes	0.5		BSF Complex, Airport Colony, Telephone Ex., In Front of Vidhyadham, BSF Water Tank, Santosh Bysical, Kalani Nagar, Khandelwal Senw, Fharsiwala, Bholenath Colony, Dargaha Wala, Rajnagar Munna Elec.	
6	INDORE CITY	EAST	MANORAMA GANJ GRID	33KV	M.G NO.1	CHQ	15.10.2019	12:30	13:00	00:30	FOR VCB TRIP TEST WORK BY STM	SE CITY	AE(Maint.)	NO	Yes	0.5		SUPPLY NOT AFFECTED.	
7	INDORE CITY	WEST	AIRPORT	11KV	AIRPORT	CHQ	15.10.2019	06:30	07:00	00:30	FOR O/G ISOLATOR R,Y- PHASE NUT BOLT RED HOT & Y PHASE CT RED HOT ATTEND WORK.	SE CITY	AE(Maint.)	NO	Yes	0.25		Petrol Dipo Relaince, Indian Oil, Kalka Mata Tempal, Babu Murai Colony, Shakti Nagar, Khandelwal Pepar, Highlink City, Leads Developers, Babashri Chota Bangadda Pal Wala, ManuShri, Laxmi Nagar Colony, Ashok Nagar, Smarti Nagar, Mahavir Tempal, Vyanktesh Vihar.	
8	INDORE CITY	WEST	GANDHI NAGAR	33KV	33KV GAMBHIR I/C MAIN	CHQ	15.10.2019	15:00	15:30	00:30	FOR VCB TRIP TEST WORK BY STM	SE CITY	AE(Maint.)	YES	Yes	Nil		NIL	
9	INDORE CITY	WEST	NAGIN NAGAR	11KV	RAJ NAGAR	CHQ	15.10.2019	16:00	16:30	00:30	FOR VCB TRIP TEST WORK BY STM	SE CITY	AE(Maint.)	NO	Yes	0.45		Ramnagar, Bajran Nagar, Vijayvargiy Nagar, Om Eat Bhatta, Sundar Nagar, Jagdish Nagar, Prince Nagar, Roshan Nagar, Pushpa Nagar, Piru Pahalwan Rishi Nagar, Kushwah Shree Nagar.	
10	INDORE CITY	North	132 KV NORTH ZONE	33 KV	33 KV MANGLIYA	CHQ	15.10.2019	12:00	12:30	00:30	FOR JUMPER DISCONNECTED WORK (FOUR POLE MAINTENANCE WORK OF brilliant convention centre) DOUBLE supply arrangement	SE CITY	AE(Maint.)	NO	Yes	0.65		KABIT KHEDI & 114 & ht consumer	
11	INDORE CITY	North	132 KV NORTH ZONE	33 KV	33 KV MANGLIYA	CHQ	15.10.2019	14:00	14:30	00:30	After work jumper connected	SE CITY	AE(Maint.)	NO	Yes	0.65		KABIT KHEDI & 114 & ht consumer	
12	INDORE CITY	North	33/11 kv vijay nagar	33 KV	33 kv scheme no. 78 1st	CHQ	15.10.2019	12:00	12:30	00:30	FOR JUMPER DISCONNECTED WORK (FOUR POLE MAINTENANCE WORK OF brilliant convention centre) DOUBLE supply arrangement	SE CITY	AE(Maint.)	NO	Yes	0.5		KABIT KHEDI & 114 & ht consumer	
13	INDORE CITY	North	33/11 kv vijay nagar	33 KV	33 kv scheme no. 78 1st	CHQ	15.10.2019	14:00	14:30	00:30	after work jumper connected	SE CITY	AE(Maint.)	NO	Yes	0.5		KABIT KHEDI & 114 & ht consumer	