

M.P.P.K.V.V. C.LTD. INDORE CIRCLE																
Planned shutdown																
S.No	Name of Circle	NAME OF DIVISION	Name of EHV S/s or 33/11 KV S/s	Line KV Capacity (33 or 11)	Name of 33 KV / 11 KV feeder	Group (for 33KV) / Category (for 11 KV)	Date of Planned Shutdown	Duration of From	To	Total Duration	Reason for Planned Shutdown (Maintenance/Erection work/ FSP / Safety purpose etc.)	Shutdown Approved by -	Approval Granted to-	Alternate Supply Arrangements are available or not (Yes/No)	Demand in MW affected due to Shutdown.	Areas affected
1	INDORE CITY	East	S.ch. No. 140 Talab wala	11 kv	Ganesh Dham	CHQ	04.06.2019	12:30:00	12:50:00	00:20:00	FOR VCB REPAIR WORK	SECITY	AE(Maint.)	No	1.32	RELATED AREA AFFECTED
2	INDORE CITY	North	New Loha mandi	11 kv	Lastudiya	CHQ	04.06.2019	14:30:00	14:50:00	00:20:00	VCB not trip on Fault	SECITY	AE(Maint.)	No	1.48	RELATED AREA AFFECTED
3	INDORE CITY	Central	Gumasta Nagar	11 kv	Dwarikapuri	CHQ	04.06.2019	15:50:00	16:20:00	00:30:00	For VCB 's C.T. Jumper work	SECITY	AE(Maint.)	No	0.6	RELATED AREA AFFECTED
4	INDORE CITY	Central	Gumasta Nagar	11 kv	11 kv Main	CHQ	04.06.2019	16:30:00	16:50:00	00:20:00	For VCB repair work	SECITY	AE(Maint.)	No	0.5	RELATED AREA AFFECTED
5	INDORE CITY	Central	Prajoti Nagar	33 kv	33 kv I/C	-	04.06.2019	17:20:00	17:40:00	00:20:00	VCB not trip from Panel	SECITY	AE(Maint.)	No	1	RELATED AREA AFFECTED
6	INDORE CITY	South	Mayur Nagar	33 kv	33 kv I/C -II	-	04.06.2019	06:30:00	7:00:00	00:30:00	For VCB's C.T. replacement work	SECITY	AE(Maint.)	No	0.68	RELATED AREA AFFECTED
7	INDORE CITY	East	Khairana	33 kv	33 kv I/C -II	-	04.06.2019	08:00:00	8:30:00	00:30:00	For VCB's C.T. wiring work	SECITY	AE(Maint.)	No	0.98	RELATED AREA AFFECTED
8	INDORE CITY	East	Khairana	33 kv	33 kv I/C-I	-	04.06.2019	8:30:00	9:00:00	00:30:00	For VCB's C.T. Maingring work	SECITY	AE(Maint.)	No	0.78	RELATED AREA AFFECTED
9	INDORE CITY	North	Mahalaxmi	33 kv	PTB No. 3	-	04.06.2019	9:30:00	9:50:00	00:20:00	For VCB's Spring Charging problem	SECITY	AE(Maint.)	No	0.65	RELATED AREA AFFECTED
10	INDORE CITY	North	Mahalaxmi	11 kv	Tulsi Nagar	CHQ	04.06.2019	10:20:00	10:50:00	00:30:00	For VCB's C.T. replacement work	SECITY	AE(Maint.)	No	0.45	RELATED AREA AFFECTED
11	INDORE CITY	North	Sector -F	11 kv	MR-10	CHQ	04.06.2019	6:00:00	9:00:00	03:00:00	For STC work	SECITY	AE(Maint.)	No	0.4	Soniya gandhi nagar, rahul gandhi nagar, ganesh nagar-1, jeet nagar, jeet nagar-2, kamdhenu park colony-1
12	City circle	South Division	Khatiwala Tank	11 kv	Bairathi Colony	CHQ	04.06.2019	07:00:00	08:00:00	01:00:00	For STC work	SECITY	AE(Maint.)	No	1	Simran palace, 413,khaiwala tank,3/1 jeevan nagar,manik bag.
13	Indore city	Central	Rau	11KV	Pigdamber IP & rural	INDUSTRIAL	04.06.2019	07:00	10:00	03:00:00	Due to IPDS Pole Erection Work	SECITY	AE(Maint.)	NO	0.65	Rau, Mama Ka Dhaba, Ram Rahim Colony, Krishan Sheet Grah, Jhumar Ghat, Shri Krishna Paradise Phase 1 & 2, Maa Padmanawati Colony & ETC.