| | M.P.P.K.V.V. C. LTD. INDORE CIRCLE | | | | | | | | | | | | | | | | |
|-----|--|-------------------|--------------------------------|------------|--------------------------------------|----------------------|---|----------|----------|----------|---|-------------------------------|-----------------------|-------------------------------|------------------|----------------|--|
| S N | Name of NAME OF Name of EHV S/s or Line KV Capacity Name of 33 KV / Group (for 33KV) / Date of Planned Duration of | | | | | | DATE-06.07.2019 of Planned Total Reason for Planned Shutdown (Maintenance/Erection Shutdown Approval Alternate Suppl | | | | | Alternate Supply Arrangements | Demand in MW affected | Remark(Areas | | | |
| 0 | Circle | DIVISION | 33/11 KV S/s | (33 or 11) | 11 KV feeder | Category (for 11 KV) | Shutdown | From | to | Duration | work/ FSP / Safety purpose etc.) | Approved by - | Granted to- | are available or not (Yes/No) | due to Shutdown. | affected) | Remark(Areas affected) |
| 1 | INDORE CITY | Central | Annapurna | 11 kv | Paraspar nagar | CHQ | 06.07.2019 | 07:00:00 | 10:00:00 | 03:00:00 | Due to IPDS Pole Erection Work P/D Shutdown | SE CITY | AE(Maint.) | NO | 1 | Paper Declared | Paraspar nagar |
| 2 | INDORE CITY | Central | Pragati nagar | 11 kv | Parmanu nagar | CHQ | 06.07.2019 | 07:00:00 | 10:00:00 | 03:00:00 | Due to IPDS Pole Erection Work P/D Shutdown | SE CITY | AE(Maint.) | NO | 0.85 | Paper Declared | Parmanu nagar |
| 3 | INDORE CITY | Central | Rau | 11 kv | Pigdamber Rural | CHQ | 06.07.2019 | 07:00:00 | 10:00:00 | 03:00:00 | Due to IPDS Pole Erection Work P/D Shutdown | SE CITY | AE(Maint.) | NO | 0.76 | Paper Declared | Pigdamber Rural |
| 4 | INDORE CITY | Central | Jincy | 11KV | Govt.Press | CHQ | 06.07.2019 | 07:00:00 | 10:00:00 | 03:00:00 | Due to Tree Cutting & Line Maintenance Order By EE.Central City Dn. | SE CITY | AE(Maint.) | NO | 1 | | Govt.Press |
| 5 | Indore city | Central | RajMohalla | 33 kv | 33 kv Gumasta nagar O/G | CHQ | 06.07.2019 | 06:30 | 07:00 | 00:30 | Due to VCB's Closing Coil Repaire work | SE CITY | AE(Maint.) | NO | 0.95 | | 11 KV Rau-1 ,Pigdamber Rural & IP feeder Affected |
| 6 | Indore city | Central | Gumasta nagar | 11 kv | 11 kv Main No1 | - | 06.07.2019 | 08:30 | 09:00 | 00:30 | Due to VCB's Closing Coil Repaire work | SE CITY | AE(Maint.) | NO | 0.75 | | Sch no 71, HT Verma Unioun Hospital,Hindusthan Petrolium, Bharat Petrolium, GNt market, Govt, Hospital |
| 7 | Indore city | Central | Pragati Nagar | 33 kv | 33 kv Annapurna- I I/C | - | 06.07.2019 | 09:30 | 10:00 | 00:30 | Due to VCB not Tripped from Panal | SE CITY | AE(Maint.) | NO | 0.65 | | Sch no 71, HT Verma Unioun Hospital,Hindusthan Petrolium, Bharat Petrolium, GNt market, Govt, Hospital |
| 8 | Indore city | Central | Pragati Nagar | 33 kv | 33 kv Annapurna- II I/C | - | 06.07.2019 | 10:00 | 10:30 | 00:30 | Due toVCB's A.C. Supply cable Repaire Work | SE CITY | AE(Maint.) | NO | 0.6 | | Devendra nagar, Umesh nagar, Silver AUX, Parshnath nagar, parmanu nagar, Alankar Palace, & ETC |
| 9 | INDORE CITY | EAST | TAAJ NAGAR | 11KV | KALIKA MATA & RAJIV GRAM BARLA | СНQ | 06.07.2019 | 06:30:00 | 10:00:00 | 03:30:00 | LINE MAINTENANCE & TREE CUTTING WORK. | SE CITY | AE(Maint.) | NO | 0.8 | Paper Declared | KHAN KAMPAUND, DARGAH, JUM-JUM CHOURAHA AND GARIB NAVAZ COLONY,HAJI COLONY, BABA FARID NAGAR, BANGALI COLONY AND PULICE LINE ETC. |
| 10 | INDORE CITY | EAST | SATYA SAI | 11KV | BHAGAT SINGH & BCM HEIGHT | CHQ | 06.07.2019 | 06:30:00 | 10:00:00 | 03:30:00 | LINE MAINTENANCE & TREE CUTTING WORK. | SE CITY | AE(Maint.) | NO | 0.65 | Paper Declared | METRO TOWER, SATYA SAI SCHOOL, GUJARATI SCHOOL, TOTAL HELPS ,SHEETAL NAGAR AND RAHIL INTERPRISES ETC. |
| 11 | INDORE CITY | North | Vijay nagar | 11 kv | 11 kv sukhliya | CHQ | 06.07.2019 | 06:00:00 | 10:00:00 | 04:00:00 | line maintenance & tree cutting | SE CITY | AE(Maint.) | NO | 0.94 | Paper Declared | Sukhliya, Bapat Chouraha, Nursingh collage, Hotel Ambrocia, Sch.No.54 Vijay Nagar, Barod Hospital, |
| 12 | INDORE CITY | North | Vijay nagar | 11 kv | 11 kv Scheme no. 54 | CHQ | 06.07.2019 | 06:00:00 | 10:00:00 | 04:00:00 | line maintenance & tree cutting | SE CITY | AE(Maint.) | NO | 0.9 | Paper Declared | Vijay Nagar, Nyay Nagr puliya, Vishwanand Multi, Shalimar bunglow, Hira Nagar thana, Sundar Nagar, MR-10, Marthoma School, |
| 13 | INDORE CITY | North | 33/11 kv Scheme no. 136 2nd | 11 kv | 11 kv Feeder no 2 | CHQ | 06.07.2019 | 07:00:00 | 10:00:00 | 03:00:00 | for 5% supervision work (congrs neta) | SE CITY | AE(Maint.) | NO | 0.65 | | Areas affected |
| 14 | INDORE CITY | North | 33/11 kv Scheme no. 136 2nd | 33 kv | 33 kv I/c | CHQ | 06.07.2019 | 05:45:00 | 06:00:00 | 00:15:00 | for ME & isolator red hot work | SE CITY | AE(Maint.) | NO | 0.7 | | grid affected |
| 15 | INDORE CITY | North | 33/11 kv Scheme no. 136 2nd | 33 kv | 11 kv main no 2 | CHQ | 06.07.2019 | 06:00:00 | 06:20:00 | 00:20:00 | bus red hot work | SE CITY | AE(Maint.) | NO | 0.8 | | 11 kv Feeder no 4 &5 & 6 |
| 16 | INDORE CITY | North | 33/11 kv LIG | 33 kv | 33 kv MPSRTC | CHQ | 06.07.2019 | 09:00:00 | 09:15:00 | 00:15:00 | b-phase isolator red hot work | SE CITY | AE(Maint.) | NO | 1.2 | | 11 kv Industry house & old palasiya & uttam bhog |
| 17 | INDORE CITY | North | 33/11 kv sector E | 11 kv | 11 kv sector E-1 | CHQ | 06.07.2019 | 06:30:00 | 06:45:00 | 00:15:00 | for ct red hot work | SE CITY | AE(Maint.) | NO | 0.65 | | Areas affected |
| 18 | INDORE CITY | South Division | Univercity | 11 kv | Khandwa naka & Indrapuri | CHQ | 06.07.2019 | 06:30:00 | 09:30:00 | 03:00:00 | Tree Cutting &line Maintenance Work | SE CITY | AE(Maint.) | No | 1.82 | Paper Declared | SOYABEAN CENTER, NANAK NAGAR, 1SHIVAM NAGAR, univercity quarter indira puri, soyabeen canter gate, 29/2 arya point,8 indira puri colony, |
| 19 | INDORE CITY | South Division | Sabji Mandi | 11 kv | Pipliyapala | CHQ | 06.07.2019 | 06:30:00 | 09:30:00 | 03:00:00 | Tree Cutting &line Maintenance Work | SE CITY | AE(Maint.) | No | 1.3 | Paper Declared | New kissan indusric,lagan garden, ashok plastic ke pass. |
| 20 | INDORE CITY | South Division | Mayur nagar | 11 kv | Mayur nagar | CHQ | 06.07.2019 | 07:00:00 | 09:00:00 | 02:00:00 | To Avoid Accident Urgent Required Line Maintenance IPDDS work at Mayur Nagar | SE CITY | AE(Maint.) | No | 1.38 | | SHANI NAGAR, MAYUR NAGAR, JAN SEVA,PINC CITY, ANUJSHRI KIRANA BHANDAR, |
| 21 | INDORE CITY | South Division | Navlakha | 33 kv | Rajmohalla no. 1 & 2 O/G | CHQ | 06.07.2019 | 09:00:00 | 10:00:00 | 01:00:00 | 33 kv Line Maintenance work | SE CITY | AE(Maint.) | Yes | Nil | | Nil |
| 22 | INDORE CITY | South Division | Subji mandi | 11 kv | main. 1& 4 | CHQ | 06.07.2019 | 06:00:00 | 06:30:00 | 00:30:00 | "Y" & "B" Phase CT red hart work at Yard | SE CITY | AE(Maint.) | NO | 0.72 | | 11 kv Rajendra nagar "Lokmanya nagarBijalpur, gayatri nagar " pawan putra nagar " |
| 23 | INDORE CITY | South Division | Sabji mandi | 33 KV | Sabji mandi I/C | CHQ | 06.07.2019 | 06:30:00 | 06:45:00 | 00:15:00 | 33 kv Sabji mandi O/G feeder I/C Isolator clamp red hot work | SE CITY | AE(Maint.) | No | 2.49 | | 11 kv All feeder |
| 24 | INDORE CITY | | CITY CONTROL ROOM | 11KV | TILAK PATH | CHQ | 06.07.2019 | 08:00:00 | 11:00:00 | 03:00:00 | I.P.D.S LINE MAINTENANCE WORK. | SE CITY | AE(Maint.) | NO | 0.95 | Paper Declared | RAMBAAG, NARAYAN BAAG, JATI COLONY AND RELATED KSHETRA |
| 25 | INDORE CITY | WEST | AERODROME | 11KV | B.S.F. | СНО | 06.07.2019 | 08:00:00 | 11:00:00 | 03:00:00 | I.P.D.S LINE MAINTENANCE WORK. | SE CITY | AE(Maint.) | NO | 0.8 | Paper Declared | B.S.F. KEMPAS, AIRPORT COLONY, TELEPHONE EXCHENGE, VIDHYADHAM KE SAMNE, KALANI NAGAR AND RELATED KSHETRA. |
| 26 | INDORE CITY | WEST | AERODROME | 11KV | VIDHYADHAM | CHQ | 06.07.2019 | 08:00:00 | 11:00:00 | 03:00:00 | I.P.D.S LINE MAINTENANCE WORK. | SE CITY | AE(Maint.) | NO | 0.6 | Paper Declared | KRISHA BAAG COLONY, CITY NARSHING HOME,MALWA HOSPITAL, SHIKSHAK |
| 27 | INDORE CITY | WEST | CITY CONTROL ROOM | 11KV | 11kv SANWER ROAD | CHQ | 06.07.2019 | 08:00:00 | 10:00:00 | 02:00:00 | FOR I.P.D.S AND L.T LINE MAINTENANCE WORK. | SE CITY | AE(Maint.) | NO | 1 | | BAANGANGA, MARIMATA , RAGHUVANSHI COLONY, AND RELATED KSHETRA. |
| 28 | Indore city | West | RajMohalla | 33 kv | 8 MVA PTR No. 2 | - | 06.07.2019 | 07:00 | 07:30 | 00:30 | Due to PTR Oil Leakage | SE CITY | AE(Maint.) | NO | 1 | | Rani palace, Ambar nagar, Daimond palace, & ETC |
| 29 | Indore city | West | RajMohalla | 33 kv | 5 MVA PTR No. 3 | - | 06.07.2019 | 07:30 | 08:00 | 00:30 | Due to PTR Oil Leakage & 11 kv Main no1 VCB's TNC Switch Defective | SE CITY | AE(Maint.) | NO | 0.68 | | Dravin nagar, Nakoda Chook, Kut-Kut Bhawan, Ranjeet hanuman, & ETC |