	M.P.P.K.V.V. C, LTD. INDORE CIRCLE															
	Planned shutdown DATE- 02.11.2019															
S.N	Name of Circle	NAME OF DIVISION	Name of EHV S/s or 33/11 KV S/s	Line KV Capacity (33 or 11)	Name of 33 KV / 11 KV feeder	Group (for 33KV) / Category (for 11 KV)	Date of Planned Shutdown	Duration of to		Reason for Planned Shutdown (Maintenance/Erection work/ FSP / Safety purpose etc.)	Shutdown Approved by		Alternate Supply Arrangements are available or not (Yes/No)	It has been Reported on Whatsapp Group	Demand in MW affected Remark(Ar due to Shutdown,	
1		South Division	Palda Industrial	33 kv	Palda Industrial	CHQ	02.11.2019	6:00 6:3		33 kv feeder ME B-phase Bushing Oil Lekages & Red		AE(Maint.)	Yes	Yes	due to Shutdown. as affected  Nil	Nil
2	INDORE CITY	South Division	University	11 kv	Bas bar & 11 kv Main no. 1	СНQ	02.11.2019	6:30 7:3	0 1:00	main no. 1 R-phase CT Clamp red hot & Bas side Isolator clamp red hot work at yard	SE CITY	AE(Maint.)	NO	Yes	1.36	Ganesh Nagar, Filter Plant, Ekta Nagar, Sodnam Dhaba, Soniya Gandhi Nagar, Rahul Gandhi Nagar, Ganesh Nagar-1, Jeet Nagar, Jeet Nagar-2, Kamdhenu Park Colony-1, Nanak Nagar, 1shivam Nagar, 94 Shivam Nagar, Soyabean Anusandhan Kendra, 301/1 Pipliya Rao, Tulsi Jai Singhani,
3	INDORE CITY	South Division	Univercity	11 kv	Khandwa naka	CHQ	02.11.2019	6:30 7:3	0 1:00	11 kv feeder Y-phase CT clamp red hot work at yard	SE CITY	AE(Maint.)	No	Yes	0.64	SOYABEAN CENTER, NANAK NAGAR, 1SHIVAM NAGAR,
4	INDORE CITY	South Division	University	11 kv	Main no. 3	сно	02.11.2019	6:30 7:3	0 1:00	11 kv Vishnupuri feeder R-phase I/C side Isolator & Male ,Female contect red hot work at yard	SE CITY	AE(Maint.)	No	Yes	0.84	$11\mathrm{kv}$ Vishnupuri & Indrapuri feeder affected aera
5	INDORE CITY	South Division	Sabji mandi	11 kv	Main No.4	CHQ	02.11.2019	7:30 8:0	0:30	11 kv Pawanputra + Bijalpur feeder Bas side Isolator Y-phase clamp red hot work at Yard	SE CITY	AE(Maint.)	No	Yes	1.3	11 kv All feeders
6	INDORE CITY	South Division	Indira Complex	11 kv	Indira Complex	CHQ	02.11.2019	9:00 9:3	0:30	11 kv feeder Y-phase ME Clamp red hot work at yard	SE CITY	AE(Maint.)	No	Yes	0.68	Janki nagar, opp vishal tower-1,opp vishal tower-2, indira complex, opp krishna hostel, krishna boys hostel
7	INDORE CITY	South Division	Mayur nagar	11 kv	Ram nagar	CHQ	02.11.2019	9:30 10:0	0:30	11 kv feeder B-phase O/G Side Isolator Clamp red hot work at yard	SE CITY	AE(Maint.)	No	Yes	0.73	SHRI BALAJI ENG KE SAMNE, PRABHU TOLE KATA KE SAMNE,APURVA PALACE, VAEDAN FACTORY,
8	INDORE CITY	South Division	Sabji Mandi	11 kv	Rajendra Nagar	CHQ	02.11.2019	7:00 9:0	0 2:00	Tree cutting & Line Maintenance work	SE CITY	AE(Maint.)	No	Yes	1.4	Bijalpur Chouraha, Kesharbag Road ,Tata Tower , Amitesh Nagar, Atg Appt Amitesh Ngar,
9	INDORE CITY	EAST	TUKOGANJ	11kv	SNEHLATAGANJ	CHQ	02.11.2019	6:30 7:0	0:30	FOR CT RED HOT ATTEND WORK.	SE CITY	AE(Maint.)	NO	Yes	0.65	${\bf AGNIBAN\ PRESS, SNEHLATA\ GANJ\ ,\ RALWAY\ MAL\ GODAM\ AND\ PASHU\ CHIKITSALAY.}$
10	INDORE CITY	EAST	SC.NO.134	11kv	BARLA,AASRFI NGR. & SECTOR- F	СНО	02.11.2019	7:00 7:3	0:30	FOR X-MER NO.1 MAIN VCB CT RED HOT ATTEND WORK.	SE CITY	AE(Maint.)	NO	Yes	0.95	IDA QATER, SLATER HOUSE AND JASPAL DA DABA,ASHRFI NAGAR , DOLAT BAG, ZALARIA ROAD,SCHME NO. 134 , SECTOR F ETC.
11	INDORE CITY	EAST	GOYAL NGR.	11KV	CHOUHAN NGR.	CHQ	02.11.2019	10:00 12:3	30 2:30	TREE CUTTING & X-MER REPLACEMAINT / LINE SHIFITING WORK AT FLY OVER BRIDGE PIPLIYAN SQUAER.	SE CITY	AE(Maint.)	NO	Yes	0.5	PIPLIYA HANA, RAVI MASALA, DEEPAK NAGAR, DEEPAK NAGAR AND KOTHARI COLLAGE ETC.
12	INDORE CITY	EAST	SC.NO.140 TALAB WALA	11KV	GANESH DHAM	CHQ	02.11.2019	11:30 12:0	00 0:30	POLE ERECTION WORK BY IPDS.	SE CITY	AE(Maint.)	NO	Yes	0.45	ASHISH NAGAR , BRAJESHWARI NX, GANESH DHAM AND SHUBHLABH PRIMIUM ETC.
13	INDORE CITY	WEST	CITY CONTROL ROOM	11KV	11 MAIN NO1	CHQ	02.11.2019	08:00 08:1	5 00:15	11kv urja parisar feeder i/c isolator R.B phase o/g side clamp red hot work.	SE CITY	AE(Maint.)	NO	Yes	0.75	11kv jail road, VIP, URJA PARISAR
14	INDORE CITY	WEST	CITY CONTROL ROOM	11KV	Tilakpath	CHQ	02.11.2019	07:30 08:0	00:30	y phase ct clamp red hot work. &200kva Dtr Charging work at rambag	SE CITY	AE(Maint.)	NO	Yes	0.5	GPH Compound, Swadesh Press, Narayan Bagh, Malhar Aashram, Chandan Apart., Panth Vaidh Colony, Jatti Colony, Tapsya Apart., Etc.
15	INDORE CITY	WEST	pagnispaga	11KV	Harsiddhi,pipli bazar	CHQ	02.11.2019	05:45 06:0	00:15	11harsiddi i/c isolator clamp red hot work.	SE CITY	AE(Maint.)	NO	Yes	0.25	Harsidhi Bagicha & Main Road, Kadav Ghat, Matan Market, Shakil Sabji Wala, Ghoda Gali, Tokni Wala, RamLaxman Bazar, Pipli Bazar, Nakoda Tower, Samosa Corner, ImamBada, Niharpura, Sarvate Complex, Gopal Tempal, Atala Bazar.
16	INDORE CITY	WEST	pagnispaga	11KV	11 MAIN NO2	CHQ	02.11.2019	06:00 06:2	00:20	R phase ct clamp red hat work& Yashwant road o/g Ab Switch y phase clamp red hot Work	SE CITY	AE(Maint.)	NO	Yes	0.4	11KV YASHWANT ROAD, KRASHNPURA
17	INDORE CITY	WEST	SANGAM NAGAR	11KV	Aerodrum.2	CHQ	02.11.2019	09:00 09:3	00:30	For tree Cutting work.	SE CITY	AE(Maint.)	NO	Yes	0.25	Hammal Colony, Sukhdeb Nagar Ex., Lock Nayak Nagar, GuruKripa Colony, Vyanktesh Nagar Ex., Ambikapuri, Kanykubaj Nagar,
18	INDORE CITY	Central	Rajendra Nagar	11 KV	Main -1	CHQ	02.11.2019	06:30 06:5	00:20	Due to R Phase CT Red hot Work	SE CITY	AE(Maint.)	NO	Yes	0.65	11 KV Annapurna & Sukhniwas Affected
19	INDORE CITY	Central	Rajmohalla	11 KV	Malharganj	CHQ	02.11.2019	12:00 13:0	01:00	Due to CT Replacement Work by STM	SE CITY	AE(Maint.)	NO	Yes	0.7	Silawat Pura.malharganj.Biyabani.Jangam Pura & ETC
20	INDORE CITY	Central	Bijalpur	33 KV	Bijalpur-1	CHQ	02.11.2019	10:00 11:0	01:00	B Phase I/C AB Switch Male & Female Replacement & CT replacement Work	SE CITY	AE(Maint.)	NO	Yes	1.2	11 KV Prabhu Nagar & Siddhipuram & Ahirkhedi Grid All 11 KV Feeder Affected
21	INDORE CITY	Central	Silicon City	11 KV	Feeder no 4	CHQ	02.11.2019	14:00 15:0	01:00	Due to ME Replacement Work at Grid	SE CITY	AE(Maint.)	NO	Yes	0.5	Silicon City Colony Affected
22	INDORE CITY	North	33/11 kv LIG	11 KV	11 kv Old Palasiya	CHQ	02.11.2019	14:00 14:3	00:30	for New HT Consumer work of Panchan Daas Company	SE CITY	AE(Maint.)	NO	Yes	0.45	Shopping complex, Industry house, Onam Plaza, Sanjivni nursingh home, Hotel Amaltas, RK Puram colony, sanjay upvan, Dev nagar,