

M.P.P.K.V.V. C. LTD. INDORE CIRCLE																		
S.N o	Name of Circle	NAME OF DIVISION	Name of EHV S/s or 33/11 KVS/s	Line KV Capacity (33 or 11)	Name of 33 KV / 11 KV feeder	Planned shutdown			DATE- 26.09.2019									
						Group (for 33KV) / Category (for 11 KV)	Date of Planned Shutdown	Duration of From to	Total Duration	Reason for Planned Shutdown (Maintenance/Erection work/ FSP / Safety purpose etc.)	Shutdown Approved by -	Approval Granted to-	Alternate Supply Arrangements are available or not (Yes/No)	It has been Reported on Whatsapp Group	Demand in MW affected due to Shutdown.	Remark(Are as affected)	Remark(Areas affected)	
1	INDORE CITY	Central	Annapurna	11 kv	Paraspar nagar	CHQ	26.09.2019	8:00	11:00	3:00	3 Span Conductor Stringing Work at Road Crossing Near Chankya Puri Square Under IPDS	SE CITY	AE(Maint.)	No	YES	2.02	Paper Declared	Pricanco Colony, Sudama nagar, Paraspar nagar, Gopur Squae, Sahjivan nagar & ETC
2	INDORE CITY	Central	Pragati nagar	11 kv	Siddhipuram	CHQ	26.09.2019	8:00	11:00	3:00	2 No. DTR Augmantation Work At Vaishali nagar & Ahliya nagar Under IPDS	SE CITY	AE(Maint.)	No	YES	0.69	Paper Declared	Vaishali nagar, Ahliya nagar, Braj Vihar, Siddhipuram, & ETC
3	INDORE CITY	Central	Footi kothi	11 kv	Vidur nagar	CHQ	26.09.2019	8:00	11:00	3:00	4 No. Pole Erection & 3 Span Counductor Stringing Work at Vidur nagar Under IPDS	SE CITY	AE(Maint.)	No	YES	0.72	Paper Declared	CAT Road, Rishi Palace, Digvijay Multi, hawabangla Road & Etc
4	INDORE CITY	Central	Bijalpur	11 kv	Sanjay nagar	CHQ	26.09.2019	8:00	11:00	3:00	3 No. Pole Erection & 2 No. DTR Charging at Jitu Patwari ji Office, Soni garden,Bijalpur Mini School Under IPDS	SE CITY	AE(Maint.)	No	YES	0.64	Paper Declared	Sanjay nagar, Grma Bijalpur, & ETC
5	INDORE CITY	Central	Nagin nagar	11 kv	Rani palace	CHQ	26.09.2019	8:00	11:00	3:00	2 No. DTR Charging & Jumping Work at Nagin nagar kakad Mata mandir Under IPDS	SE CITY	AE(Maint.)	No	YES	0.71	Paper Declared	Rani palace, Ambar nagar,Daimond palace, Sirpur kakad & ETC
6	INDORE CITY	Central	Rau	11 kv	Rau-2	CHQ	26.09.2019	8:00	11:00	3:00	3 NO. Pole Erection & Counductor Stringing Work at RauShramik Colony,Saria Ward IPDS	SE CITY	AE(Maint.)	No	YES	0.45	Paper Declared	Shramik Colony, Saria Ward, Swastik Vihar, Kanha Park Cancerr Hospital, Cat Road & ETC,
7	INDORE CITY	Central	Revenue nagar	11 kv	Usha nagar	CHQ	26.09.2019	8:00	11:00	3:00	4 No. Pole Erection & 2 No. DTR Installation at Usha raje Maglik Parisar Near Usha nagar Under IPDS	SE CITY	AE(Maint.)	YES	YES	0.35	Paper Declared	Usha Nagar, Usha nagar EXT, Mhow Naka, mahalaxmi mandir & Etc
8	INDORE CITY	Central	Footi kothi	11 kv	Ahirkhedi	CHQ	26.09.2019	17:30	18:00	0:30	Due to VCB Trip Test Work by STM	SE CITY	AE(Maint.)	No	YES	0.4		Ahirkhedi, Gram Ahirkhedi kakad, Ht Conn. Shradha Saburi Colony, Vidur nagar, Choudhary market & Etc
9	INDORE CITY	Central	Footi Kothi	11 kv	Footi Kothi & Sudama nager	CHQ	26.09.2019	7:00	7:30	0:30	Jumper Open For 200 KVA DTR Shifting Work Under 5 % Super Vision BY CONTACTOR JAGPAL SINGH Near Sudama Nagar	SE CITY	AE(Maint.)	No	YES	0.35	ONLY 1 NO DTR AFFECTED	vikram squire, footi kothi circle
10	INDORE CITY	Central	Footi Kothi	11 kv	Footi Kothi & Sudama nager	CHQ	26.09.2019	10:00	10:30	0:30	Due to Jumper Reconnected After Work	SE CITY	AE(Maint.)	No	YES	0.25	ONLY 1 NO DTR AFFECTED	vikram squire, footi kothi circle
13	INDORE CITY	Central	Rau	11 kv	Pigdamber Rural	CHQ	26.09.2019	9:00	10:00	1:00	1 no DTR Charging Work At maa padmawati Colony under 5 % supervision	SE CITY	AE(Maint.)	No	YES	0.5		maa padmawati Colony Affected
14	INDORE CITY	Central	Gumasta nagar	11 kv	Main no 3	CHQ	26.09.2019	6:30	6:50	0:20	Due to Isolator jumper Repairing Work At Grid	SE CITY	AE(Maint.)	No	YES	0.25		11 KV Sirpur & Dwarkapuri Affected
15	INDORE CITY	Central	Rajendra nagar	11 kv	Main no 1	CHQ	26.09.2019	11:15	11:45	0:30	Due to AB Switch Male ,Female Replacement & Repairing Work At Grid	SE CITY	AE(Maint.)	No	YES	0.4		takshila parisar, Dhanvantri nagar, Rajendra nagar, Waman Polotenic Collage ,Rajendra nagar Naka, Narang Cold Storage, Bhim nagar, Durga nagar & ETC
16	INDORE CITY	South Division	palda naka	33 kv	Navlakha no.01 l/c	CHQ	26.09.2019	7:00	7:30	0:30	i/c isolatore R phase clamp red hot work	SE CITY	AE(Maint.)	No	YES	1.87		all feeder
17	INDORE CITY	South Division	Karbala	11 kv	prem nagar	CHQ	26.09.2019	8:00	12:00	4:00	4 NO. POLE ERECTION WORK BY KSHAMA POWER NEAR PREM NAGAR UNDER IPDS	SE CITY	AE(Maint.)	No	YES	2.69	Paper Declared	prem nagar ,gopal bagh, manik bagh
18	INDORE CITY	South Division	Tejaji nagar	11 kv	Anuradha nagar	CHQ	26.09.2019	14:00	17:00	3:00	6 No. Pole Erection & Gaurning work by Kshama power Under IPDS	SE CITY	AE(Maint.)	No	YES	1.96	Paper Declared	aniradha nagar ,kelod kartal & other area
19	INDORE CITY	South Division	Pagnis paga	11 kv	Moti tabela	CHQ	26.09.2019	8:00	10:00	2:00	200 kva DP Structure work by STC at Vasudev nagar	SE CITY	AE(Maint.)	No	YES	2.02		pagnis paga ,guru kripa apartment
20	INDORE CITY	South Division	Pagnis paga	11 kv	Palsikar	CHQ	26.09.2019	10:00	12:00	2:00	1 No. DTR Charging & 4 span conductor stringging work BY STC	SE CITY	AE(Maint.)	No	YES	1.27		Palsikar colony, & other area
21	INDORE CITY	EAST	SHALIMAR TOWNSHIP	11KV	SHALIMAR TOWNSHIP	CHQ	26.09.2019	8:00	10:00	2:00	FOR RMU CABLE INSTALLATION & CHARGING WORK.	SE CITY	AE(Maint.)	NO.	YES	0.25		SHALIMAR TOWN, BAPU NAGAR AND GULAB BAG
22	INDORE CITY	EAST	SATYA SAI	11KV	SCH NO. 94	CHQ	26.09.2019	8:00	9:00	1:00	FOR EXTENSION BRACKET INSTALL WORK under 5 % supervision by contactor kushwah ji AT MANSAROWAR NAGAR.	SE CITY	AE(Maint.)	NO.	YES	0.45	2 No. DTR Affected	CLASSIC PURNIMA, SHEETAL NAGAR, CHIKITK NAGAR AND GULAB BAG COLONY ETC.
23	INDORE CITY	EAST	MANORAMAGA NJ	11KV	KANCHANBAGH	CHQ	26.09.2019	12:30	13:00	0:30	VCB TRIP TEST WORK BY STM.	SE CITY	AE(Maint.)	NO.	YES	0.65		KANCHANBAG, APPLD TOWER, INDRAPRASTH TOWER M.G. ROAD AND SOUTH TUKOGANJ ETC.
24	INDORE CITY	EAST	MANORAMAGA NJ	11KV	TELEPHONE EXCHANGE 2	CHQ	26.09.2019	13:30	14:00	0:30	VCB TRIP TEST WORK BY STM.	SE CITY	AE(Maint.)	NO.	YES	0.5		KANCHANBAG, VISHESH HOSPITAL , NATHMANDIR AND HIGH COURT ETC.
25	INDORE CITY	EAST	PRESS COMPLEX	11KV	ANOOP NAGAR	CHQ	26.09.2019	14:30	15:00	0:30	VCB TRIP TEST WORK BY STM.	SE CITY	AE(Maint.)	NO.	YES	0.25		KAKAD, LIFE LINE HOSPITAL, KALINDI KUNJ AND PUSHP NAGAR ETC.
26	INDORE CITY	EAST	SANJNA PARK	33KV	10MVA POWER X-MER	CHQ	26.09.2019	11:30	12:30	1:00	10MVA POWER X-MER MAINTENANCE WORK BY STM.	SE CITY	AE(Maint.)	NO.	YES	0.95		SANJNA PARK GRID AFFECTED.
27	INDORE CITY	EAST	SC.NO.140 TANKI WALA	33KV	5MVA POWER X- MER	CHQ	26.09.2019	8:30	9:30	1:00	5MVA POWER X-MER NO.1 MAINTENANCE WORK BY STM.	SE CITY	AE(Maint.)	YES.	YES	Nil		WILL BE SUPPLY CHANGEOVER AVALIBEL
28	INDORE CITY	EAST	SC.NO.140 TANKI WALA	33KV	5MVA POWER X- MER	CHQ	26.09.2019	9:30	10:30	1:00	5MVA POWER X-MER NO.2 MAINTENANCE WORK BY STM.	SE CITY	AE(Maint.)	YES.	YES	Nil		WILL BE SUPPLY CHANGEOVER AVALIBEL
29	INDORE CITY	WEST	SANGAM NAGAR	11KV	RAMBALI NAGAR	CHQ	26.09.2019	6:00	6:30	0:30	FOR ME OIL LEAKAGE WORK AT S/S	SE CITY	AE(Maint.)	NO	YES	0.45		All LT Consume & Laxmipura Colony, Laxmanpura Eat Bhatta, Archana Nagar.
30	INDORE CITY	WEST	PAGNINS PAGA	11KV	KRISHNAPURA	CHQ	26.09.2019	6:45	7:00	0:15	FOR B -PHASE CT CLAMP RED HOT WORK.	SE CITY	AE(Maint.)	NO	YES	0.5		Chadrbhaga Pul, Kabuter Khana, Sona Kohinoor, Resham Wala Len, LaxmiNarayan Tempal, Mangal Sadan, Pandri Nath Police Station, Pandri Nath Tempal.
31	INDORE CITY	WEST	SECTOR-A	11KV	SECTOR-A	CHQ	26.09.2019	13:00	13:30	0:30	FOR 200KVA FAILED X-MER Replacement WORK AT SANWER ROAD SECTOR-A SAI MACHINE TOOL	SE CITY	AE(Maint.)	NO	YES	0.35		All LT Consumer & Mungad Alu, Meta Tubey, Sciye Line, Indore Naitred, Quajer Eng., Ast Vinayak, Tirupati Printo Pek, Rajput Ind.
32	City Indore	North	220 North Zone	33 kv	33 kv Sector C	CHQ	26.09.2019	17:15	17:45	00:30	For ME Change work of HT Consumer Mudra Steel	SE CITY	AE(Maint.)	yes	YES	Nil		15 NO. HT Consumer Affected
33	City Indore	North	33/11 kv 114	11 kv	11 kv Army Welfare	CHQ	26.09.2019	06:30	11:00	04:30	line maintenance & Tree Cutting work	SE CITY	AE(Maint.)	NO	YES	0.45	Paper Declared	Army Welfare Areas affected
34	City Indore	North	33/11 kv 114	11 kv	11 kv Rajiv 1st	CHQ	26.09.2019	07:30	08:30	01:00	Line Safety Purpose work on 11 kv Army Welfare	SE CITY	AE(Maint.)	NO	YES	0.35		Rajeev Avash vihar main road, Critian Colony, Schm.no.78,
35	INDORE CITY	North	33/11 kv Vijay nagar	11 kv	11 kv Scheme No. 78	CHQ	26.09.2019	8:00	11:00	3:00	for Feeder Bifurcation work by STC Team	SE CITY	AE(Maint.)	NO	YES	0.45		Schm.No.78, Prestige Public school
36	INDORE CITY	North	33/11 kv Vijay nagar	33 kv	33 kv Scheme no. 78 1st & 2nd	CHQ	26.09.2019	10:00	11:00	1:00	for Safety Purpose work On Scheme no. 78	SE CITY	AE(Maint.)	No	YES	0.25		33/11 kv Scheme No 78 Grid Affected
37	INDORE CITY	North	33/11 kv Loha mandi	11 kv	11 kv main	CHQ	26.09.2019	16:00	16:30	0:30	VCB TRIP TEST WORK BY STM.	SE CITY	AE(Maint.)	No	YES	0.65		11 kv Lasudiya naka & New Loha mandi & Niranjan Pur
38	INDORE CITY	North	33/11 kv Loha mandi	11 kv	11 kv New Loha mandi	CHQ	26.09.2019	16:30	17:00	0:30	VCB TRIP TEST WORK BY STM.	SE CITY	AE(Maint.)	No	YES	0.5		New loha mandi,
39	INDORE CITY	North	33/11 kv Vijay naagr	11 kv	11 kv Sicca School	CHQ	26.09.2019	6:00	6:30	0:30	Y-phase CT Clamp Red hot work	SE CITY	AE(Maint.)	No	YES	0.35		A.B.Road, Rajat Jayanti, Idea colony, Vijay Ngr. Thana, Sky Park, Pakija Show room, Krashu Motors, La omni garden

40	INDORE CITY	North	33/11 kv Scheme no. 136 1st	33 kv	33 kv ESI 1st (o/g)	CHQ	26.09.2019	7:00	7:30	0:30	B-phase CT Clamp Red hot work of 33 kv ESI 1st	SE CITY	AE(Maint.)	No	YES	0.5		sch.no. 136 -I s/s
41	INDORE CITY	North	33/11 kv Modern	11 kv	11 kv B-1	CHQ	26.09.2019	17:00	18:00	1:00	For 1 No. DTR Charging Work By STC Near ganesh Dham colony	SE CITY	AE(Maint.)	No	YES	0.25		Sector F Industrial Area