

M.P.P.K.V.V. C. LTD. INDORE CIRCLE																		
Planned shutdown																		
DATE- 17.09.2019																		
S.No	Name of Circle	Name of DIVISION	Name of EHV S/c or 33/11 KV S/c	Line KV Capacity (33 or 11)	Name of 33 KV / 11 KV feeder	Group (for 33KV) / Category (for 11 KV)	Date of Planned Shutdown	Duration of From	To	Total Duration	Reason for Planned Shutdown (Maintenance/Erection work/ PSP / Safety purpose etc.)	Shutdown Approved by	Approval Granted to	Alternate Supply Arrangements are available or not (Yes/No)	It has been Reported on Whatsapp Group	Demand in MW affected due to Shutdown	Remark(Are as affected)	Remark(Areas affected)
1	INDORE CITY	Central	Revenue nagar	11 kv	Usha nagar	CHQ	17.09.2019	8:00	11:00	3:00	Due to 3 No. Pole Erection & 2 No. DTR Installation at Usha raje Maglik Parisar Near Usha nagar Under IPDS	SE CITY	AE(Maint.)	No	YES	0.5	PAPER DECLARED	Usha Nagar, Usha nagar EXT, Mhow Naka, mahalaxmi mandir & Etc
2	INDORE CITY	Central	Revenue nagar	11 kv	Madhuban	CHQ	17.09.2019	10:00	11:00	1:00	Due to Double CKT With Usha nagar For Safety Purpose	SE CITY	AE(Maint.)	No	YES	0.45		Madhuban Colony, Ghanishyam Das nagar, Moon palace, Colony, Indra Ghandi nagar & Etc
3	INDORE CITY	Central	Pragati nagar	11 kv	Pragati nagar	CHQ	17.09.2019	8:00	11:00	3:00	Due to 3 Span Conductor stringing & Guarding Tighting & 2 No. Pole Erection Work at Near Water tank Pragati nagar Bhagat Sing garden Under IPDS	SE CITY	AE(Maint.)	No	YES	0.45	PAPER DECLARED	Pragti Nagar, Krishna nagar, Parashar nagar, Jawahar nagar & ETC
4	INDORE CITY	Central	Gumasta nagar	11 kv	Sirpur	CHQ	17.09.2019	8:00	11:00	3:00	Due to 3 No. DTR Renovation & installation Work At Nalle Wali DP Noorani nagar Under IPDS	SE CITY	AE(Maint.)	No	YES	0.5	PAPER DECLARED	Noorani nagar, Green park Ambar nagar Geeta nagar
5	INDORE CITY	Central	Rajendra nagar	11 kv	Annapurna	CHQ	17.09.2019	8:00	11:00	3:00	Due to 2 No. Pole Erection & 3 Span Conductor Stringing Work at Takshila & Woman polotecnik Collage Under IPDS	SE CITY	AE(Maint.)	No	YES	0.35	PAPER DECLARED	takshila parisar, Dhanvantri nagar, Rajendra nagar, Waman Polotecnik Collage & ETC
6	INDORE CITY	Central	Navda panth	11 kv	Sinhasa IP	CHQ	17.09.2019	8:00	11:00	3:00	Due to 2 No. Pole Erection Work At Gram Bank Basti Under IPDS	SE CITY	AE(Maint.)	No	YES	0.4	PAPER DECLARED	Gram Sinhasa, Gram bank, Ahmad nagar, P K bandhu parisar & ETC
7	INDORE CITY	Central	Rau	11 kv	Pigdamber IP	CHQ	17.09.2019	8:00	10:00	2:00	Due to DTR Charging , Jumping Work at Near Rau Grid kamal nagar Under IPDS	SE CITY	AE(Maint.)	No	YES	0.5		Rau, Mama ka Dhaba,ram rahim Colony, Kishan Sheet Grah, Jhumar Ghat, Shri Krishna Peradise, Maa padmawati Colony & ETC
8	INDORE CITY	Central	Rau	11 kv	Pigdamber Rural	CHQ	17.09.2019	8:00	11:00	3:00	Due to DTR Charging , Jumping Work at Near Rau Grid kamal nagar Under IPDS	SE CITY	AE(Maint.)	No	YES	0.35	PAPER DECLARED	Rau, Mama ka Dhaba,ram rahim Colony, Kishan Sheet Grah, Jhumar Ghat, Shri Krishna Peradise, Maa padmawati Colony & ETC
9	INDORE CITY	Central	Rajendra nagar	11 kv	Annapurna	CHQ	17.09.2019	8:30	9:00	0:30	Due to VCB CT Replacement Work by STM	SE CITY	AE(Maint.)	No	YES	0.5		takshila parisar, Dhanvantri nagar, Rajendra nagar, Waman Polotecnik Collage & ETC
10	INDORE CITY	Central	Rajendra nagar	11 kv	PTR no 2	CHQ	17.09.2019	9:00	9:30	0:30	Due to VCB Testing & Oil Topping Work by STM	SE CITY	AE(Maint.)	No	YES	0.95		Area Affected Releted to This Feeder
11	INDORE CITY	Central	Rau	11 kv	Main no 1	CHQ	17.09.2019	10:00	11:00	1:00	Due to VCB CT Replacement & Testing Work by STM	SE CITY	AE(Maint.)	No	YES	0.85		11 kv rau-2 Rangwasa, Royal park Affected
12	INDORE CITY	South Division	Indira Complex	33 kv	O.P.H. O/G	CHQ	17.09.2019	6:00	6:30	0:30	33 kv feeder Y-phase ME clamp red hot work	SE CITY	AE(Maint.)	Yes	YES	Nil		Nil
13	INDORE CITY	South Division	Indira complex	33 kv	Indira complex no. 2 & Bas Cupler	CHQ	17.09.2019	6:00	6:30	0:30	33 kv feeder CT clamp/ Bas bar Y-phase Isolator I/C Clamp red hot work at Yard	SE CITY	AE(Maint.)	No	YES	1.36		11 kv GPO , DAVA BAZAR, INDIRA COMPLEX, SANWAD NAGAR, T. S. -II & T.S. -I , LOHA MANDI, NAV COMPLEX, SADHU WASWANI
14	INDORE CITY	South Division	Indira Complex	33 kv	Main no. 1 & 2	CHQ	17.09.2019	6:30	7:00	0:30	11 kv main no. CT Clamp & CT Jumper red hot work at Yard	SE CITY	AE(Maint.)	No	YES	1.3		11 kv T.S. no.1 & 2 feeder or Area , MATHURA WALA, GPO POST OFFICE, SHANKAR BAG ,CHAWNJI DIVISION OFFICE ,IDA COMPOUND
15	INDORE CITY	South Division	Khatiwala Tank	11 kv	Bairathi Colony	CHQ	17.09.2019	11:00	11:30	0:30	11 kv feeder O/G R-phase Isolator clamp red hot work	SE CITY	AE(Maint.)	No	YES	0.49		Simran palace,413.khaiwala tank,3/1 prem nagar manik bag,
16	INDORE CITY	South Division	Khatiwala tank	11 kv	5 mva no. 2	-	17.09.2019	11:00	11:30	0:30	11 kv main no.2 VCB R-phase Pole clamp & Virsawarkar feeder Y-phase Pole clamp red hot work at Yard	SE CITY	AE(Maint.)	NO	YES	0.67		11 kv Virsawarkar ,saifee feeder or area SAIFE NAGAR GARDEN, OPP. SAIF NAGAR,VINAR APPT
17	INDORE CITY	South Division	Palda naka	11KV	Kohinoor	CHQ	17.09.2019	7:00	9:00	2:00	X-MER DISMENTAL WORK BY STC at Kohinoor colony	SE CITY	AE(Maint.)	No	YES	1.62		CROMPTON GREAVES, SWASTIK ENTERPRISE, KOHINOOR COLONY
18	INDORE CITY	South Division	PAGNISPAGA	11 kv	Palsikar	CHQ	17.09.2019	9:00	10:00	1:00	X-MER REPLACEMENT WORK BY STC at Palsikar colony	SE CITY	AE(Maint.)	No	YES	0.84		PALAK APPT,PRENA COLLECTION, 51 VASUDEV NAGAR, COLLECTRATE CHOURAHA, palsikar feeder
19	INDORE CITY	South Division	Palda industrial	11 kv	Kalindi feeder	CHQ	17.09.2019	8:00	12:00	4:00	3 no. Pole Erection work by Kshama power Under IPDS scheme at Udhvog Nagar area	SE CITY	AE(Maint.)	No	YES	1.34	PAPER DECLARED	Udhvog nagar or related area
20	INDORE CITY	South Division	Indira Complex	11 kv	T.S. No. 2	CHQ	17.09.2019	12:30	13:00	0:30	11 kv feeder VCB Trip Test work by STM	SE CITY	AE(Maint.)	No	YES	0.36		11 kv feeder T.S. No. 2
21	INDORE CITY	South Division	Indracomplex	11 kv	Shankar bagh	CHQ	17.09.2019	13:00	13:30	0:30	11 kv feeder VCB Trip Test work by STM	SE CITY	AE(Maint.)	No	YES	0.49		Shankar Bagh ,Kalali Mohalla , Dhoobi Ghat
22	INDORE CITY	South Division	Mayur nagar	11 kv	main no.1	CHQ	17.09.2019	14:00	14:30	0:30	11 kv main no. CT Replacement work by STM	SE CITY	AE(Maint.)	No	YES	0.68		11 kv Ram Nagar , Firdosh Nagar , Pink City feeders
23	INDORE CITY	South Division	Mayur nagar	33 kv	Daily college no.2 I/C & O/G	CHQ	17.09.2019	15:00	15:30	0:30	33 kv feeder VCB Tripping Testing work by STM	SE CITY	AE(Maint.)	Yes	YES	Nil		Nil
24	INDORE CITY	South Division	Mount barg	11 kv	Nayta Mundla	CHQ	17.09.2019	16:00	16:30	0:30	11 kv feeder VCB Trip Test work by STM	SE CITY	AE(Maint.)	No	YES	0.74		11 KV Nayta Mundla feeder
25	INDORE CITY	South Division	Sabji Mandi	11 kv	Gayatri Nagar	CHQ	17.09.2019	17:00	18:00	1:00	11 kv VCB Wiring checked by STM	SE CITY	AE(Maint.)	No	YES	0.69		11 kv Gayatri nagar feeder
26	INDORE CITY	EAST	TUKOGANJ	11KV	MG ROAD	CHQ	17.09.2019	7:30	8:00	0:30	315 KVA FAIL X-MER REPLACEMENT WORK NEAR TIJORI GALL	SE CITY	AE(Maint.)	NO.	YES	0.25		GANDHI HALL, CENTAR COTAWALI, NAGARNIGAM AND MRUG NAYANI ETC.
27	INDORE CITY	EAST	VANDANA NGR.	11KV	RAVINDRA NGR. & PIPLIYAHANA	CHQ	17.09.2019	9:00	9:30	0:30	200 KVA FAIL X-MER REPLACEMENT WORK NEAR CLASSIC BUILDING	SE CITY	AE(Maint.)	NO.	YES	0.65		CHAMELI PARK , ARCHANA MEDICAL ,TILAK NAGAR AND VINOBA NAGAR ETC.
28	INDORE CITY	EAST	SAKET NGR.	11KV	PATRAKAR COLONY	CHQ	17.09.2019	9:30	10:00	0:30	100KVA FAIL X-MER REPLACEMENT WORK NEAR UNIC HOSPITAL	SE CITY	AE(Maint.)	NO.	YES	0.5		SAKET ZONE , KD CARE HOSPITAL, PATRAKAR CHOURAHA AND GAYATRI MANDIRE , MEDICARE ETC.
29	INDORE CITY	EAST	SANCHAR NGR.	11KV	PAKIZA LIFE STYLE	CHQ	17.09.2019	11:00	12:00	1:00	FOR 3 SPAN CONDUCTOR STRINGING WORK NEAR PAKIZA LIFE STYLE UNDER IPDS	SE CITY	AE(Maint.)	NO.	YES	0.35	PAPER DECLARED	PAKIZA LIFE STYLE
30	INDORE CITY	WEST	CITY CONTROL ROOM	11KV	JAIL ROAD	CHQ	17.09.2019	9:00	12:00	3:00	FOR 2 NO. DTR REPLACEMENT WORK NEAR STORE UNDER IPDS.	SE CITY	AE(Maint.)	NO.	YES	0.4	PAPER DECLARED	MTC Office, Neem Wali Mata, Dhut Ind., Vishisht Collage, (Iprotech. HTC)
31	INDORE CITY	WEST	KILA MAIDAN	11KV	CHATRAPATI NAGAR	CHQ	17.09.2019	9:00	12:00	3:00	FOR 3 NO. DTR JUMPER WORK AND CABLE STRINGING WORK NEAR KANDILPURA UNDER IPDS.	SE CITY	AE(Maint.)	NO.	YES	0.35	PAPER DECLARED	Kandilpura, Laxmbai Nagar FayarBigrediyar, Bheru Tempal, DalalBag, Chhatrapati Nagar, Agrasen Nagar, Mahavir Bag, Jain Swetamber (HTC), Piliyakhan, Sanbhagya Office.
32	INDORE CITY	WEST	M.P. NAGAR	11KV	KUSHWAH NAGAR	CHQ	17.09.2019	5:30	5:45	0:15	FOR B PHASE CT I/G RED HOT ATTEND WORK.	SE CITY	AE(Maint.)	NO.	YES	0.45		Indian School, Yadav Nand Nagar, Dargaha Wala, Kiran Pal Chakki, Munshiji Stechu, Rajaram Nagar, Kushwah Nagar, Khajur Wala Vishal Nagar, GangaBag Chouraha, Karma Nagar Gali No. 1, 2, 3, 4, New Govind Colony.
33	INDORE CITY	WEST	GANDHI NAGAR	11KV	11 MAIN NO- 01 (DENTAL COLLAGE, DEVDHARAM, GANDHI NAGAR, BANGARDA)	CHQ	17.09.2019	6:00	6:15	0:15	FOR Y- PHASE CT O/G SIDE CLAMP RED HOT WORK.	SE CITY	AE(Maint.)	NO.	YES	0.65		11KV DENTAL COLLAGE, DEVDHARAM, GANDHI NAGAR, BANGARDA
34	INDORE CITY	WEST	GANDHI NAGAR	11KV	11 MAIN NO- 03 (JAMBURI, NAINOD)	CHQ	17.09.2019	6:15	6:30	0:15	FOR O/G AB SWITCH R PHASE I/C SIDE CLAMP RED HOT WORK.	SE CITY	AE(Maint.)	NO.	YES	0.35		11KV JAMBURI, NAINOD
35	INDORE CITY	WEST	SANGAM NAGAR	11KV	AIRODRUM-02	CHQ	17.09.2019	9:30	10:30	1:00	FOR 25KVA DTR REPLACEMENT WORK AT AKHAND NAGAR NEAR FOLADI ATTA CHAKKI	SE CITY	AE(Maint.)	NO.	YES	0.4		Hammal Colony, Sukhdeb Nagar Ex., Lock Nayak Nagar, Gurukripa Colony, Vyanktesh Nagar Ex., Ambikapuri, Kanykubai Nagar,
36	INDORE CITY	North	33/11 kv Electronic Com	11KV	11KV EC-2	CHQ	17.09.2019	6:30	11:00	4:30	Line Maintenance & Tree Cutting Work	SE CITY	AE(Maint.)	NO.	YES	0.35	PAPER DECLARED	Electronic complex parisar
37	INDORE CITY	North	33/11 kv Setelite	11KV	11KV Magar Kheda	CHQ	17.09.2019	12:00	12:30	0:30	For VCB Trip Test Work by STM Team	SE CITY	AE(Maint.)	NO.	YES	0.45		Magar Kheda Area
38	INDORE CITY	North	33/11 kv Setelite	11KV	11KV Row House	CHQ	17.09.2019	12:30	13:00	0:30	For VCB Trip Test Work by STM Team	SE CITY	AE(Maint.)	NO.	YES	0.65		Row House Area
39	INDORE CITY	North	33/11 kv Setelite	5MVA	3.5 MVA PTR No.1	-	17.09.2019	13:00	13:30	0:30	For VCB Trip Test Work by STM Team	SE CITY	AE(Maint.)	NO.	YES	0.35		11kv FEEDER -I