

M.P.P.K.V.V. C. LTD. INDORE CIRCLE																		
S.N o	Name of Circle	NAME OF DIVISION	Name of EHV S/s or 33/11 KV S/s	Line KV Capacity (33 or 11)	Name of 33 KV / 11 KV feeder	Planned shutdown DATE- 18.08.2019					Reason for Planned Shutdown (Maintenance/Erection work/ FSP / Safety purpose etc.)	Shutdown Approved by -	Approval Granted to-	Alternate Supply Arrangements are available or not (Yes/No)	It has been Reported on Whatsapp Group	Demand in MW affected due to Shutdown.	Remark( Areas affected)	Remark(Areas affected)
						Group (for 33KV) / Category (for 11 KV)	Date of Planned Shutdown	Duration of Planned Shutdown		Total Duration								
								From	to									
1	INDORE CITY	WEST	PARGNISPAGA	11KV	MAIN-2	CHQ	18.08.2019	5:30:00	6:00:00	0:30:00	FOR 11KV KRISNAPURA FEEDER I/C SIDE Y PHASE ISOLATER CLAMP JUMPER RED HOT POINT	SE CITY	AE (HTM)	NO	YES	1		11 KV YASWANT ROAD+KRISNAPURA FEEDER
2	INDORE CITY	WEST	PARGNISPAGA	33KV	MAIN-3	VIII	18.08.2019	6:00:00	6:30:00	0:30:00	FOR R PHASE O/G SIDE JUMER CLAMP RED HOT POINT	SE CITY	AE (HTM)	NO	YES	0.9		11 KV MOTITABELA+PALSIKAR FEEDER
3	INDORE CITY	WEST	HEMILTAN ROAD	33KV	33KV MAIN	VIII	18.08.2019	6:30:00	7:00:00	0:30:00	FOR 33KV MAIN VCB POLE CLAMP RED HOT POINT ATTEND & 11KV HEMILTAN ROAD Y PHASE I/C SIDE ISOLATER CLAMP JUMPER RED HOT POINT WORK	SE CITY	AE (HTM)	NO	YES	0.8		11 KV HEMILTAN +NANDLALPURA FEEDER
4	INDORE CITY	WEST	SECTOR-A	11KV	SUNDER NAGER	CHQ	18.08.2019	10:00:00	11:00:00	1:00:00	FOR 25KVA &100 KVA FAILED DTR REPLACEMENT WORK AT KUSHWAH SHREE NAGER NEAR HANUMAN MANDIR & SHIV MANDIR	SE CITY	AE (HTM)	NO	YES	0.6		Ramnagar, Bajran Nagar, Vijayvargiy Nagar, Om Eat Bhatta, Sundar Nagar, Jagdish Nagar, Prince Nagar, Roshan Nagar, Pushpa Nagar, Piru Pahalwan Rishi Nagar, Kushwah Shree Nagar.
5	INDORE CITY	WEST	GANDHI NAGER	11KV	BUDHANIYA	CHQ	18.08.2019	12:00:00	12:45:00	0:45:00	FOR 200KVA DTR REPLACEMENT WORK AT NANDBAGH GALI NO.-3 NEAR SUKLA KIRANA	SE CITY	AE (HTM)	NO	YES	0.7		BUDHANIYA
6	INDORE CITY	WEST	SANGAM NAGAR	11KV	SANGAM NAGAR	CHQ	18.08.2019	8:00:00	9:00:00	1:00:00	3 NO CT REPLECMENT BY STM	SE CITY	AE (HTM)	NO	YES	0.8		Sangam Nagar, Riksha Stand. Laxmanpura, Gomti Nagar, Holmark School, IDL School.
7	INDORE CITY	WEST	ZINSI HAT	11KV	GORAKUND	CHQ	18.08.2019	12:00:00	12:30:00	0:30:00	1 NO CT REPLECMENT BY STM	SE CITY	AE (HTM)	NO	YES	0.6		Jinsi Hot Ground, Gajal Hotel, TV Hospital, Mahant Complex, Tamboli Bakhal, Cenra Bank, Gorakund Chouraha, Murli Tea, Madhuri Sadi, Junapith Mata Mandir, Pandya Electrical.
8	INDORE CITY	EAST	220KV - B.MARDANA	33KV	VANDANA NAGAR - 2	VIII	18.08.2019	6:30:00	10:30:00	4:00:00	LINE MAINTENANCE & TREE CUTTING WORK.	SE CITY	AE (HTM)	YES.	YES	-	PAPER DECLDED	WILL BE SUPPLY CHANGEOVER AVALIBEL.
9	INDORE CITY	EAST	GOYAL NGR.	11KV	BIJLI NGR.	CHQ	18.08.2019	6:30:00	10:30:00	4:00:00	LINE MAINTENANCE & TREE CUTTING WORK.	SE CITY	AE (HTM)	NO.	YES	0.7	PAPER DECLDED	LOKHANDWALA , BANGALI CHOURHA, BIJALI NAGAR AND ANCHAL NAGAR ETC
10	INDORE CITY	EAST	MAHALAXMI GIRD	11KV	MAHALAXMI & KHAJIRANA(R)	CHQ	18.08.2019	16:00:00	16:30:00	0:30:00	11KV MAIN NO.1 VCB TRIP TEST WORK BY STM.	SE CITY	AE (HTM)	NO.	YES	0.9		MAHALAXMI NAGAR, R-SECTOR, PIONEER COLLAGE,SAIKRUPA, RAMKRUSHAN BAG, YADAV SHOW ROOM AND MR-10 ETC.
11	INDORE CITY	EAST	TUKOGANJ GIRD	33KV	8MVA POWER X-MER NO.1	CHQ	18.08.2019	17:00:00	17:15:00	0:15:00	33KV VCB NO.1 SPRING CHARGING & INDICATION PROBLEM WORK BY STM.	SE CITY	AE (HTM)	YES.	YES	-		WILL BE SUPPLY CHANGEOVER AVALIBEL.
12	INDORE CITY	EAST	TUKOGANJ GIRD	33KV	5MVA POWER X-MER NO.2	CHQ	18.08.2019	17:35:00	17:45:00	0:10:00	33KV VCB NO.2 INDICATION PROBLEM WORK BY STM.	SE CITY	AE (HTM)	YES.	YES	-		WILL BE SUPPLY CHANGEOVER AVALIBEL.
13	INDORE CITY	EAST	TUKOGANJ GIRD	33KV	5MVA POWER X-MER NO.3	CHQ	18.08.2019	18:00:00	18:15:00	0:15:00	33KV VCB NO.3 SPRING CHARGING & INDICATION PROBLEM WORK BY STM.	SE CITY	AE (HTM)	YES.	YES	-		WILL BE SUPPLY CHANGEOVER AVALIBEL.
14	INDORE CITY	EAST	TUKOGANJ GIRD	11KV	NAYAPURA & TEL. ESSENTIAL	CHQ	18.08.2019	17:15:00	17:30:00	0:15:00	11KV VCB NO.1 SPRING CHARGING & INDICATION PROBLEM WORK BY STM.	SE CITY	AE (HTM)	NO.	YES	0.9		GHADIWALI MASJID, JAIL ROAD , PRASHANT HOTEL,BAL VINAY MANDIR SCHOOL, VIMAL VINAY BULIDING, YASHWANT COLONY AND CLUB ETC.
15	INDORE CITY	EAST	TUKOGANJ GIRD	11KV	SNEHLATAGANJ & MTH	CHQ	18.08.2019	17:45:00	18:00:00	0:15:00	11KV VCB NO.2 SPRING CHARGING & INDICATION PROBLEM WORK BY STM.	SE CITY	AE (HTM)	NO.	YES	0.8		SHASTRI BRIGE , RALWAY STATION, PALIKA PLAZA AND MTH BAZAR, RALWAY MAL GODAM AND PASHU CHIKITSALAY ETC
16	INDORE CITY	South Division	Palda Industrial	11 kv	Krishna pulses & R.D. Udyog Nagar	CHQ	18.08.2019	7:00:00	10:00:00	3:00:00	3 no. DTR installation and Conductor replacement work under IPDS Team at Industrial Areas	SE CITY	AE (HTM)	No	YES	1.5	PAPER DECLDED	Indusrrial area ,Udhyog nagar
17	INDORE CITY	Central	Rajmohalla	11 kv	Jawahar marg-1 & 2	CHQ	18.08.2019	8:00:00	11:00:00	3:00:00	Line Maintenance & Tree Cutting Work	SE CITY	AE (HTM)	No	YES	1	PAPER DECLDED	Jawahar marg main road, South Raj Mohalla, Biyabani, malganj, North Raj Mohalla, & Etc

18	INDORE CITY	Central	Rau	11 kv	Royal Park	CHQ	18.08.2019	10:30:00	11:00:00	0:30:00	Due to Shiv Sagar AB Switch Red Hot Work	SE CITY	AE (HTM)	No	YES	0.6		Shiv Sagar Colony, Royak Krishna, Royal park, Ht Conn, Colour Graphix, Sheel Graphix
19	INDORE CITY	North	33/11 kV MODERN	11 kv	11 kv B-1	CHQ	18.08.2019	10:00:00	10:30:00	0:30:00	for VCB testing by STM Team	SE CITY	AE (HTM)	No	YES	0.7		Sector F Industrial Area
20	INDORE CITY	North	33/11 kV MODERN	11 kv	11 kv Main no. 1	CHQ	18.08.2019	10:30:00	11:00:00	0:30:00	for VCB testing by STM Team	SE CITY	AE (HTM)	No	YES	0.9		11 kv B-1 & Rural
21	INDORE CITY	North	220 kv North Zone	33 kv	33 kv Zonal 1st	IX	18.08.2019	10:00:00	17:00:00	7:00:00	for Conductor Replacement work by STC Team	SE CITY	AE (HTM)	No	YES	1		14 no HT Consumer Affected
22	INDORE CITY	North	220 kv North Zone	33 kv	33 kv Sector C	IX	18.08.2019	10:00:00	17:00:00	7:00:00	for Conductor Replacement work by STC Team	SE CITY	AE (HTM)	yes	YES	-		only sector F area 21 ht consumer affected
23	INDORE CITY	North	33/11 kV Modern	11 kv	11 kv Choutha sansar	CHQ	18.08.2019	10:00:00	17:00:00	7:00:00	for Conductor Replacement work by STC Team	SE CITY	AE (HTM)	No	YES	0.8		Sector F Industrial Area
24	INDORE CITY	North	33/11 kV Modern	11 kv	11 kv Sector B-1	CHQ	18.08.2019	10:00:00	17:00:00	7:00:00	for Conductor Replacement work by STC Team	SE CITY	AE (HTM)	No	YES	0.6		Sector F Industrial Area
25	INDORE CITY	North	33/11 kV Sector F	11 kv	11 kv Zest Pharma	CHQ	18.08.2019	10:00:00	17:00:00	7:00:00	for Conductor Replacement work by STC Team	SE CITY	AE (HTM)	No	YES	0.6		Jesth Pharma, Sector Industria Area
26	INDORE CITY	North	33/11 kV Sector F	11 kv	11 kv MR-10	CHQ	18.08.2019	10:00:00	11:00:00	1:00:00	for STC Team work	SE CITY	AE (HTM)	No	YES	0.7		Industrial Area, Sector F
27	INDORE CITY	North	33/11 kV Modern	11 kv	11 kv Rural	CHQ	18.08.2019	10:00:00	17:00:00	7:00:00	for Conductor Replacement work by STC Team	SE CITY	AE (HTM)	No	YES	0.6		Maruti Nagar
28	INDORE CITY	North	33/11 kV Modern	11 kv	11 kv marimata	CHQ	18.08.2019	10:00:00	17:00:00	7:00:00	for Conductor Replacement work by STC Team	SE CITY	AE (HTM)	No	YES	0.7		Ganeshdham colony, Sanwer main road, Orient wire, JP Papers
29	INDORE CITY	North	33/11 kV sector E	11 kv	11 kv Sector B	CHQ	18.08.2019	10:00:00	17:00:00	7:00:00	for Conductor Replacement work by STC Team	SE CITY	AE (HTM)	No	YES	0.7		Sector B Industrial Area, Jai Prakash Industry
30	INDORE CITY	North	33/11 kV sector E	11 kv	11 kv Sagar Feeder	CHQ	18.08.2019	10:00:00	17:00:00	7:00:00	for Conductor Replacement work by STC Team	SE CITY	AE (HTM)	No	YES	0.8		Sagar Industry, Sector B & E
31	INDORE CITY	North	220 kv North Zone	33 kv	33 kv Zonal 2nd	IX	18.08.2019	10:00:00	17:00:00	7:00:00	for Conductor Replacement work by STC Team	SE CITY	AE (HTM)	No	YES	0.9		Modern Grid Affected
32	INDORE CITY	North	33/11 kV Sector F	11 kv	11 kv Sureme roll	CHQ	18.08.2019	10:00:00	17:00:00	7:00:00	for SAFETY PURPOSE STC work	SE CITY	AE (HTM)	No	YES	0.5		Jesth Pharma, Sector Industria Area
33	INDORE CITY	North	220/33kv mangaliya	33 kv	33 kv Satellite Feeder	CHQ	18.08.2019	11:00:00	11:20:00	0:20:00	TO JUMPER WORK FOR NEW COLONY CHARGING Singapore Green View	SE CITY	AE (HTM)	yes	YES	No		Singapore, Satellite
34	INDORE CITY	North	220/33kv NORTH ZONE	33 kv	RAMAPHASPET	CHQ	18.08.2019	10:00:00	11:00:00	1:00:00	for Conductor STRINGING work by STC Team	yes	YES	NO	YES			33/11 KV MAHAKAL, SEC, A S/S EFFECTED