

Subject: - Approval of planned Shutdown of 33/11 KV Sub station of STM Dn. Indore circle

Reference:-

Permit requisition from	Date	Period :- Between	From	To	Total Duration Hrs.
E.E. (STM)	26-05-2019		Mention Below		

• **Connected & Area Affected :-**

<b>1] Name of 33/11 KV S/s</b>	Sector- E
<b>Names of connected Feeder</b>	Sector- E1
<b>Date</b>	26.05.2019
<b>Time</b>	06:30 to 06:50 Total 00:20 Mint.
<b>Reason for Planned S/D</b>	For VCB not charge
<b>Number of Affected Feeder</b>	1 No.
<b>Names of connected Feeder</b>	33 kv I/C Ramaphaspeta at 33/11 kv Sector- E S/s
<b>Time</b>	07:00 to 07:20 Total 00:20 Mint.
<b>Reason for Planned S/D</b>	For VCB not trip on Fault
<b>Number of Affected Feeder</b>	2 No's
<b>Names of connected Feeder</b>	11 kv Rural Feeder From 33/11 kv Sector- E S/s
<b>Time</b>	07:30 to 07:50 Total 00:20 Mint.
<b>Reason for Planned S/D</b>	For VCB not trip on Fault
<b>Number of Affected Feeder</b>	1 No.

<b>2] Name of 33/11 KV S/s</b>	Press Complex
<b>Names of connected Feeder</b>	11 kv Shri Nagar
<b>Date</b>	26.05.2019
<b>Time</b>	09:30 to 09:50 Total 00:20 Mint.
<b>Reason for Planned S/D</b>	For VCB not trip on Fault
<b>Number of Affected Feeders</b>	1 No.
<b>Names of connected Feeder</b>	11 kv Anup Nagar Feeder From 33/11 kv Press Complex S/s
<b>Time</b>	10:00 to 10:30 Total 00:30 Mint.
<b>Reason for Planned S/D</b>	For VCB's Closing coil & pole repair work
<b>Number of Affected Feeder</b>	1 No.

<b>3] Name of 33/11 KV S/s</b>	Indira Complex
<b>Names of connected Feeder</b>	11 kv Main No.-I
<b>Date</b>	26.05.2019
<b>Time</b>	12:00 to 12:20 Total 00:20 Mint.
<b>Reason for Planned S/D</b>	For VCB's Y-Phase C.T. Replacement Work BY STM
<b>Number of Affected Feeders</b>	2 No's

<b>4] Name of 33/11 KV S/s</b>	Goyal Nagar
<b>Names of connected PTR</b>	5 MVA- I
<b>Date</b>	26.05.2019
<b>Time</b>	13:00 to 13:20 Total 00:20 Mint.
<b>Reason for Planned S/D</b>	For PTR Oil leakage repair Work BY STM
<b>Number of Affected Feeders</b>	3 No's



5] Name of 33/11 KV S/s	Paada Naka
Names of connected Feeder	11 KV Kohinoor
Date	26.05.2019
Time	14:00 to 14:30 Total 00:30 Hrs.
Reason for Planned S/D	For VCB not trip on Fault
Number of Affected Feeders	1 No.

6] Name of 33/11 KV S/s	Rau
Names of connected PTR	11 kv Pigdamber Feeder
Date	26.05.2019
Time	15:00 to 15:20 Total 00:20 Mint.
Reason for Planned S/D	For VCB's Panel Repair Work BY STM
Number of Affected Feeders	1 No

➤➤➤ As required please insert or delete tables as above.

Total No. 33 Feeders interrupted	Nil	Total No. 11 KV feeders interrupted	13 No's
Total No. 33/11 KV Substations interrupted	Nil	Total No. of Villages Affected	18 No's

- Forecasting of demand two days before the date of proposed shutdown :-

Affected MW	1.80
-------------	------

- Description of work in planned shutdown

Transco/MPPKVVCL	Description of works
Name of Dn. undertaking work.	
MPPKVVCL	Mention Above

➤➤➤ As required please insert or delete rows as above.

- If 33 KV feeder shutdown proposals are affecting other circle also, than the consent of concerned SE incharge of that circle has been taken: - \_\_\_\_\_ No \_\_\_\_\_ (mandatory).
- It has been ensured that :-
- The duration is reasonable for the work proposed.
- No VIP, Mass gathering, Function or any festival, administration/public related issue is involved in the area affected.
- Alternate arrangement for essential services has been taken care of/ managed during the proposed shutdown period and date.

Superintending Engineer  
City Circle MPPKVVCL Indore

Assistant Engineer (NDCC)  
City Circle MPPKVVCL Indore

Superintending Engineer (Operation)  
Executive Director (IR)  
Executive Director (Operation)



-: Note sheet:-

Subject: - Approval of planned Shutdown of 33/11 KV Sub station of STM Dn. Indore city circle

Reference:-

Permit requisition from	Date	Period :- Between	From	To	Total Duration in Hrs.
E.E. (STM)	27-05-2019 To 02-06-2019		Mention Below		

• Connected & Area Affected :-

<b>1] Name of 33/11 KV S/s</b>	Mahalaxmi Nagar
<b>Names of connected PTR</b>	8 MVA-I, II,III, 10 MVA-IV & 3.15 MVA- V
<b>Date</b>	27.05.2019
<b>Time</b>	06:00 to 08:30 Total 02:30 Hrs.
<b>Reason for Planned S/D</b>	For 33/11 KV S/s Pre Monsoon Maintenance Work BY STM
<b>Number of Affected Feeders</b>	3 No's

<b>2] Name of 33/11 KV S/s</b>	Sangam Nagar
<b>Names of connected PTR</b>	5 MVA-I, 8 MVA-II, 5 MVA-III & 5 MVA- IV
<b>Date</b>	28.05.2019
<b>Time</b>	06:00 to 08:00 Total 02:00 Hrs.
<b>Reason for Planned S/D</b>	For 33/11 KV S/s Pre Monsoon Maintenance Work BY STM
<b>Number of Affected Feeders</b>	2 No's

<b>3] Name of 33/11 KV S/s</b>	Rajmohalla
<b>Names of connected PTR</b>	5 MVA-I, 8 MVA-II, 5 MVA-III & 5 MVA- IV
<b>Date</b>	29.05.2019
<b>Time</b>	06:00 to 08:00 Total 02:00 Hrs.
<b>Reason for Planned S/D</b>	For 33/11 KV S/s Pre Monsoon Maintenance Work BY STM
<b>Number of Affected Feeders</b>	3 No's

<b>4] Name of 33/11 KV S/s</b>	Footikothi
<b>Names of connected PTR</b>	8 MVA-I & 5 MVA- II
<b>Date</b>	30.05.2019
<b>Time</b>	06:00 to 07:00 Total 01:00 Hrs.
<b>Reason for Planned S/D</b>	For 33/11 KV S/s Pre Monsoon Maintenance Work BY STM
<b>Number of Affected Feeders</b>	3 No's



5] Name of 33/11 KV S/s	Silver Spring- I
Names of connected PTR	5 MVA-I, 3.15 MVA-II & 10 MVA- III
Date	31.05.2019
Time	06:30 to 08:00 Total 01:30 Hrs.
Reason for Planned S/D	For 33/11 KV S/s Pre Monsoon Maintenance Work BY STM
Number of Affected Feeders	2 No's

6] Name of 33/11 KV S/s	Univercity
Names of connected PTR	5 MVA-I, 5 MVA-II & 5 MVA- III
Date	01.06.2019
Time	06:00 to 07:30 Total 01:30 Hrs.
Reason for Planned S/D	For 33/11 KV S/s Pre Monsoon Maintenance Work BY STM
Number of Affected Feeders	2 No's

7] Name of 33/11 KV S/s	K.E.H.
Names of connected PTR	8 MVA-I
Date	02.06.2019
Time	06:00 to 06:30 Total 00:30 Hrs.
Reason for Planned S/D	For 33/11 KV S/s Pre Monsoon Maintenance Work BY STM
Number of Affected Feeders	2 No's

8] Name of 33/11 KV S/s	Railway Reservation Counter
Names of connected PTR	8 MVA-I
Date	02.06.2019
Time	07:30 to 08:00 Total 00:30 Hrs.
Reason for Planned S/D	For 33/11 KV S/s Pre Monsoon Maintenance Work BY STM
Number of Affected Feeders	2 No's

**Note:-** Above PTR Maintenance will be done One by One, every 30 min. duration

➤➤➤ As required please insert or delete tables as above.

Total No. 33 Feeders interrupted	Nil	Total No. 11 KV feeders interrupted	19 No's
Total No. 33/11 KV Substations interrupted	8	Total No. of Villages Affected	22 No's

- Forecasting of demand two days before the date of proposed shutdown :-

Affected MW	1.95
-------------	------

- Description of work in planned shutdown

Transco/MPPKVCL	Description of works
-----------------	----------------------