

M.P.P.K.V.V. C.LTD. INDORE CIRCLE																
Planned shutdown																
S.No	Name of Circle	NAME OF DIVISION	Name of EHV S/s or 33/11 KV S/s	Line KV Capacity (33 or 11)	Name of 33 KV / 11 KV feeder	Group (for 33KV) / Category (for 11 KV)	Date of Planned Shutdown	Duration of		Total Duration	Reason for Planned Shutdown (Maintenance/Erection work/ FSP / Safety purpose etc.)	Shutdown Approved by -	Approval Granted to-	Alternate Supply Arrangements are available or not (Yes/No)	Demand in MW affected due to Shutdown.	Areas affected
								From	to							
1	INDORE CITY	South Division	Palda Industrial	11 kv	Vinayak	CHQ	07.04.2019	07:00:00	07:30:00	00:30:00	11 kv Line Extension work for M/S. Swastik agencies	SE CITY	AE(Maint.)	No	0.79	11 kv Vinayak feeder
2	INDORE CITY	South Division	Varun Victory	11 kv	Main no. 1	CHQ	07.04.2019	15:30:00	15:45:00	00:15:00	11 kv Main no Tripping test work by STM	SE CITY	AE(Maint.)	No	0.85	11 kv Varun victory colony & feeder no.1, 2
3	INDORE CITY	North	33/11 KV SECTOR E	11 KV	11 KV RURAL	CHQ	07.04.2019	14:00:00	14:15:00	00:15:00	FOR VCB WORK BY STM TEAM	SE CITY	AE(Maint.)	NO	0.5	Areas affected
4	INDORE CITY	North	33/11 KV SECTOR E	33 KV	33 KV RAMAPHASPHET I/C	CHQ	07.04.2019	14:15:00	14:30:00	00:15:00	FOR VCB WORK BY STM TEAM	SE CITY	AE(Maint.)	NO	0.65	Areas affected
5	INDORE CITY	North	132 KV ELECTRONIC COM	33 KV	33 KV NAGAR NIGAM	CHQ	07.04.2019	06:00	06:15	00:15	FOR JUMPER CONNECTED WORK VERY ARGENT PLANNED	SE CITY	AE(Maint.)	NO		ONLY HT CONSUMER & SHALIWAR SWAM