

M.P.P.K.V.V. C. LTD. INDORE CIRCLE																		
	Planned shutdown DATE- 14.08.2019																	
S.N o	Name of Circle	NAME OF DIVISION	Name of EHV S/s or 33/11 KV S/s	Line KV Capacity (33 or 11)	Name of 33 KV / 11 KV feeder	Group (for 33KV) / Category (for 11 KV)	Date of Planned Shutdown	Duration of Planned Shutdown		Total Duratio n	Reason for Planned Shutdown (Maintenance/Erection work/ FSP / Safety purpose etc.)	Shutdown Approved by -	Approval Granted to-	Alternate Supply Arrangements are available or not (Yes/No)	It has been Reported on Whatsapp Group	Demand in MW affected due to Shutdown.	Remark(Areas affected)	Remark(Areas affected)
								From	to									
1	INDORE CITY	WEST	Kila Maidan	11 KV	Chhatrapati	CHQ	14.08.2019	8:00	11:00	3:00	6 Span Conductor Stringing & 1 no. DTR Augmentation Work near BSF Area Under IPDS	SE CITY	AE (HTM)	NO	YES	0.86		Agrasen Nagar & Chhatrapati
2	INDORE CITY	WEST	Sangam Nagar	11 KV	Subhash Marg-I	CHQ	14.08.2019	9:30	10:30	1:00	Safety Purpose work on 11 kv Chhatrapati feeder Due to Double Circle	SE CITY	AE (HTM)	NO	YES	0.56	Paper Declared	Subhash Marg-I
3	INDORE CITY	WEST	AIRPORT	11 KV	BSF	CHQ	14.08.2019	8:00	11:00	3:00	1 no. DTR Augmentation work Near Kandlipura Area Under IPDS	SE CITY	AE (HTM)	NO	YES	0.98		Kalani Chouraha & BSF Area
4	INDORE CITY	WEST	Sector-A	11 KV	Sector-A	CHQ	14.08.2019	5:30	6:00	0:30	1 No. M.E.'s Spark Jumper Repair work Near Sector-A Agarbatti Complex of H.T. Consumer (Mahalaxmi Plastic)	SE CITY	AE (HTM)	NO	YES	0.45	-	Sector-A Area
5	INDORE CITY	WEST	Zinsi	11 KV	Loharpatti	CHQ	14.08.2019	7:00	8:00	1:00	200 KVA Failed DTR Replacement work Near Naveen Takies	SE CITY	AE (HTM)	NO	YES	0.68	-	Loharpatti
6	INDORE CITY	WEST	Zinsi	11 KV	Kilagate	CHQ	14.08.2019	11:00	12:00	1:00	2 No's DTR Maintenance work Near 15 Bataliyan Due to Independence Day	SE CITY	AE (HTM)	NO	YES	0.94	-	Kilagate
7	INDORE CITY	WEST	Gandhi Nagar	11 KV	Budhaniya	CHQ	14.08.2019	13:00	14:00	1:00	200 KVA failed DTR Replacement work Near Nandan Bag	SE CITY	AE (HTM)	NO	YES	0.75	-	Budhaniya
8	INDORE CITY	WEST	City Control Room	11 KV	Pologround-II	CHQ	14.08.2019	8:00	8:30	0:30	11 kv Feeder VCB Repair work By STM	SE CITY	AE (HTM)	NO	YES	0.46	-	Pologround
9	INDORE CITY	North	Shilnath	11 kv	Shivaji nagar	CHQ	14.08.2019	7:00	10:00	3:00	Line Maintenance, Isolator Replacement by A.E. HTM & 1No. DTR Charging work by STC	SE CITY	AE (HTM)	NO	YES	0.56	-	Shivaji nagar, Jeevan ki fel, Sigma school,
10	INDORE CITY	North	Shilnath	11 kv	11 kv Main no 1	CHQ	14.08.2019	6:45	7:00	0:15	11 KV Main Isolator Disconnect Due to work on 11 kv Shivaji Nagar Feeder	SE CITY	AE (HTM)	NO	YES	0.7	-	11 kv Shivaji Nagar & Shivshakti nagar & Kulkarni Bhatta & Over Bridge
11	INDORE CITY	North	Shilnath	11 kv	11 kv Main no 1	CHQ	14.08.2019	10:00	10:15	0:15	11 KV Main Isolator Connect After work Complete on 11 kv Shivaji Nagar feeder	SE CITY	AE (HTM)	NO	YES	0.4	-	11 kv Shivaji Nagar & Shivshakti nagar & Kulkarni Bhatta & Over Bridge
12	INDORE CITY	North	L.I.G.	11 kv	Old Palasiya	CHQ	14.08.2019	7:00	7:30	0:30	for Pole Erection work new HT Consumer m/s panchulal agrawal chartiable trust	SE CITY	AE (HTM)	NO	YES	0.35	-	Shopping complex, Industry house, Onam Plaza, Sanjivni nursingh home, Hotel Amaltas, RK Puram colony, sanjay upvan, Dev nagar,
13	INDORE CITY	North	220 north zone	33 kv	33 kv Vijay Nagar No. 1&2	VIII	14.08.2019	7:30	8:00	0:30	for cable kit sparking so Connection Disconnected work of HT Consumer Ino Flex	SE CITY	AE (HTM)	NO	YES			1 no HT Consumer Affected
14	INDORE CITY	North	MPSRTC	11 kv	11 kv Main no. 1	CHQ	14.08.2019	6:00	6:30	0:30	Due to R-Phase VCB's C.T. Jumper Red hot work at S/s	SE CITY	AE (HTM)	NO	YES	0.9		11 kv kalali & palasiya
15	INDORE CITY	North	Modern	11 kv	11 kv Main no 3	CHQ	14.08.2019	6:00	6:30	0:30	Due to R-Phase VCB's C.T. Jumper Red hot work at S/s	SE CITY	AE (HTM)	NO	YES	0.67		11 kv C-1
16	INDORE CITY	North	Scheme No. 114	11 kv	Lal Banglow	CHQ	14.08.2019	10:00	12:00	2:00	1 No. DTR Charging Work near Sch.No. 114 By STC Team	SE CITY	AE (HTM)	NO	YES	0.84		Lal Banglow
17	INDORE CITY	Central	Pragati nagar	11 kv	11 kv Main no 2	CHQ	14.08.2019	17:00	17:30	0:30	Due to VCB's C.T. Testing Work by STM	SE CITY	AE (HTM)	NO	YES	0.45		11 KV parmanu nagar, Sudama nagar, pragati nagar, Buddha nagar, D Mart-Sch no 135 Affected
18	INDORE CITY	Central	Annapurna	11 kv	Paraspar nagar	CHQ	14.08.2019	8:00	11:00	3:00	5 Span conductor stringing work at Gopur Chouraha Under IPDS	SE CITY	AE (HTM)	NO	YES	0.75	Paper Declared	Pricanco Colony, Sah Jivan nagar, Chankya Puri Square, Sudama nagar & ETC
19	INDORE CITY	Central	Pragati nagar	11 kv	Siddhipuram	CHQ	14.08.2019	8:00	11:00	3:00	Safety Purpose work on 11 kv Paraspar nagar feeder Due to Line Crossing	SE CITY	AE (HTM)	NO	YES	0.39	Paper Declared	Vaishali Mnagar, Ahilya nagar, Grater vaishali nagar Siddhipuram & ETC
20	INDORE CITY	Central	Pragati nagar	11 kv	Sudama nagar	CHQ	14.08.2019	9:00	10:00	1:00	11 kv Feeder Broken Gaurding Repair work Near Reti Mandi	SE CITY	AE (HTM)	NO	YES	0.45		Surya Dev nagar, Satyadev nagar, Sudama nagar & ETC
21	INDORE CITY	Central	Gumasta nagar	11 kv	Sirpur	CHQ	14.08.2019	8:00	11:00	3:00	Due to 2 No's Pole Erection & 1 No. DTR renovation work Near Noorani Nagar Under IPDS	SE CITY	AE (HTM)	NO	YES	0.6	Paper Declared	Noorani nagar, Green park, Ambar nagar & ETC
22	INDORE CITY	Central	Rau	11 kv	Rau-2 & rangwasa	CHQ	14.08.2019	8:00	11:00	3:00	5 Span Guarding Work Near Cancer Hospital Under IPDS & 3 Span Conductor stringing at Sanjna Park Colony Under 5% Supervision	SE CITY	AE (HTM)	NO	YES	0.56	Paper Declared	Rau Shramik Colony, Saria Ward, Swastik Vihar Kanha Park, Cancer Hospital Shyam Sangam & ETC

23	INDORE CITY	Central	Bijalpur	11 kv	Sanjay nagar & Shivcity	CHQ	14.08.2019	11:30	12:00	0:30	Due to Tree Cutting Work Against CM Help Line Complaint	SE CITY	AE (HTM)	NO	YES	0.6		Sanjay nagar, Shiv City Colony, Gram Bijalpur & ETC
24	INDORE CITY	Central	Rajmohalla	33 kv	Rajmohalla-1	VII	14.08.2019	6:00	6:20	0:20	Due to 33 KB AB Switch Jumper Red Hot Work at grid	SE CITY	AE (HTM)	Yes	YES	-		no Area Affected
25	INDORE CITY	Central	Rajendra nagar	11 kv	11 kv Main no 1 & 2	CHQ	14.08.2019	6:30	7:00	0:30	Due to Basbar Jumper Red hot Work at grid	SE CITY	AE (HTM)	NO	YES	0.56		Annapurana , Sukhniwas, AIR & Vaishali
26	INDORE CITY	Central	Footi Kothi	11 kv	11 kv Main no 1	CHQ	14.08.2019	5:30	5:45	0:15	Due to VCB's Pole Jumper Red hot Work at Grid	SE CITY	AE (HTM)	NO	YES	0.48		11 KV Ahirkhedi, Footi Kothi, Vidur nagar Affected
27	INDORE CITY	South	Palda industrial	11 kv	Kalindi feeder	CHQ	14.08.2019	7:00	10:00	3:00	5 no. Pole Erection work & 4 Span Conductor stringing work At By pass road by Kshama Power Under IPDS	SE CITY	AE (HTM)	No	YES	1.62	Paper Declared	udhyog nagar ,by pass roadarea
28	INDORE CITY	South	Mehhanic Nagar	11 kv	Aditya Nagar	CHQ	14.08.2019	7:00	10:00	3:00	3 Span conductor stringing work at Aditya nagar area by Kshama Power Under IPDS	SE CITY	AE (HTM)	No	YES	1.25	Paper Declared	ADITYA NAGAR ,MECHANIC NAGAR , GURUDWARA , D MIGRO .
29	INDORE CITY	South	Sabji mandi	11 kv	Main no. 3	CHQ	14.08.2019	6:30	7:00	0:30	11 kv main no.3 R-phase O/G Isolator clamp red hot work	SE CITY	AE (HTM)	No	YES	0.69		Bijalpur Chouraha, Kesharbag Road ,Tata Tower , Amitesh Nagar, Atg Appt Amitesh Ngar,
30	INDORE CITY	South	Mechanic Nagar	11 kv	Main no. 1	CHQ	14.08.2019	7:00	7:30	0:30	11 kv Isolator Male-Female contact replacement & Red hot work at S/s	SE CITY	AE (HTM)	No	YES	0.84		11 kv Aditya nagar & Sidharth Nagar feeder or related Area
31	INDORE CITY	South	Sabji mandi	11 kv	Manik bagh	CHQ	14.08.2019	8:00	9:00	1:00	2 no. DTR Charging work by STC at Manik bag Area	SE CITY	AE (HTM)	No	YES	0.85		Shefi nagar,manik bag chouraha, baribag coony, ashok colony, malik nursing.viay palace
32	INDORE CITY	EAST	220KV-B.MARDANA	33KV	VANDANA NAGAR - I	CHQ	14.08.2019	6:30	7:30	1:00	Due to VCB's C.T. Replacement work at S/s	SE CITY	AE (HTM)	YES.	YES	-		WILL BE SUPPLY CHANGEOVER AVAILABLE.
33	INDORE CITY	EAST	220KV-B.MARDANA	33KV	VANDANA NAGAR - II (O/G)	CHQ	14.08.2019	9:30	10:00	0:30	Due to VCB's C.T. Replacement work at S/s	SE CITY	AE (HTM)	YES.	YES	-		WILL BE SUPPLY CHANGEOVER AVAILABLE.
34	INDORE CITY	EAST	MANORAMAGANJ	11KV	KC2	CHQ	14.08.2019	9:00	9:30	0:30	Due VCB ON/OFF Problem work from CRP BY STM	SE CITY	AE (HTM)	NO.	YES	0.45		NAVRATAN,WHITECHARCH, DHAR KOTHI SENT REPHEL SCHOOL AND MY HOSPITAL ETC.
35	INDORE CITY	EAST	MANORAMAGANJ	11KV	KANCHANBAGH	CHQ	14.08.2019	9:30	10:00	0:30	11KV Main No.4 Spring charging work by STM	SE CITY	AE (HTM)	NO.	YES	0.68		KANCHANBAG, APPLO TOWER, INDRAPRASTH TOWER M.G. ROAD AND SOUTH TUKOGANJ ETC.
36	INDORE CITY	EAST	BTC	11KV	BASKET BALL	CHQ	14.08.2019	10:30	11:00	0:30	Due to VCB's C.T. Replacement work at S/s By STM	SE CITY	AE (HTM)	NO.	YES	0.75		AGRAWAL STORE, DM TOWER, CARE WELL HOSPITAL AND VIKAS PRADHIKARN ETC
37	INDORE CITY	EAST	OPH	11KV	CHAWANI & DAULATGANJ.	CHQ	14.08.2019	16:00	16:30	0:30	11KV Main No.1 Spring charging work by STM	SE CITY	AE (HTM)	NO.	YES	0.94		CHAWANI & DAULATGANJ.
38	INDORE CITY	EAST	SC.NO.134	33KV	SANCHAR NAGAR - II (INCOMMING FEEDER)	CHQ	14.08.2019	12:00	12:30	0:30	Due VCB ON/OFF Problem work from CRP BY STM	SE CITY	AE (HTM)	YES.	YES	-		WILL BE SUPPLY CHANGEOVER AVAILABLE.