|   | M.P.P.K.V.V. C. LTD. INDORE CIRCLE  Planned shutdown DATE-27.07.2019 |                   |                            |          |                       |                  |            |       |         |         |   |                      |                  |                  |              |                 |                   |   |
|---|--|-------------------|----------------------------|----------|-----------------------|------------------|------------|-------|---------|---------|---|----------------------|------------------|------------------|--------------|-----------------|-------------------|---|
| S.N Name of NAME OF Name of EHV S/s Line KV Name of 33 KV / Group (for 33 KV) / Date of Planned 1 |  |                   |                            |          |                       |                  |            |       | tion of | Total   | ATE- 27.07.2019 Reason for Planned Shutdown   | Approval             | Alternate Supply | It has been      | Demand in MW | Remark(Area     |                   |   |
| 0   | Circle   | DIVISION          | or 33/11 KV S/s            | Capacity | 11 KV feeder          | Category (for 11 | Shutdown   | From  | to      | Duratio | (Maintenance/Erection work/ FSP / Safety  | Shutdown<br>Approved | Granted to-      | Arrangements are | Reported on  | affected due to | s affected)       | Remark(Areas affected)  |
| 1   | INDORE<br>CITY   | WEST              | ZINSI HAT                  | 11 kv    | 5 MVA PTR NO<br>3     | СНО              | 27.07.2019 | 05:45 | 06:00   | 00:15   | FOR OUTGOING ISOLATOR Y- PHASE CLAMP RED HOT.   | SE CITY              | AE(Maint.)       | NO               | Yes          | 0.65            |                   | 11KV LOHARPATTI-1 & 2   |
| 2   | INDORE<br>CITY   | WEST              | GANDHI<br>NAGAR            | 11 kv    | DENTAL                | СНО              | 27.07.2019 | 07:00 | 10:00   | 03:00   | 2No. A.B. SWITCH INSTALLATION & 10<br>SPAN GAURDING WORK NEAR DENTAL<br>COLLAGE UNDER IPDS                                    | SE CITY              | AE(Maint.)       | NO               | Yes          | 0.8             | PAPER<br>DECLARED | DENTAL COLLEGE AND RELATED KSHETRA.   |
| 3   | INDORE<br>CITY   | WEST              | GANDHI<br>NAGAR            | 11 kv    | GANDHI NAGAR          | CHQ              | 27.07.2019 | 07:00 | 10:00   | 03:00   | 10 SPAN CONDUCTOR STRINGING WORK<br>NEAR BOHARA COLONEY UNDER IPDS  | SE CITY              | AE(Maint.)       | NO               | Yes          | 0.95            | PAPER<br>DECLARED | Gandhi Nagar, Bora Colony, Sant Marg, Parasram<br>Road, E Special, Unkar Road, Mangal Road,<br>Panchayat Khsetra, Muslim Colony.                |
| 4   | INDORE<br>CITY   | WEST              | SANGAM<br>NAGAR            | 11 kv    | IDA-51                | СНО              | 27.07.2019 | 07:00 | 10:00   | 03:00   | 1 NO. DTR AUG. AT LATUR BAG UNDER<br>IPDS   | SE CITY              | AE(Maint.)       | NO               | Yes          | 0.85            | PAPER<br>DECLARED | MORDEN MALTI, GANGA BAAG CHOURAHA, 51<br>NO. SHKEME, LATURE BAAG, GANESH BAAG AND<br>RELATED KSHETRA.   |
| 5   | INDORE<br>CITY   | South<br>Division | Mount barg                 | 11 kv    | Nayta Mundla          | СНО              | 27.07.2019 | 07:00 | 10:00   | 03:00   | 2 NO. 11 KV LINE POLE ERECTION WORK<br>WORK AT AT NAYTA MUNDLA BY<br>KSHAMA POWER UNDER IPDS                                  | SE CITY              | AE(Maint.)       | NO               | Yes          | 0.75            | PAPER<br>DECLARED | Nayta Mundla feeder   |
| 6   | INDORE<br>CITY   | South<br>Division | Palda<br>Industrial        | 11 kv    | R.D. Udyog<br>Nagar   | СНО              | 27.07.2019 | 07:00 | 10:00   | 03:00   | 2 NO. 11 KV LINE POLE ERECTION WORK<br>WORK AT PALDA INDUSTRIAL AREA BY<br>KSHAMA POWER UNDER IPDS                            | SE CITY              | AE(Maint.)       | NO               | Yes          | 0.65            | PAPER<br>DECLARED | 11 kv R.D. Udyog Nagar Feeder   |
| 7   | INDORE<br>CITY   | South<br>Division | University                 | 11 kv    | Vishnupri             | СНО              | 27.07.2019 | 10:00 | 10:30   | 00:30   | 200 KVA FAILED DTR REPLACEMENT WORK<br>AT ASHOK NAGAR   | SE CITY              | AE(Maint.)       | NO               | Yes          | 0.8             |                   | Dasmesh dwar,jabran colony , juni indore thana,   |
| 8   | INDORE<br>CITY   | Central           | Rajendra<br>Nagar          | 11 kv    | Annapurna             | СНО              | 27.07.2019 | 07:00 | 10:00   | 03:00   | TREE CUTTING & LINE MAINTENANCE<br>WORK   | SE CITY              | AE(Maint.)       | NO               | Yes          | 0.85            | PAPER<br>DECLARED | Takshila Parisar, Woman Polotecnic Collage,<br>Dhanwantri Nagar, rajendra nagar & ETC   |
| 9   | INDORE<br>CITY   | Central           | Gumasta<br>nagar           | 11 kv    | Sirpur & Dhar<br>Road | СНО              | 27.07.2019 | 07:00 | 10:00   | 03:00   | 6 SPAN CONDUCTOR STRAGING & 1 NO.<br>NEW DTR CHARGING WORK NEAR<br>NOORANI NAGAR TO GARIB NAWAZ<br>COLONY UNDER IPDS          | SE CITY              | AE(Maint.)       | NO               | Yes          | 0.7             | PAPER<br>DECLARED | Nooarni nagar, Green park Ambar nagar, Chandan<br>nagar, Sirpur, Chandan Nagar Square, Aam Wala<br>road, Loha Wala Gate, Chandu Wala Road & ETC |
| 10  | INDORE<br>CITY   | Central           | Pragati Nagar              | 11 kv    | Pragati nagar         | СНО              | 27.07.2019 | 07:00 | 10:00   | 03:00   | 2 NO. DTR AUGMANTATION &<br>RENOVATION WORK NEAR KRASHNA<br>NAGAR WORK UNDER IPDS   | SE CITY              | AE(Maint.)       | NO               | Yes          | 0.8             | PAPER<br>DECLARED | Pragati nagar, Krishna nagar, Tiwari Nagar,<br>Rajendra nagar, P[arashar nagar & ETC  |
| 11  | INDORE<br>CITY   | Central           | Pragati Nagar              | 11 kv    | Buddha Nagar          | СНО              | 27.07.2019 | 07:00 | 09:00   | 02:00   | Due to LT Cable Stringing Work at<br>Buddha nagar & kundan NagarFor Sefety<br>Purpose   | SE CITY              | AE(Maint.)       | NO               | Yes          | 0.5             |                   | Buddha nagar CAT Road, mamta nagar, Kundan<br>nagar, & ETC  |
| 12  | INDORE<br>CITY   | Central           | Rau                        | 11 kv    | Rau-1                 | CHQ              | 27.07.2019 | 07:00 | 07:30   | 00:30   | Jumper outage for pole erection work at<br>hasanji nager sc D by STC  | SE CITY              | AE(Maint.)       | NO               | Yes          | 0.35            |                   | Rau, Shramik colony   |
| 13  | INDORE<br>CITY   | Central           | Rau                        | 11 kv    | Rau-1                 | CHQ              | 27.07.2019 | 10:00 | 10:15   | 00:15   | jumper close After work   | SE CITY              | AE(Maint.)       | NO               | Yes          | 0.2             |                   | Rau, Shramik colony   |
| 14  | INDORE<br>CITY   | Central           | Annapurna                  | 11 kv    | Bhawanipur            | СНО              | 27.07.2019 | 07:00 | 10:00   | 03:00   | 1 DTR CHARGINING AND 2 SPAN CONDUCTOR<br>STRINING WORK NEAR POOJA HOSPITAL<br>SHRI RAM VATIKA SUDAM NAGAR UNDER<br>IPDS       | SE CITY              | AE(Maint.)       | NO               | Yes          | 0.5             | PAPER<br>DECLARED | Bhawnipur. Pooja Hospital, Shri Ram vatika,<br>Annapurna road, Mishra nagar, Annapurna nagar,<br>& ETC  |
| 15  | NDORE<br>CITY  | Central           | Annapurna                  | 11 kv    | Dashara maidan        | CHQ              | 27.07.2019 | 07:00 | 10:00   | 03:00   | DOUBLE CKT WITH 11 KV BHAWANIPUR  | SE CITY              | AE(Maint.)       | NO               | Yes          | 0.85            | PAPER<br>DECLARED | Dahara Maidan, Annapurna Road, Kanti Kaplani<br>nagar, Jai Jagat Colony, Jhulal Mandir & Etc  |
| 16  | Indore<br>city   | Central           | Footi Kothi                | 11 kv    | Vidur Nagar           | СНО              | 27.07.2019 | 10:00 | 10:30   | 00:30   | DUE TO VCB TASTING WORK BY STM  | SE CITY              | AE(Maint.)       | NO               | Yes          | 0.45            |                   | vidur nagar area  |
| 17  | INDORE<br>CITY   | Central           | Rau                        | 11 kv    | Pigdamber<br>Rural    | CHQ              | 27.07.2019 | 11:00 | 11:30   | 00:30   | DUE TO VCB TASTING WORK BY STM  | SE CITY              | AE(Maint.)       | NO               | Yes          | 0.45            |                   | Near rau Grid, Kamal nagar, Satya Sai nagar, mama<br>ji ka Dhaba  |
| 18  | City<br>Indore   | North             | 33/11 kv<br>Khatipura      | 11 kv    | 11 kv main            | CHQ              | 27.07.2019 | 06:30 | 06:45   | 00:15   | FOR ISOLATOR RED HOT WORK   | SE CITY              | AE(Maint.)       | NO               | Yes          | 0.4             |                   | 11 kv khatipura & Agrawal com & sector D  |
| 19  | City<br>Indore   | North             | 33/11 kv<br>MPSRTC         | 11 kv    | 11 kv main no. 2      | CHQ              | 27.07.2019 | 07:40 | 08:00   | 00:20   | B-PHASE I/C ISOLATOR RED HOT WORK<br>OF 11 KV MAIN NO. 2  | SE CITY              | AE(Maint.)       | NO               | Yes          | 0.5             |                   | 11 kv Shopping Com & machenic nagar & ITI   |
| 20  | City<br>Indore   | North             | 33/11 kv<br>Shilnath       | 11 kv    | 11 kv main            | СНО              | 27.07.2019 | 06:45 | 07:15   | 00:30   | FOR R-PHASE I/C ISOLATOR RED HOT OF<br>11 KV KULKARNI BHATTA & Y-PHASE<br>I/C ISOLATOR & CT RED HOT OF 11 KV<br>SHIVAJI NAGAR | SE CITY              | AE(Maint.)       | NO               | Yes          | 0.65            |                   | 11 kv Shivshakti nagar & shivaji nagar & over<br>Bridge & kulkarni bhatta   |
| 21  | City<br>Indore   | North             | 33/11 kv<br>electronic com | 11 kv    | 11 kv EC- 2           | СНО              | 27.07.2019 | 06:00 | 06:30   | 00:30   | FOR ISOLETOR RED HOT WORK   | SE CITY              | AE(Maint.)       | NO               | Yes          | 0.5             |                   | Electronic complex parisar  |
| 22  | City<br>Indore   | North             | 33/11 kv<br>kabit Khedi    | 11 kv    | 11 kv Shayam<br>nagar | СНО              | 27.07.2019 | 05:30 | 05:45   | 00:15   | FOR 11KV CT RED HOT WORK  | SE CITY              | AE(Maint.)       | NO               | Yes          | 0.45            |                   | Shyam Nagar, MR-10 Road, Lavkush vihar, Jineshwar<br>School, Sabri nagar sabji mandi, Bandhan Garden  |
| 23  | NDORE<br>CITY  | North             | 33/11 kv<br>sector E       | 11 kv    | 11 kv E- 1            | СНО              | 27.07.2019 |       |         |         | LINE MAINTENANCE & TREE CUTTING<br>WORK   | SE CITY              | AE(Maint.)       | NO               | Yes          | 0.5             | PAPER<br>DECLARED | Sector E & shivlkanth Nagar   |
| 24  | NDORE  | EAST              | SANJNA PARK                | 11KV     | SANJNA PARK           | CHQ              | 27.07.2019 | 07:00 | 07:30   | 00:30   | FOR CT RED HOT ATTEND WORK  | SE CITY              | AE(Maint.)       | NO               | Yes          | 0.4             |                   | SANJANA PARK COMLETLY   |
| 25  | INDORE<br>CITY   | EAST              | SC.NO.140<br>TANKI WALA    | 11KV     | SAMPAT FARM           | CHQ              | 27.07.2019 | 07:30 | 08:00   | 00:30   | FOR CT RED HOT ATTEND WORK  | SE CITY              | AE(Maint.)       | NO               | Yes          | 0.25            |                   | JAIN COLLAGE, DHAGA FACTORY, BHURI TEKARI AND<br>BLU WATER PARK ETC.  |
| 26  | INDORE<br>CITY   | EAST              | KHAJRANA                   | 11KV     | CHANDRALOK            | CHQ              | 27.07.2019 | 08:00 | 08:30   | 00:30   | FOR ISOLATOR RED HOT ATTEND WORK.   | SE CITY              | AE(Maint.)       | NO               | Yes          | 0.45            |                   | SAKET NAGAR , CLASSIC PURNIMA, SUNIKET AND<br>RAVI NAGAR  |