

M.P.P.K.V.V. C. LTD. INDORE CIRCLE																
Planned shutdown																
S.No	Name of Circle	NAME OF DIVISION	Name of EHV S/s or 33/11 KV S/s	Line KV Capacity (33 or 11)	Name of 33 KV / 11 KV feeder	Group (for 33KV) / Category (for 11 KV)	Date of Planned Shutdown	Duration of		Total Duration	Reason for Planned Shutdown (Maintenance/Erection work/ FSP / Safety purpose etc.)	Shutdown Approved by -	Approval Granted to-	Alternate Supply Arrangements are available or not (Yes/No)	Demand in MW affected due to Shutdown.	Areas affected
1	INDORE CITY	South Division	220 kv south zone	33 kv	Kanadiya	CHQ	05.04.2019	7:00:00	7:15:00	0:15:00	33 kv feeder Clamp red hot work at Varun Victory Grid	SE CITY	AE(Maint.)	Yes	Nil	Nil
2	INDORE CITY	South Division	Palda industrial	11 kv	Nayta Mundla	CHQ	05.04.2019	7:15:00	7:30:00	0:15:00	Due to 11 kv feeder Revers & PTR Charging work	SE CITY	AE(Maint.)	No	0.58	Nayta Mundla Feeder
3	INDORE CITY	South Division	Mount barg	11 kv	Nayta Mundla	CHQ	05.04.2019	7:15:00	7:30:00	0:15:00	Due to 11 kv feeder Revers & PTR Charging work	SE CITY	AE(Maint.)	No	0.67	Nayta Mundla Feeder
4	INDORE CITY	South Division	Khatiwala Tank	11 kv	Bairathi Colony	CHQ	05.04.2019	9:30:00	10:00:00	0:30:00	Failed DTR Replacement work	SE CITY	AE(Maint.)	No	0.82	Simran Palace,413,Khaiwola Tank,3/1 Prem Nagar,Manik Bag,
5	INDORE CITY	Central	Footi Kothi	11kV	MAIN NO 1	CHQ	05.04.2019	15:00:00	15:15:00	0:15:00	Due to VCB tasting Work by STM	SE CITY	AE(Maint.)	NO	1	11 KV Vidur nagar, Footi kothi, &Ahirkhedli Affected
6	INDORE CITY	Central	Footi Kothi	11kV	MAIN NO 2	CHQ	05.04.2019	15:30:00	15:45:00	0:15:00	Due to VCB tasting Work by STM	SE CITY	AE(Maint.)	NO	1.2	11 KV Prajapat nagar, Parvohan nagar, Goralu Colony,Affected
7	INDORE CITY	Central	Pragati Nagar	11kV	Pragati nagar	CHQ	05.04.2019	14:00:00	14:15:00	0:15:00	Due to VCB tasting Work by STM	SE CITY	AE(Maint.)	NO	0.6	Pragati Nagar, Krishna nagar,Jawahar nagar, parashar nagar,Tiwari nagar, Rajendra nagar
8	INDORE CITY	Central	Pragati Nagar	11kV	Buddha nagar	CHQ	05.04.2019	10:30:00	11:00:00	0:30:00	Due to Fail DTR Replacement Work	SE CITY	AE(Maint.)	NO	0.75	Buddha nagar, CAT Road, mamta Nagar,Kundan nagar, & ETC
9	INDORE CITY	Central	Annapurna	11kV	Paraspar nagar	CHQ	05.04.2019	13:00:00	13:15:00	0:15:00	Due to VCB tasting Work by STM	SE CITY	AE(Maint.)	NO	0.75	Pricanco Colony, Sudama nagar, Gopur Square, Paraspar nagar, Sahjivan Nagar, & ETC
10	INDORE CITY	Central	Rau	11kV	Rangwasa	CHQ	05.04.2019	14:00	14:15	00:15	Due to ME Tasting Work At Ht Conn. Sanjana Cold Storage	SE CITY	AE(Maint.)	NO	0.6MW	Area affected Releted to this Feeder
11	INDORE CITY	Central	Footi Kothi	11	Prajapat nagar	CHQ	05.04.2019	10:00	10:15	00:15	Due to DTR jumper Work at IPDS Project	SE CITY	AE(Maint.)	NO	0.6MW	NA Area Affected Releted to this Feeder
12	INDORE CITY	EAST	GOYAL NGR.	11KV	GOYAL VIHAR.	CHQ	05.04.2019	10:30:00	10:45:00	0:15:00	FOR POLE ERECTION WORK BY IPDS.	SE CITY	AE(Maint.)	NO	0.9	RADHA KRUSHAN COLONY , MAHARASHTRA BANK, SHAHNAI 2 AND PREM BANGHAN GARDEN ETC.
13	INDORE CITY	EAST	SATYA SAI	11KV	MEGHDOOT	CHQ	05.04.2019	11:00:00	11:20:00	0:20:00	FOR X-MER CHARGING WORK BY IPDS	SE CITY	AE(Maint.)	NO	0.65	ADARSH MEGHDOOT NAGAR, MR-9 SOLANKI NAGAR , SHRDHA SHRI AND PRIYADARSHINI COLONY ETC.
14	INDORE CITY	EAST	MAHALAXMI	33KV	BMVA POWER X-MER NO.1	CHQ	05.04.2019	16:30:00	16:45:00	0:15:00	BMVA POWER X-MER NO.1 CRP ON & OFF PROBELM WORK BY STM.	SE CITY	AE(Maint.)	NO	1.5	KHAJRANA(R) & MAHALAXMI
15	INDORE CITY	EAST	MAHALAXMI	33KV	3.15 MVA POWER X-MER NO.5	CHQ	05.04.2019	16:45:00	17:00:00	0:15:00	3.15 MVA POWER X-MER NO.5 CRP ON & OFF PROBELM WORK BY STM.	SE CITY	AE(Maint.)	NO	1	UPTOWN APOLLO
16	INDORE CITY	EAST	MAHALAXMI	11KV	KHAJRANA(R)	CHQ	05.04.2019	17:00:00	17:15:00	0:15:00	FOR CRP ON & OFF PROBELM WORK BY STM.	SE CITY	AE(Maint.)	NO	0.56	SAIKRUPA, RAMKRUSHAN BAG, YADAV SHOW ROOM AND MR-10 ETC.
17	INDORE CITY	EAST	MAHALAXMI	11KV	SUNCITY	CHQ	05.04.2019	17:15:00	17:30:00	0:15:00	FOR CRP ON & OFF PROBELM WORK BY STM.	SE CITY	AE(Maint.)	NO	0.7	SUNCIT COLONY
18	INDORE CITY	WEST	PAGNISPAGA	11 KV	PIPLIBAZAR	CHQ	05.04.2019	6:30:00	7:00:00	0:30:00	FOR 315 KVA X-MER REPLACEMENT WORK AT RAJWADA GOPAL MANDIR	SE CITY	AE(Maint.)	NO	0.5	Pipli Bazar, Ram Laxman Bazar, Yasoda Mata Mandir, Imambada, Gopal Mandir Nakoda Tower, Samona Corner, Atala Bazar,
19	INDORE CITY	North	33/11 Sector E	11 KV	11 KV Sagar Feeder	CHQ	05.04.2019	6:00:00	6:15:00	0:15:00	For Connection Connected Work of HT Hariram Uttam Chand	SE CITY	AE(Maint.)	NO	0.5	releted area