

M.P.P.K.V.V. C. LTD. INDORE CIRCLE																	
S.N o	Name of Circle	NAME OF DIVISION	Name of EHV S/s or 33/11 KV S/s	Line KV Capacity (33 or 11)	Name of 33 KV / 11 KV feeder	Group (for 33KV) / Category (for 11 KV)	Date of Planned Shutdown	Planned shutdown		Total Duration	Reason for Planned Shutdown (Maintenance/Erection work/ FSP / Safety purpose etc.)	Shutdown Approved by -	Approval Granted to-	Alternate Supply Arrangements are available or not (Yes/No)	Demand in MW affected due to Shutdown.		Areas affected
								Duration of									
								From	to								
1	INDORE CITY	North	33/11 KV VIJAY NAGAR	11 KV	11 KV SCHEME NO. 54	CHQ	05.01.2018	10:00:00	12:30:00	2:30:00	LINE MAINTENANCE & TREE CUTTING & STC TEAM WORK	SE CITY	AE(Maint.)	No	1		Vijay Nagar, Nyay Nagr puliya, Vishwanand Multi, Shalimar bungalow, Hira Nagar thana, Sundar Nagar, MR-10, Marthoma School, COCONUT APARMENT
2	INDORE CITY	North	33/11 KV KHATIPURA	11 KV	11 KV SECTOR D	CHQ	05.01.2018	13:30:00	13:50:00	0:20:00	FOR FIALED TRANSFORMER REPLACEMENT WORK (AMERGENCY PLANNED	SE CITY	AE(Maint.)	No	0.7		Sector D.& Shukla brothers khett
3	INDORE CITY	North	33/11 KV VIJAY NAGAR	11 KV	11 kv MAIN NO. 1	CHQ	05.01.2018	9:00:00	9:20:00	0:20:00	FOR VCB WORK BY STM TEAM	SE CITY	AE(Maint.)	No	0.9		11 KV 54 & SUKHLIYA
4	INDORE CITY	North	33/11 KV 114	33 KV	33 KV MANGLIYA I/C	VIII	05.01.2018	15:30:00	16:30:00	1:00:00	FOR CT REPLACEMENT WORK	SE CITY	AE(Maint.)	No	1.5		
5	INDORE CITY	North	33/11 KV ELECTRONIC COM	5 MVA	5 MVA PTR NO. 3	_	05.01.2018	17:00:00	17:30:00	0:30:00	FOR VCB WORK BY STM TEAM	SE CITY	AE(Maint.)	No	1		CLERK COLONY & READYMED & EC-1
6	INDORE CITY	South Division	Indracomplex	11 kv	Shankar bagh	CHQ	05.01.2018	6:30:00	7:00:00	0:30:00	11 kv Feeder O/G side Isolator r-phase clamp & Male female contect replacement work	SE CITY	AE(Maint.)	No	0.8		Shankar Bagh ,Kalali Mohalla , Dhobi Ghat
7	INDORE CITY	EAST	SATYA SAI	11KV	BCM HEIGHT , MEGHDOOT & VELOCITY.	CHQ	05.01.2018	7:00:00	8:00:00	1:00:00	11KV MAIN NO.2 INCOMMING INSULATCOR RED HOT ATTEND WORK.	SE CITY	AE(Maint.)	No	1		ADARSH MEGHDOOT NAGAR, MR-9 , SOLANKI NAGAR , SHRDHA SHRI AND PRIYADARSHNI COLONY,BCM HIGHTS , JAIN MANDIR , SHEETAL NAGAR AND RAHIL INTERPRISES,MAHIDPUR WALA, VELLOCITY SINEMA AND MAHAK VATIKA, ARAWAL SHOW ETC.
8	INDORE CITY	EAST	SATYA SAI	11KV	PRESS COMPLEX OLD	CHQ	05.01.2018	8:00:00	8:30:00	0:30:00	Y PHASE CT RED HOT ATTEND WORK.	SE CITY	AE(Maint.)	No	0.8		DEWAS NAKA , DOORSANCHAR, ORBITE MALL AND PU-4 ETC.
9	INDORE CITY	EAST	VANDNA NGR.	11KV	VANDNA NGR.	CHQ	05.01.2018	10:00:00	10:30:00	0:30:00	11KV MAIN NO.2 CT RED HOT ATTEND WORK.	SE CITY	AE(Maint.)	No	0.7		SWARN VATIKA , PARICHARIKA NAGAR, GEETA NAGAR , PADMAVATI COLON AND GIRDHAR NAGAR ETC.
10	INDORE CITY	EAST	MAHALAXMI	33KV	8MVA POWER X-MER	_	05.01.2018	7:30:00	7:50:00	0:20:00	8MVA POWER X-MER NO.2 OIL TOPPING WORK BY STM.	SE CITY	AE(Maint.)	No	1.2		11KV TULSI NAGAR FEEDER AFFECTED.
11	INDORE CITY	EAST	MAHALAXMI	33KV	10MVA POWER X-MER	_	05.01.2018	7:50:00	8:10:00	0:20:00	10MVA POWER X-MER NO.4 OIL TOPPING WORK BY STM.	SE CITY	AE(Maint.)	No	1.5		11KV GOYAL AVENUE & NIPANIYA FEEDER AFFECTED.
12	INDORE CITY	Central	220 KVA South Zone	33KV	Rau	VIII	05.01.2019	13:00	14:00	01:00	Due to CT Replacement work by STM	SE CITY	AE(Maint.)	yes	-		3 no No Area Affected
13	INDORE CITY	Central	Silicon City	11KV	PTR no 1 8 MVA	_	05.01.2019	14:30	14:50	00:20	PTR Oil Leakage Work by STM	SE CITY	AE(Maint.)	yes	-		11 KV Feeder Chang Over
14	INDORE CITY	WEST	GANDHI NAGAR	11 KV	BUDHANIYA	CHQ	05.01.2019	10:00:00	12:00:00	2:00:00	FOR DTR CHARGING WORK AT RAM NAGAR BY IPDS	SE CITY	AE(Maint.)	NO	0.8		Nandbag, Rakhi Nagar, High Link Rejensi, Bhanwar Seth, Charch,
15	INDORE CITY	WEST	SANGAM NAGAR	11 KV	KAVERI NAGAR	CHQ	05.01.2019	10:00:00	12:00:00	2:00:00	FOR DTR CHARGING WORK AT RAM NAGAR BY IPDS	SE CITY	AE(Maint.)	NO	0.9		Sch. No. 51 Mim. Area, Rajput Wala, Shubham Nagar, Kavery Nagar, Mama Patty, Leck Palace, Garib Nawaj, Mahavir Nagar, Saket Dham, Shrinath Vihar, Shubham Palace, Kedar Nagar, Poonam Wala.