| | INDORE | |
|--|--------|--|
| | | |

| S.No Name of Circle 1 INDORE CITY 2 INDORE CITY 3 INDORE CITY | NAME OF DIVISION | Name of EHV S/s or 33/11 KV S/s | Line KV Capacity | Name of 33 KV / 11 KV feeder | Group (for 33KV) / Category (for 11 | Date of Planned Shutdown | | tion of | Total | 24.07.2019 Reason for Planned Shutdown | Shutdown | Approval | Alternate Supply | It has been | Demand in MW | Remark(Areas | |
|--|---------------------|------------------------------------|---------------------|-----------------------------------|--|-----------------------------|-------|-------------|----------|---|----------|-------------|------------------|-------------|-----------------|-------------------|---|
| 1 INDORE CITY 2 INDORE CITY 3 INDORE | | 55/11 RV 5/5 | (00 44) | | | | | | Duration | (Maintenance/Erection work/ FSP / Safety | Approved | Granted to- | Arrangements are | Reported on | affected due to | affected) | Remark(Areas affected) |
| 2 INDORE CITY | | Pragati nagar | 11 kv | Siddhipuram & prabhu nagar | CHQ | 24.07.2019 | 07:00 | to 10:00 | 03:00 | Due to Tree Cutting & line Maintenance Work | SE CITY | AE(Maint.) | NO | Yes | 0.65 | PAPER DECLARED | Vaishlai nagar, Ahilya nagar, Braj Vihar, Siddhipuram, ,Vigyan Nagar, Prabhu nagar, Saraswati Nagar, Silver AUX, umesh nagar & |
| 3 INDORE | Central | Bijalpur | 11 kv | Mundi & Setelight | CHQ | 24.07.2019 | 07:00 | 10:00 | 03:00 | Due to Tree Cutting & line Maintenance Work | SE CITY | AE(Maint.) | NO | Yes | 0.6 | PAPER DECLARED | ETC Setelight Town Ship, Haidary Town Ship, Maskin E Sefiya, Shivala Part 1 & 2 Gram Bilawali, New Bijalpur & Mundi |
| | Central | Pragati nagar | 11 kv | Parmanu nagar | CHQ | 24.07.2019 | 07:00 | 10:00 | 03:00 | 4 Span Conductor Stringing & Mid Span pole Erection Work Near Ahilya nagar Under IPDS | SE CITY | AE(Maint.) | NO | Yes | 0.65 | PAPER DECLARED | Cat road, Pragati nagar, Krishna nagar, parmanu nagar, HT Conn, parmanu Rahwasi Sangh & Etc |
| 4 INDORE CITY | Central | Rajmohalla | 33KV | Gumasta nagar Zonal | CHQ | 24.07.2019 | 12:00 | 13:00 | 01:00 | Due to New HT Conn. Gurukripa Confencry.Charging Work | SE CITY | AE(Maint.) | Yes | Yes | NIL | | No Area Affected |
| 5 INDORE CITY | Central | Gumasta nagar | 11 kv | IDA-2 | CHQ | 24.07.2019 | 12:00 | 12:30 | 00:30 | Due to Sefty Perpose For 33 KV Gumasta nagar Zonal For New HT Conn. | SE CITY | AE(Maint.) | NO | No | 0.5 | | Area Affected Releted to this Feeder |
| 6 INDORE CITY | Central | Rau | 11 kv | Pidamber Rural | CHQ | 24.07.2019 | 06:00 | 06:20 | 00:20 | Due to VCB Tasting Work by STM | SE CITY | AE(Maint.) | NO | no | 0.5 | | Maa Padmawati Colony, Shri Krishna Peradise Phase 1 & 2 & ETC |
| 7 INDORE CITY | Central | Rau | 11 kv | RANGWASA | СНО | 24.07.2019 | 13:00 | 13:30 | 00:30 | 100 KVA FAILD DTR REPLECMENT WORK NEAR SHAYAM SANGAM | SE CITY | AE(Maint.) | NO | no | 0.5 | | shayam sangam, cat raod, tezar fentacy, surya mandir |
| 8 INDORE CITY | Central | 132/33 KV RAU | 33KV | Panther | VIII | 24.07.2019 | 05:30 | 05:45 | 00:15 | Due to Bas Bar I/C Side Red Hot Work at Housing Board Grid | SE CITY | AE(Maint.) | Yes | Yes | NIL | | No Area Affected |
| 9 INDORE CITY | Central | Pragati nagar | 11 kv | Main no 2 | CHQ | 24.07.2019 | 06:00 | 06:15 | 00:15 | Due to Isolator Red hot Work at Grid | SE CITY | AE(Maint.) | NO | No | 0.85 | | 11 KV parmanu nagar, Buddha nagar, Sudama nagar, Pragati nagar, D-Mart,IDA-135 Affected |
| 10 INDORE CITY | Central | Annapurna | 11 kv | paraspar Nagar & Dasharamaidan | CHQ | 24.07.2019 | 06:20 | 06:40 | 00:20 | Due to Isolator Red hot Work at Grid | SE CITY | AE(Maint.) | NO | No | 0.65 | | Area Affected Releted to this Feeder |
| 11 INDORE CITY | EAST | MANORAMAGAN J | 11 kv | KHAJRANA | CHQ | 24.07.2019 | 06:30 | 10:00 | 03:30 | line maintenance & tree cutting work | SE CITY | AE(Maint.) | NO | Yes | 0.5 | PAPER DECLARED | GEETA BHAVAN , SHEKH HATIM HOSPITAL, GATER KAILASH AND PWD OFFICE ETC. |
| 12 INDORE CITY | EAST | MANORAMAGAN J | 11 kv | TILAK NAGAR | CHQ | 24.07.2019 | 06:30 | 10:00 | 03:30 | line maintenance & tree cutting work | SE CITY | AE(Maint.) | NO | Yes | 0.5 | PAPER DECLARED | SEVA SARDAR NAGAR, BADI GWAL TOLI , CHOKSI LAB AND SHANTI NAGAR ETC. |
| 13 INDORE CITY | EAST | K.E.H. | 11KV | МҮН | CHQ | 24.07.2019 | 08:00 | 08:30 | 00:30 | for ct replacemaint work. | SE CITY | AE(Maint.) | Yes | Yes | NIL | | nil |
| 14 INDORE CITY | EAST | GOYAL NGR. | 11KV | GOYAL VIHAR. | CHQ | 24.07.2019 | 08:50 | 09:20 | 00:40 | for vcb on & off problem work by stm | SE CITY | AE(Maint.) | NO. | Yes | 0.5 | | RADHA KRUSHAN COLONY , MAHARASHTRA BANK , SHAHNAI 2 AND PREM BANDHAN GARDEN ETC |
| 15 INDORE CITY | EAST | BTC | 33KV | MG-1 (INCOMMING FEEDER) | CHQ | 24.07.2019 | 09:30 | 10:00 | 00:30 | for ct replacemaint work. | SE CITY | AE(Maint.) | NO. | Yes | 0.85 | | BTC GRID. |
| 16 INDORE CITY | North | 33/11 kv mahakal | 11 kv | 11 kv Mehandi Pur balaji | CHQ | 24.07.2019 | 06:30 | 10:00 | 03:30 | line maintenance & tree cutting work | SE CITY | AE(Maint.) | NO | Yes | 0.5 | PAPER DECLARED | MAHIDPUR BALAJI AREA |
| 17 INDORE CITY | North | 33/11 kv Eectronic com | 11 kv | 5 mva ptr no 3 | CHQ | 24.07.2019 | 08:30 | 09:30 | 01:00 | for PTR Maintenance work by stm team | SE CITY | AE(Maint.) | NO | Yes | 0.65 | | 11 kv Ec- 1 & readymed Com & clrek colony |
| 18 INDORE CITY | North | 33/11 kv Kabit Khedi | 11 kv | 11 kv Chandra Gupt | CHQ | 24.07.2019 | 11:00 | 11:30 | 00:30 | for CT replacement work by stm team | SE CITY | AE(Maint.) | NO | Yes | 0.45 | | MR-10 Sukhliya C Sector |
| 19 INDORE CITY | South Division | Tejaji nagar | 11 kv | Anuradha nagar | CHQ | 24.07.2019 | 07:00 | 10:00 | 03:00 | 4 no. Pole Erection & 3 span Gaurding work near annuradha nagar Under IPDS | SE CITY | AE(Maint.) | Nil | Yes | 0.65 | PAPER DECLARED | Anuradha nagar , by pass square, |
| 20 INDORE CITY | South Division | Mehhanic Nagar | 11 kv | Aditya Nagar | CHQ | 24.07.2019 | 07:00 | 09:00 | 02:00 | Tree cutting & line maintenance | SE CITY | AE(Maint.) | No | Yes | 0.8 | PAPER DECLARED | ADITYA NAGAR ,MECHANIC NAGAR , GURUDWARA , D MIGRO . |
| 21 INDORE CITY | South Division | Mayur nagar | 11 kv | Dhanlaxmi | CHQ | 24.07.2019 | 07:00 | 10:00 | 03:00 | 6 No. Pole Erection work near udhog nagar Under IPDS | SE CITY | AE(Maint.) | No | Yes | 0.75 | PAPER DECLARED | BALAJI UDYOG,SUMIT PULSES,MAYUR NAGAR,RIDDHI SIDDHI |
| 22 INDORE CITY | South Division | Navlakha | 11 kv | Main no.1 | CHQ | 24.07.2019 | 06:00 | 06:30 | 00:30 | 11 kv main no.1 B-phase CT clamp red hot work | SE CITY | AE(Maint.) | No | Yes | 0.76 | | Mahadev dal mil, 62 prakash nagar, 107 prakash nagar, b-5 shiv kripa colony, sajan nagar dal mil, kalyan dal mil, brejhashwari tower, kk udyog nagar, kalyan dal mill ke pass |
| 23 INDORE CITY | South Division | Daily College | 11 kv | Main no. 1 | СНО | 24.07.2019 | 06:30 | 07:00 | 00:30 | 11 kv Musakhedi feeder Y-phase CT clamp red hot work | SE CITY | AE(Maint.) | No | Yes | 0.48 | | MITTAL ATA CHAKKI,OLD JAIL,GOL CHOURAHA, JEMS OXFORD SCHOOL , Bheel Colony,99 Moosakhedi Main Road, North Moosakhedi, Azad Nagar Kali Pulia |
| 24 INDORE CITY | South Division | Daily College | 11 kv | Main no. 3 | CHQ | 24.07.2019 | 07:00 | 07:20 | 00:20 | 11 kv feeder O/C side Isolator B- phase clamp red hot work | SE CITY | AE(Maint.) | NO | Yes | 0.56 | | 11 kv feeder Stadium , Industrial |
| 25 INDORE CITY | South Division | Daliy College | 11 kv | Residency | CHQ | 24.07.2019 | 07:00 | 07:20 | 00:20 | 11KV ME red hot work At S/s | SE CITY | AE(Maint.) | No | Yes | 0.49 | | Residancy water tank, pwd cothy st, colactor niwas, jim khana, |
| 26 INDORE CITY | South Division | Palda Industrial | 11 kv | Main no. 2 | CHQ | 24.07.2019 | 07:30 | 08:00 | 00:30 | 11 kv feeder Y,B-phase CT clamp red hot work | SE CITY | AE(Maint.) | No | Yes | 0.84 | | 11 kv Khandel wal , Vinayak , Kalindi feeder |
| 27 INDORE CITY | South Division | Sabji mandi | 11 kv | Main no. 4 | СНО | 24.07.2019 | 09:00 | 09:30 | 00:30 | 11 kv Main no.4 Bas Cupler R-phase Isolator clamp red hot work | SE CITY | AE(Maint.) | No | Yes | 0.82 | | 11 kv Pawanputra nagar ,Bjjalpur ,Gayatri nagar feeder |
| 28 INDORE CITY | South Division | Sabji mandi | 33 kv | Narang cold stores O/G | CHQ | 24.07.2019 | 17:00 | 17:30 | 00:30 | 33 kv VCB trip test work by STM | SE CITY | AE(Maint.) | Yes | Yes | Nil | | Nil |
| 29 INDORE CITY | South Division | Sabji Mandi | 11 kv | Gayatri Nagar | CHQ | 24.07.2019 | 18:00 | 18:30 | 00:30 | 11 kv feeder VCB not proper on/off scada control panel work by STM | SE CITY | AE(Maint.) | No | Yes | 0.72 | | 11 kv Gayatri nagar feeder |
| 30 INDORE CITY | South Division | New Rani Bag | 11KV | Feeder No. 3 | СНО | 24.07.2019 | 15:00 | 15:30 | 00:30 | 11 kv feeder VCB not proper on/off scada control panel work by STM | SE CITY | AE(Maint.) | No | Yes | 0.82 | | Feeder No. 3 |
| 31 INDORE CITY | Division | Palda Industrial | 33 kv | Palda Industrial O/G | СНQ | 24.07.2019 | 13:00 | 13:30 | 00:30 | HT Consumer M/S. S.K. Enterprises ME Replacement work | SE CITY | AE(Maint.) | Yes | Yes | Nil | | Nil |
| 32 INDORE CITY | South Division | Indira Complex | 33 kv | O.P.H. O/G | CHQ | 24.07.2019 | 07:00 | 08:00 | 01:00 | 33 kv feeder Red hot work attend | SE CITY | AE(Maint.) | Yes | Yes | Nil | | Nil |
| 33 INDORE CITY | WEST | CITY CONTROL ROOM | 33KV | 33 KV CITY -1 | СНО | 24.07.2019 | 05:30 | 05:45 | 00:15 | FOR VCB INCOMING OUTGOING CLAMP RED HOT.(NO EFFECTED) | SE CITY | AE(Maint.) | Yes | Yes | 0.65 | | Remark(Areas affected) |
| 34 INDORE CITY | WEST | CITY CONTROL ROOM | 33KV | 33 KV CITY -2 | СНО | 24.07.2019 | 05:45 | 06:00 | 00:15 | FOR VCB INCOMING OUTGOING CLAMP RED HOT.(NO EFFECTED) | SE CITY | AE(Maint.) | Yes | Yes | 0.5 | | Remark(Areas affected) |
| 35 INDORE CITY | WEST | CHOTA BANGARDA | 11 kv | PADMALAY | CHQ | 24.07.2019 | 09:00 | 09:15 | 00:15 | FOR R & Y Phase CT CLAMP RED HOT. | SE CITY | AE(Maint.) | NO | Yes | 0.4 | | PADMALAY AREA |