

M.P.P.K.V.V. C. LTD. INDORE CIRCLE																				
S.No	Name of Circle	NAME OF DIVISION	Name of EHV S/s or 33/11 KV S/s	Line KV Capacity (33 or 11)	Name of 33 KV / 11 KV feeder	Group (for 33KV) / Category (for 11KV)	Planned shutdown			DATE- 13.11.2019			Reason for Planned Shutdown (Maintenance/Erection work/ FSP / Safety purpose etc.)	Shutdown Approved by -	Approval Granted to-	Alternate Supply Arrangements are available or not (Yes/No)	It has been Reported on Whatsapp Group	Demand in MW affected due to Shutdown.	Remark(Areas affected)	Remark(Areas affected)
							Date of Planned Shutdown	Duration of to	Total Duration											
1	INDORE CITY	EAST	MANORAMAGANJ	11KV	TELEPHONE EXCHANGE 2	CHQ	12.11.2019	6:30	9:00	2:30		TREE CUTTING & JUMPER TIGHT ATTEND WORK.	SE CITY	AE(Maint.)	NO	YES	0.5		KANCHANBAG, VISHESH HOSPITAL, NATHMANDIR AND HIGH COURT ETC.	
2	INDORE CITY	EAST	BTC	11KV	BASKET BALL	CHQ	12.11.2019	12:00	13:00	1:00		FOR HT CONSUMERS ME REPLACEMAIN WORK FROM CRICKET MATCH.	SE CITY	AE(Maint.)	NO	YES	0.45		AGRAWAL STORE, DM TOWER, CARE WELL HOSPITAL AND VIKAS PRADHIKARN	
3	INDORE CITY	North	132 kv Satya Sai	33 kv	33 kv Vandana Nagar	CHQ	12.11.2019	8:30	11:00	2:30		line Maintenance & Tree Cutting work	SE CITY	AE(Maint.)	YES	YES	NIL		1 HT Consumer Affected	
4	INDORE CITY	WEST	220KV NORTH ZONE	33KV	IND-A	CHQ	13.11.2019	7:00	7:15	0:15		I/C ISOLATER RED HOT WORK	SE CITY	AE(Maint.)	YES	YES	NIL		NIL	
5	INDORE CITY	WEST	CITY CONTROL ROOM	11 KV	8MVA-3	CHQ	13.11.2019	6:00	6:30	0:30		Y-PHASE CT O/G CLAM RED HOT WORK	SE CITY	AE(Maint.)	NO	YES	0.5		11KV POLOGRAUND1 &2, IT BUILDING	
6	INDORE CITY	WEST	CITY CONTROL ROOM	11 KV	5MVA-2	CHQ	13.11.2019	6:35	6:50	0:15		VCB Y-PHASE POLE O/G RED HOT WORK	SE CITY	AE(Maint.)	NO	YES	0.5		11KV SHIV VILASH, SANWER ROAD	
7	INDORE CITY	WEST	GANDHINAGAR	11 kv	MAIN-1	CHQ	13.11.2019	9:00	10:00	1:00		I/C ISOLATER R-PHASE REPLACEMENT WORK	SE CITY	AE(Maint.)	No	YES	0.79		11KV GANDHI NAGAR, BHANGDA, DENTAL COLLAGE	
8	INDORE CITY	WEST	GANDHINAGAR	11KV	MAIN-2	CHQ	13.11.2019	10:00	11:00	1:00		I/C ISOLATER R-PHASE REPLACEMENT WORK	SE CITY	AE(Maint.)	No	YES	0.64		11KV BUDHANIA, BORIYA	
9	INDORE CITY	WEST	SEC-A	11KV	MAIN-3	CHQ	13.11.2019	7:20	7:40	0:20		R-PHASE CT JUMPER RED HOT WORK	SE CITY	AE(Maint.)	No	YES	0.45		11KV SEC-A, AWANTIKA NAGAR	
10	INDORE CITY	WEST	SEC-A	11KV	GOVIND NAGAR KHARCHA	CHQ	13.11.2019	7:45	8:00	0:15		R-PHASE CT OIL LEAKAGE WORK	SE CITY	AE(Maint.)	No	YES	0.5		GOVIND NAGAR KHARCHA AREA	
11	INDORE CITY	Central	Gumasta nagar	11 KV	Dwarkapuri	CHQ	13.11.2019	8:00	11:00	3:00		Pole Shifting Work Under 5 % Supervision Contractor Acharya at Dwarkapuri Colony AND POST MONSOON MAINTENANCE BY AE HTM	SE CITY	AE(Maint.)	No	YES	0.5		Dwarkapuri. Footi kothi.Vikram Square, Sch no 71, Footi kothi Square,	
12	INDORE CITY	Central	Gumasta nagar	11 KV	IDA-1	CHQ	13.11.2019	6:15	6:35	0:20		Due to O/G Side Isolator Red hot Work	SE CITY	AE(Maint.)	No	YES	0.45		Sch no 71, GNT Market, Meckenic Nagar, HT Conn, Verma union Hospital.Hindusthan Petroleum. & ETC	
13	INDORE CITY	Central	Footi Kothi	11 KV	Main no 2	CHQ	13.11.2019	7:00	7:20	0:20		Due to B Phase CT Red Hot Work At grid	SE CITY	AE(Maint.)	No	YES	0.5		11 KV Prajapat nagar & Gwala Colony& Parivahan Nagar Affected	
14	INDORE CITY	Central	Footi Kothi	11 KV	Vidur Nagar	CHQ	13.11.2019	8:00	11:00	3:00		2 No. DTR Installation & Charging Work at Vidur nagar Under IPDS	SE CITY	AE(Maint.)	No	YES	0.45	Paper Declared	Vidur nagar, Rishi palace, Aastha Palace, Chaoudhary market & ETC	
15	INDORE CITY	Central	Rajendra nagar	11 KV	Annapurna	CHQ	13.11.2019	8:00	11:00	3:00		2 No. DTR Installation & Charging Work at Dhanvantri nagar Under IPDS	SE CITY	AE(Maint.)	No	YES	0.5	Paper Declared	rajendra nagar, Dhanvantri nagar, Woman Collage.Takshila parisar & ETC	
16	INDORE CITY	Central	Rau	11 KV	Rangwasa	CHQ	13.11.2019	8:00	11:00	3:00		3 No. Pole Erection & Structure Fitting Renovation DTR At Rau Industrial Area Under IPDS	SE CITY	AE(Maint.)	No	YES	0.65	Paper Declared	Rau Industrial Area, Cancer Hospital. Dehri Area & ETC	
17	INDORE CITY	Central	Revenue nagar	11 KV	Vishvkarma nagar	CHQ	13.11.2019	8:00	11:00	3:00		2 No. DTR Charging & Jumper Work at Near Bank Colony Narendra Tiwari marg Under IPDS	SE CITY	AE(Maint.)	No	YES	0.75	Paper Declared	Vishvkarma nagar, Bank Colony, nnarendra Tiwari marg & ETC	
18	INDORE CITY	Central	Navda panth	11 KV	City IP	CHQ	13.11.2019	8:00	11:00	3:00		4 No. Pole Erection & 2 No. DTR Charging Work att Gram bank basti Under IPDS	SE CITY	AE(Maint.)	No	YES	0.5	Paper Declared	Gramm Bank, Gram Sinhasa,Dhar Road, Sirpur, NH-59 IND-AHMD	
19	INDORE CITY	Central	Nagin nagar	11 KV	Rani palace	CHQ	13.11.2019	8:00	11:00	3:00		Due to Guarding &2 No. DTR Charging Work Diamond Palace Under IPDS	SE CITY	AE(Maint.)	No	YES	0.65	Paper Declared	Rani palace, Ambar nagar, Daimond palace & Etc	
20	INDORE CITY	North	33/11 kv Vijay nagar	11 KV	11 kv Sukhliya	CHQ	13.11.2019	11:00	11:30	0:30		for IPDS work	SE CITY	AE(Maint.)	NO	YES	0.65		Sukhliya, Bapat Chouraha, Nursing collage, Hotel Ambrocia, Sch.No.54 Vijay Nagar, Barod Hospital,	
21	INDORE CITY	North	33/11 kv kabit Khedi	11 KV	11 kv Shyam nagar	CHQ	13.11.2019	12:00	12:30	0:30		for IPDS work	SE CITY	AE(Maint.)	NO	YES	0.75		Shyam Nagar, MR-10 Road, Lavkush vihar, Jineshwar School, Sabri nagar sabji mandi, Bandhan Garden	
22	INDORE CITY	North	132 kv Electronic com	33 kv	33 kv ESI 2nd	CHQ	13.11.2019	8:30	11:00	2:30		line Maintenance & Tree Cutting work	SE CITY	AE(Maint.)	YES	YES	NIL		Only HT Consumer	
23	INDORE CITY	North	33/11 kv Vijay nagar	33 kv	33 kv MPSRTC 1st	CHQ	13.11.2019	8:30	11:00	2:30		line Maintenance & Tree Cutting work	SE CITY	AE(Maint.)	YES	YES	NIL		NIL	
24	INDORE CITY	North	33/11 kv Vijay nagar	11 KV	11 kv Scheme no. 78	CHQ	13.11.2019	7:00	7:20	0:20		B-phase CT Clamp red hot work	SE CITY	AE(Maint.)	NO	YES	0.56		Schm.No.78, Prestige Public school	
25	INDORE CITY	North	33/11 kv Scheme no. 136 1st	11 KV	11 kv Feeder no 3	CHQ	13.11.2019	14:30	14:50	0:20		Y-phase o/g ME Red hot work	SE CITY	AE(Maint.)	NO	YES	0.5		SCH.NO. 136 AREA	
26	City circle	South Division	Navlakha	11 kv	Navlakha no.1 & 2	CHQ	13.11.2019	7:00	9:00	2:00		Tree cutting and LINE Mantinance work	SE CITY	AE(Maint.)	NO	YES	0.89		navlakha no 1 & 2 feeder	