

M.P.P.K.V.V. C. LTD. INDORE CIRCLE																
S.No	Planned shutdown															
	Name of Circle	NAME OF DIVISION	Name of EHV S/s or 33/11 KV S/s	Line KV Capacity (33 or 11)	Name of 33 KV / 11 KV feeder	Group (for 33KV) / Category (for 11 KV)	Date of Planned Shutdown	Duration of		Total Duration	Reason for Planned Shutdown (Maintenance/Erection work/ FSP / Safety purpose etc.)	Shutdown Approved by -	Approval Granted to-	Alternate Supply Arrangements are available or not (Yes/No)	Demand in MW affected due to Shutdown.	Areas affected
1	Indore city	EAST	TUKOGANJ	11KV	PTR NO.2 MAIN	-	03.01.2019	07:30:00	08:00:00	00:30:00	PTR NO. 2 RED HOT ATTEND WORK	SE CITY	AE(Maint.)	yes	NIL	NO FEEDER EFFECTED
2	Indore city	EAST	SANJNA PARK	11KV	10 MVA PTR	-	03.01.2019	08:00:00	08:15:00	00:15:00	PTR NO. 10 OIL DOPING WORKBY STM	SE CITY	AE(Maint.)	No	2	11KV SANJANA PARK, MILAN HIGHT
3	Indore city	EAST	SANCHAR NGR.	11KV	3.15 MVA PTR	-	03.01.2019	09:00:00	09:15:00	00:15:00	PTR NO. 10 OIL DOPING WORKBY STM	SE CITY	AE(Maint.)	ves	NIL	CHANGE OVER AVAILABLE
4	Indore city	South Division	Karbala	11 kv	8 MVA no.	CHQ	03.01.2019	07:00:00	07:20:00	00:20:00	Power transformer Oil Topping work by STM	SE CITY	AE(Maint.)	No	0.73	11 Kv Prem Nagar ,Triveni , Collector Feeder
5	Indore city	South Division	Mechanic Nagar	33 kv	Rajendra nagar O/G	CHQ	03.01.2019	15:30:00	15:50:00	00:20:00	33 kv O/G feeder Tripping test work by STM	SE CITY	AE(Maint.)	No	0.49	Khatiwala tank Grid & 11 kv feeders
6	Indore city	South Division	Palda	11 kv	Vinayak	CHQ	03.01.2019	07:30:00	08:00:00	00:30:00	For line jumper work	SE CITY	AE(Maint.)	No	0.4	Industrial Area
7	Indore city	NORTH	33/11KV ESI	11KV	BIMA HOSPITSL	CHQ	03.01.2019	07:30:00	07:45:00	00:15:00	ME RED HOT ATTEND WORK	SE CITY	AE(Maint.)	No	0.65	ES.I.Hospita, Suyash vihar colony App ghar
8	Indore city	NORTH	33/11KV ELECTRONIC COM.	11KV	ELEC.COM.-1	CHQ	03.01.2019	07:00:00	07:15:00	00:15:00	BREAKER RED HOT WORK	SE CITY	AE(Maint.)	No	0.5	Nanda nagar, Ankosh system,
9	Indore city	NORTH	33/11KV SCH.NO.114	11KV	PTR NO.1 MAIN	CHQ	03.01.2019	10:00:00	10:15:00	00:15:00	BUS CUPLAR RED HOT ATTEND WORK	SE CITY	AE(Maint.)	No	1	11KV 114,AHILYA NAGAR,LAL BANGLA,SANT NAGAR, LAL BANGLO
10	Indore city	NORTH	33/11KV ELECTRONIC COM.	11KV	BHAGIRATHPURA	CHQ	03.01.2019	10:30:00	10:45:00	00:15:00	STAY ATTEND WORK	SE CITY	AE(Maint.)	No	1	Bhagirathpura, Rafeli, Shiv mandir, Tal wala, Sai mandir, Chirad mohalla, Nai basti, Redwal colony,
11	Indore city	Central	220 KVA South Zone	33KV	Rau	VIII	03.01.2019	09:30:00	10:00:00	00:30:00	Due to Streightning of Cut Point channalwitch was acidently damage vehcle at Rajiv Ghandi Square	SE CITY	AE(Maint.)	YES	-	No Area Affected
12	INDORE CITY	WEST	SECTOR-A	11 KV	MAIN NO.3(SECTOR-A+AVANTIKA NAGAR	CHQ	03.01.2019	6:30:00	7:15:00	0:45:00	FOR IN GRID 11KV MAIN R PAHSE AND 11KV SECTOR-A Y PAHSE OUTGOING ISOLATOR + ME R AND Y PHASE CLAMP RED HOT POINT ATTEND WORK	SE CITY	AE(Maint.)	NO	1.2	All LT Consumer & Mungad Alu, Meta Tubey, Sciye Line, Indore Naitred, Quajer Eng., Ast Vinayak, Tirupati Printo Pek, Rajput Ind. +All LT Consumer , Awantika Nagar, Fairdeal, Krishna Industri, Modi Industri, Shiva Industri, Sugandha Nagar, Agarbatti Complex
13	INDORE CITY	WEST	SECTOR-A	33 KV	INDUSTRIYAL -A	CHQ	03.01.2019	7:15:00	7:45:00	0:30:00	FOR IN GRID B PHASE CT CALMP RED HOT POINT ATTEND WORK	SE CITY	AE(Maint.)	yes	-	SUPPLY CHANGE OVER