

M.P.P.K.V.V. C. LTD. INDORE CIRCLE																		
S.No	Name of Circle	NAME OF DIVISION	Name of EHV S/s or 33/11 KV S/s	Line KV Capacity (33 or 11)	Name of 33 KV / 11 KV feeder	Group (for 33KV) / Category (for 11 KV)	Date of Planned Shutdown	Planned shutdown		Total Duration	Reason for Planned Shutdown (Maintenance/Erection work/ FSP / Safety purpose etc.)	Shutdown Approved by -	Approval Granted to-	Alternate Supply Arrangements are available or not (Yes/No)	Demand in MW affected due to Shutdown.		Areas affected	REMARK
								Duration of Planned From	to									
1	INDORE CITY	South Division	Mechanic Nagar	11 kv	Main no. 1	CHQ	04.03.2019	06:45:00	07:00:00	00:15:00	11 kv feeder ME / CT / Isolator clamp red hot work	SE CITY	AE(Maint.)	No	0.85		11 kv Aditya nagar & Sidharth Nagar feeder or related Area	