

M.P.P.K.V.V. C. LTD. INDORE CIRCLE																			
S.N o	Name of Circle	NAME OF DIVISION	Name of EHV S/s or 33/11 KV S/s	Line KV Capacity (33 or 11)	Name of 33 KV / 11 KV feeder	Group (for 33KV) / Category (for 11 KV)	Planned shutdown			DATE- 21.10.2019			Shutdown Approved by -	Approval Granted to-	Alternate Supply Arrangements are available or not (Yes/No)	It has been Reported on Whatsapp Group	Demand in MW affected due to Shutdown.	Remark(Are as affected)	Remark(Areas affected)
							Date of Planned Shutdown	Duration of From	to	Total Duration	Reason for Planned Shutdown (Maintenance/Erection work/ FSP / Safety purpose etc.)								
1	INDORE CITY	North	132 KV CHAMBAL	33 KV	33 KV MG-1&2	CHQ	21.10.2019	07:00	08:00	01:00	1 No mid Span pole erection For Cable support of SHELBY HOSPITAL	SE CITY	AE(Maint.)	YES	Yes	Nil		HT CONSUMER AFFECTED	
2	INDORE CITY	North	132 KV CHAMBAL	33 KV	33 KV MALTI	CHQ	21.10.2019	07:00	11:00	04:00	LINE MAINTENANCE & TREE CUTTING WORK	SE CITY	AE(Maint.)	YES	Yes	Nil		HT CONSUMER AFFECTED	
3	INDORE CITY	North	33/11 kv shilnath	11 kv	11 KV OVER BRIDGE	CHQ	21.10.2019	08:00	09:00	01:00	FOR SAFETY PURPOSE WORK ON 33KV MALTI	SE CITY	AE(Maint.)	NO	Yes	0.45		Bhandari bridge, Vallabh Nagar, Adarsh Tailor, New Dewas road, Gokuldas Compound, Pardeshipura thana, Rajkumar sabji mandi & Bridge	
4	INDORE CITY	North	33/11 kv shilnath	11 kv	11 KV SHIVAJI NAGAR	CHQ	21.10.2019	08:00	09:00	01:00	FOR SAFETY PURPOSE WORK ON 33KV MALTI	SE CITY	AE(Maint.)	NO	Yes	0.5		Shivaji nagar, Jeevan ki fel, Sigma school,	
5	INDORE CITY	WEST	PAGNISPAGA	11 KV	MAIN NO 1	CHQ	21.10.2019	06:00	06:20	00:20	11 KV HARSIDDI FEEDER I/C CLAM RED HOT WORK AT GRID	SE CITY	AE (HTM)	NO	YES	0.9		11 KV HARSIDDI AND PIPLI BAJAR	
6	INDORE CITY	WEST	SANGAM NAGAR	11 KV	MAIN NO 2	CHQ	21.10.2019	06:30	07:30	01:00	I/C ISOLATOR RED HOT AND 11 KV MAIN VCB POLE RED HOT WORK	SE CITY	AE (HTM)	NO	YES	0.8		11 KV ARODRUM 1 AND 2 AND SUBHASH MARG 1	
7	INDORE CITY	WEST	GANDHI NAGAR	11 KV	BORIYA AND BANGARDA	CHQ	21.10.2019	07:20	07:50	00:30	I/C ISOLATOR RED HOT AND 11 KV BANGARDA Y PH ME CLAMP RED HOT WORK	SE CITY	AE (HTM)	NO	YES	0.7		BORIYA AND BANGARDA	
8	INDORE CITY	EAST	220KV - B.MARDAN	33KV	SANJNA PARK GRID	CHQ	21.10.2019	06:30	10:30	04:00	FOR GRID MAINTENANCE WORK.	SE CITY	AE(Maint.)	NO.	YES	0.45		SANJNA PARK GRID	
9	INDORE CITY	EAST	220KV - B.MARDAN	33KV	SHALIMAR PLAM GRID	CHQ	21.10.2019	06:30	10:30	04:00	FOR GRID MAINTENANCE WORK.	SE CITY	AE(Maint.)	NO.	YES	0.5		SHALIMAR PLAM GRID	
10	INDORE CITY	EAST	SC.NO.134	11KV	SECTOR-C	CHQ	21.10.2019	09:00	11:00	02:00	TREE CUTTING & MAINTENANCE WORK.	SE CITY	AE(Maint.)	NO.	YES	0.35		SCETOR C AND SCHME NO. 134	
11	INDORE CITY	EAST	SC.NO.140 TANKI WALA	11KV	CHUGH REALITY	CHQ	21.10.2019	10:00	10:30	00:30	FOR CT RED HOT ATTEND WORK.	SE CITY	AE(Maint.)	NO.	YES	0.9		CHUGH REALITY	
12	INDORE CITY	Central	Pragati Nagar	11 KV	Parmanu nagar	CHQ	21.10.2019	08:00	11:00	03:00	Due to 02. no DTR Charging & Jumper Work At Parmanu nagar Under IPDS & Line maintenance Work	SE CITY	AE(Maint.)	NO.	YES	0.45	Paper Declared	Sanjay nagar Gram Bijalpur & Etc	
13	INDORE CITY	Central	Gumasta Nagar	11 KV	Gumasta nagar	CHQ	21.10.2019	08:00	11:00	03:00	Due to Tree Cutting & Line Maintenance Work	SE CITY	AE(Maint.)	NO.	YES	0.5		Gumasta nagar Area	
14	INDORE CITY	Central	Footi kothi	11 KV	Ahirkhedi	CHQ	21.10.2019	08:00	11:00	03:00	Due to Guarding & 3 No. Pole Erection Work At ahirkhedi kakad & Village Under IPDS	SE CITY	AE(Maint.)	NO.	YES	0.65	Paper Declared	Ahirkhedi Area	
15	INDORE CITY	Central	Rau	11 KV	Pigdamber IP & Rural	CHQ	21.10.2019	08:00	11:00	03:00	Due to Double ckt for conductor/jumpher DTR charging work at padmawati Colony Under IPDS	SE CITY	AE(Maint.)	NO.	YES	0.5		Pigdamber ip , rural area	
16	INDORE CITY	Central	Silicon City	11 KV	PTR No.-1	CHQ	21.10.2019	06:30	07:30	01:00	Due to PTR Post Monsoon maintenance Work By STM	SE CITY	AE(Maint.)	No	YES	0.95		11 kv Feeder No. -1 & 2	
17	INDORE CITY	Central	Silicon City	11 KV	PTR No.-2	CHQ	21.10.2019	07:30	08:30	01:00	Due to PTR Post Monsoon maintenance Work By STM	SE CITY	AE(Maint.)	No	YES	0.74		11 kv Feeder No. -3	
18	INDORE CITY	Central	Silicon City	11 KV	PTR No.-3	CHQ	21.10.2019	08:30	09:30	01:00	Due to PTR Post Monsoon maintenance Work By STM	SE CITY	AE(Maint.)	No	YES	0.68		11 kv Feeder No. -4 & 5	
19	INDORE CITY	South Division	220 kv South zone	33 kv	Rau & Sabjimandi	CHQ	21.10.2019	10:00	13:00	03:00	ME Charging at Rajivgandhi square M/s Atal Indore city Transport	SE CITY	AE(Maint.)	Yes	YES	Nil		Nil	
20	INDORE CITY	South Division	Sabji mandi	11 kv	AB Road & Pipliya Pala	CHQ	21.10.2019	10:00	13:00	03:00	Safety purpose (ME Charging at Rajivgandhi square M/s Atal Indore city Transport )	SE CITY	AE(Maint.)	No	YES	0.25		AB Road & Pipliya pala Feeder	
21	INDORE CITY	WEST	AIRPORT	11KV	8MVA NO.2	CHQ	21.10.2019	12:30	13:00	00:30	FOR VCB TRIP TEST WORK BY STM TEAM.	SE CITY	AE(Maint.)	No	YES	0.45			
22	INDORE CITY	WEST	SANGAM NAGAR	11KV	AERODRUM-2	CHQ	21.10.2019	14:00	14:30	00:30	FOR VCB TRIP TEST WORK BY STM TEAM.	SE CITY	AE(Maint.)	No	YES	0.35		11Aerodrum feeder related area.	
23	INDORE CITY	WEST	SANGAM NAGAR	11KV	SUBHASH MARG- 1	CHQ	21.10.2019	15:00	15:30	00:30	FOR VCB TRIP TEST WORK BY STM TEAM.	SE CITY	AE(Maint.)	No	YES	0.25		11kv Subhash Marg.1 feeder related area.	
24	INDORE CITY	WEST	SANGAM NAGAR	11KV	RAMBALI NAGAR	CHQ	21.10.2019	15:30	16:00	00:30	FOR VCB TRIP TEST WORK BY STM TEAM.	SE CITY	AE(Maint.)	No	YES	0.35		11kv Rambali nagar feeder related area.	
25	INDORE CITY	North	33/11 KV setelite	11 KV	11 kv ro house	CHQ	21.10.2019	16:30	17:00	00:30	FOR VCB TRIP TEST WORK BY STM TEAM.	SE CITY	AE(Maint.)	No	Yes	0.65		Ro-house Area	
26	INDORE CITY	North	33/11 KV setelite	11 KV	11 kv Magar Kheda	CHQ	21.10.2019	17:00	17:30	00:30	FOR VCB TRIP TEST WORK BY STM TEAM.	SE CITY	AE(Maint.)	No	Yes	0.7		Magar Kheda area	
27	INDORE CITY	North	33/11 KV setelite	11 KV	11 kv main	CHQ	21.10.2019	17:30	18:00	00:30	FOR VCB TRIP TEST WORK BY STM TEAM.	SE CITY	AE(Maint.)	No	Yes	0.5		11kv feeder-1	