

M.P.P.K.V.V. C. LTD. INDORE CIRCLE																		
S.N o	Name of Circle	NAME OF DIVISION	Name of EHV S/s or 33/11 KV S/s	Line KV Capacity (33 or 11)	Name of 33 KV / 11 KV feeder	Group (for 33KV) / Category (for 11 KV)	Date of Planned Shutdown	Planned shutdown			DATE- 01.11.2019							
								Duration of to	Total Duration	Reason for Planned Shutdown (Maintenance/Erection work/ FSP / Safety purpose etc.)	Shutdown Approved by -	Approval Granted to-	Alternate Supply Arrangements are available or not (Yes/No)	It has been Reported on Whatsapp Group	Demand in MW affected due to Shutdown.	Remark(Are as affected)	Remark(Areas affected)	
1	INDORE CITY	South Division	Palda Industrial	33 kv	Palda Industrial I/C	CHQ	01.11.2019	6:00	6:30	0:30	33 kv feeder ME B-phase Bushing Oil Leverages & Red hot work attend at Yard	SE CITY	AE(Maint.)	Yes	Yes	Nil		Nil
2	INDORE CITY	South Division	University	11 kv	Bas bar & 11 kv Main no. 1	CHQ	01.11.2019	6:30	7:00	0:30	main no. 1 R-phase CT Clamp red hot & Bas side Isolator clamp red hot work at yard	SE CITY	AE(Maint.)	NO	Yes	1.36		Ganesh Nagar, Filter Plant, Ekta Nagar, Sodnam Dhaba, Soniya Gandhi Nagar, Rahul Gandhi Nagar, Ganesh Nagar-1, Jeet Nagar, Jeet Nagar-2, Kamdhenu Park Colony-1 , Nanak Nagar, 1shivam Nagar, 94 Shivam Nagar, Soyabeen Anusandhan Kendra, 301/1 Pipliya Rao, Tulsi Jai Singhani,
3	INDORE CITY	South Division	Univercity	11 kv	Khandwa naka	CHQ	01.11.2019	7:00	7:30	0:30	11 kv feeder Y-phase CT clamp red hot work at yard	SE CITY	AE(Maint.)	No	Yes	0.64		SOYABEAN CENTER, NANAK NAGAR, 1SHIVAM NAGAR,
4	INDORE CITY	South Division	Indira Complex	11 kv	Indira Complex	CHQ	01.11.2019	7:30	8:00	0:30	11 kv feeder Y-phase ME Clamp red hot work at yard	SE CITY	AE(Maint.)	No	Yes	0.68		Janki nagar, opp vishal tower-1,opp vishal tower-2, indira complex, opp krishna hostel, krishna boys hostel
1	INDORE CITY	North	33/11 KV NIRANJANPUR	11 kv	11 KV EWS FEEDER	CHQ	01.11.2019	8:00	8:40	0:40	FOR TAKING VCB IN CIRCUIT	SE CITY	AE(Maint.)	No	Yes	0.45		NIRANJANPUR & LAHIYA COLONY