					Dlama	ed shutdown			M.P.P.K.V	V. C. LTD. IN	DORE CIRCI	.E		I		
S.N Name of	NAME OF DIVISION	Name of EHV S/s or 33/11 KV S/s	Line KV Capacity (33 or 11)	Name of 33 KV / 11 KV feeder	Group (for 33KV) / Category (for 11 KV)	Date of Planned	Duratio: From	to Dura	Reason for Planned Shutdown (Maintenance/Erection	Shutdown Approved by	Approval Granted to-	Alternate Supply Arrangements are available or not (Yes/No)	It has been Reported on Whatsapp Group	Demand in MW affected	Remark(Are	Remark(Areas affected)
1 INDORE CITY	Central	Nagin nagar	11 kv	Rani palace	CHQ				Due to 2 No DTD Changing & Lumpsing Work at	SE CITY	AE (HTM)	No	YES	1.34	Paper Declared	Rani palace, Ambar nagar,Daimond palace, Sirpur kakad & ETC
2 INDORE CITY	Central	Footi kothi	11 kv	Vidur nagar	CHQ	01.10.2019	8:00 1	1:00 3:	Due to 4 No. Bala Francisco 8 3 Const Coundrator	SE CITY	AE (HTM)	No	YES	0.76	Paper Declared	CAT Road, Rishi Palace, Digvijay Multi, hawabangla Road & Etc
3 INDORE CITY	Central	Rau	11 kv	Rau-2	CHQ	01.10.2019	8:00 1	1:00 3:	Due to 3 No. Pole Erection &4 Span Counductor Stringing Work at RauShramik Colony,Saria Ward Under IPDS	SE CITY	AE (HTM)	No	YES	0.53	Paper Declared	Shramik Colony, Saria Ward, Swastik Vihar, Kanha Park, Cancerr Hospital, Cat Road & ETC,
4 INDORE CITY	Central	Bijalpur	11 kv	Sanjay nagar	CHQ	01.10.2019	8:00 1	1:00 3:	Due to 3 No. Pole Erection & 2 No. DTR Charging, at Jitu Patwari ji Office,Soni garden,Bijalpur Mini School For Under IPDS	SE CITY	AE (HTM)	No	YES	0.68	Paper Declared	Sanjay nagar, Grma Bijalpur, & ETC
5 INDORE CITY	Central	Pragati nagar	11 kv	Main no 1	CHQ	01.10.2019	16:00 1	5:30 0::	Due to CT Replacement Work by STM	SE CITY	AE (HTM)	No	YES	0.72		11 kv Prabhu nagar & Siddhipuram Affected
6 INDORE CITY	Central	Rajendra nagar	11 kv	Main no 1	CHQ	01.10.2019	11:15 1	2:15 1:0	Due to AB Swicth Male ,Female Replacement Worl	SE CITY	AE (HTM)	No	YES	0.7		takshila parisar, Dhanvantri nagar, Rajendra nagar, Waman Polotecnic Collage ,Rajendra nagar Naka, Narang Cold Storage, Bhim nagar, Durga nagar & ETC
7 City Indore	North	33/11 kv Vijay nagar	11 kv	11 kv Scheme No. 78	CHQ	01.10.2019	8:00 1	1:00 3:	for Feeder Bifurcation work near scheme no.78 by STC Team	SE CITY	AE (HTM)	No	YES	0.45		Schm.No.78, Prestige Public school
8 City Indore	North	33/11 kv Vijay nagar	33 kv	33 kv Scheme no. 78 1st & 2nd	CHQ	01.10.2019	10:00 1	1:00 1:	for Safety Purpose work on 11kv scheme No.78	SE CITY	AE (HTM)	No	YES	0.5		33/11 kv Scheme No 78 Grid Affected
9 City Indore	North	220KV NORTH ZONE	33 kv	33KV SEC-C	CHQ	01.10.2019	17:00 1	7:30 0::	NEW HT CONNECTION JUMFER WORK OF NAROLI STEEL	SE CITY	AE (HTM)	YES	YES	NIL		15 HT CONSUMER
10 INDORE CITY	WEST	132 NORTH ZONE	33KV	33KV SANGAM NAGAR-2	CHQ	01.10.2019	6:00	:30 0::	FOR 33KV SANGAM NAGAR-02 BUSBAR ISOLATOI REPAIR WORK.	SE CITY	AE (HTM)	YES	YES	NIL		NIL
11 INDORE CITY	WEST	PAGNIS PAGA	11KV	PIPLI BAZAR, HARSIDDHI	CHQ	01.10.2019	7:00 7	:30 0:	FOR 11KV PIPLI BAZAR O/G ISOLATOR MAINTENANCE WORK	SE CITY	AE (HTM)	No	YES	0.45		Harsidhi Bagicha & Main Road, Kadav Ghat, Matan Market, Shakil Sabji Wala, Ghoda Gali, Tokni Wala, RamLaxman Bazar, Pipli Bazar, Nakoda Tower, Samosa Corner, ImamBada, Niharpura, Sarvate Complex, Gopal Tempal, Atala Bazar.
12 INDORE CITY	WEST	PAGNIS PAGA	11KV	MOTI TABELA	CHQ	01.10.2019	7:00 7	:30 0::	FOR SAFETY PURPOSE WORK ON 11KV PIPLI BAZAR	SE CITY	AE (HTM)	No	YES	0.25		MOTI TABELA RELATED AREA.
13 INDORE CITY	South Division	Indracomplex	11 kv	Shankar bagh	CHQ	01.10.2019	6:00	:30 0::	B-phase CT clamp red hot work at yard	SE CITY	AE (HTM)	No	YES	0.43		Shankar Bagh ,Kalali Mohalla , Dhobi Ghat
14 INDORE CITY	South Division	Indira Complex	33 kv	Main no.2	CHQ	01.10.2019	6:30 7	:00 0:	11 kv main no.2 Bas coupler R-phase Isolator clamp red hot work at Yard	SE CITY	AE (HTM)	No	YES	0.76		11 kv T.S. no.1 & 2 feeder or Area
15 INDORE CITY	South Division	Sabji mandi	11 kv	Bijalpur feeder	CHQ	01.10.2019	8:00	:00 1:	2 No. Pole Erection work by Kshema power Under IPDS at Bijalpur	SE CITY	AE (HTM)	No	YES	0.84		bijalpur area, ab road , Tejpur gadbadi
16 INDORE CITY	South Division	Palda industrial	11 kv	Nayta Mundla	CHQ	01.10.2019	8:00 1	2:00 4:	3no. Pole Erection work By Kshema power Under IPDS at Naayta munlda village	SE CITY	AE (HTM)	No	YES	1.23	Paper Declared	Nayta Mundla Feeder
17 INDORE CITY	South Division	Palda industrial	11 kv	Kalindi feeder	CHQ	01.10.2019	14:00 1	7:00 3:	6 no. Pole Erection work By Kshema power Under IPDS at Klindi town areas	SE CITY	AE (HTM)	No	YES	1.18	Paper Declared	Kalindi Feeder
18 INDORE CITY	South Division	Univercity	11 kv	Indrapuri	CHQ	01.10.2019	12:30 1	3:00 0::	VCB Trip test work by STM	SE CITY	AE (HTM)	No	YES	0.62		Water tank, monica plaza, 329 indrapuri colony, 299 indrapuri colony,
19 INDORE CITY	South Division	Univarcity	11 kv	Ekta Nagar	CHQ	01.10.2019	13:00 1	3:30 0::	VCB Trip test work by STM	SE CITY	AE (HTM)	No	YES	0.49		Ekta nagar , Ring road Kushwaha ka bagicha , Shri yantra nagar , Sant nagar
20 INDORE CITY	South Division	Univarcity	11KV	Anand nagar	CHQ	01.10.2019	13:30 1	4:00 0::	VCB Trip test work by STM	SE CITY	AE (HTM)	No	YES	0.73		Asharam Chouraha,Devi Ahiliya Hospital.45/B Durga Niwas,Takkar Niwas,Sakshi Bhavan
21 INDORE CITY	South Division	Palda Industrial	11 kv	10 mva no. 2	CHQ	01.10.2019	15:00 1	5:30 0:	PTR Oil Leackage checked by STM	SE CITY	AE (HTM)	No	YES	1.2		11 Kv Khandelwal , Kalindi , Vinayak Feeder
22 INDORE CITY	South Division	Sabji mandi	11 kv	5 MVA no.1	CHQ	01.10.2019	8:30	:00 0::	PTR Oil Topping & Maintenance work by STM	SE CITY	AE (HTM)	No	YES	0.76		11 Kv Rajendra Nagar , Lokmanya Nagar Feeder
23 INDORE CITY	South Division	Sabji mandi	11 kv	5 MVA no.2	CHQ	01.10.2019	9:30 1	0:30 1:	PTR Oil Topping & Maintenance work by STM	SE CITY	AE (HTM)	No	YES	1.58		11 Kv Manik bagh & Machenic nagar Feeder
24 INDORE CITY	South Division	Sabji mandi	11 kv	5 MVA no. 3	CHQ	01.10.2019	10:30 1	1:30 1:	PTR Oil Topping & Maintenance work by STM	SE CITY	AE (HTM)	No	YES	0.75		11 kv AB road & Pipliyapala feeder
25 INDORE CITY	South Division	Sabji mandi	11 kv	8 MVA no. 4	CHQ	01.10.2019	12:00 1	3:00 1:	PTR Oil Topping & Maintenance work by STM	SE CITY	AE (HTM)	No	YES	1.32		Pawanputra , Gayatri , Bijalpur areas
26 INDORE CITY	EAST	132 KV CHAMBAL	33KV	MG-1	CHQ	01.10.2019	6:30 8	:30 2:	TREE CUTTING & LINE MAINTENANCE WORK	SE CITY	AE (HTM)	YES	YES	NIL		NIL
27 INDORE CITY	EAST	KHAJARNA GRID	11KV	KHJARANA GRID	CHQ	01.10.2019	9:30 1	0:30 1:	ISOLATOR AND VCB MAINTENANCE WORK	SE CITY	AE (HTM)	No	YES	0.65		11KV BANGLI & GANESH MANDIR FEEDER