

M.P.P.K.V.V. C. LTD. INDORE CIRCLE																			
Sl.No	Name of Circle	NAME OF SUBSTATION	Name of HTD S/S or 33/11 KV S/S	Live KV Capacity (L3 or L1)	Name of 33 KV / 11 KV feeder	Planned shutdown			DATE: 14.10.2019			Reason for Planned Shutdown (Maintenance/Erection work/ TSP / Safety purpose etc.)	Shutdown Approved by	Approval Granted to	Alternate Supply Arrangements are available or not (Yes/No)	It has been Reported on Whatsapp Group	Demand in MW affected due to Shutdown.	Remark(s)on affected	Remark(s)on affected
						Group (for 33KV / 11KV)	Date of (Planned) Shutdown	Duration of Planned From To	Total Duration										
1	INDORE CITY	WEST	CITY CONTROL ROOM	11KV	RAJWADA	CHQ	14.10.2019	9:00	12:00	3:00	FOR 8 NO. POLE ERECTION WORK AT SADAR BAZAR UNDER IPDS.	SE CITY	AE (HTM)	No	Yes	0.45	Paper Declared	Deelip Singh Colony, Mamta Deyari, Chedilad Dubey Road, Alpaha, Sadar Bazar Water Tank, Bhishni Mohalla, Juna Rinala, Aman Chouk, Sikandrabad Colony, Dhoobi Ghat, Abhiya Paltan, Kamuniv Hat, Bura Kabhritan.	
2	INDORE CITY	WEST	CITY CONTROL ROOM	11KV	IMLI BAZAR	CHQ	14.10.2019	9:00	12:00	3:00	FOR 4 NO. POLE ERECTION WORK AT BARATHI MOHALLA UNDER IPDS.	SE CITY	AE (HTM)	No	Yes	0.35	Paper Declared	First Batsalyan, Bachi Bag Ex. Mahua Gun, Sadar Bazar, Abhiya Paltan, Bajriya, Imli Bazar, Duth Chouraha, Bhoi Mohalla, Sansara Collage, Rambag, Subhash Chouk, Kunwar Mandli, Bachha Hanuman.	
3	INDORE CITY	WEST	SANGAM NAGAR	11KV	AIRDURUM-02	CHQ	14.10.2019	9:00	12:00	3:00	FOR AB SWITCH WORK AT BADORIYA DTR UNDER IPDS.	SE CITY	AE (HTM)	No	Yes	0.25	Paper Declared	Nandbag, Rakhi Nagar, High Link Rejensi, Bhanwar Seth, Charch.	
4	INDORE CITY	WEST	CITY CONTROL ROOM	11KV	TILAKPATHI	CHQ	14.10.2019	9:00	12:00	3:00	FOR 8 SPAN CONDUCTOR STRINGING WORK AT MAMA BHANJI KI DARGIA UNDER IPDS.	SE CITY	AE (HTM)	No	Yes	0.35	Paper Declared	GPH Compound, Swadesh Press, Narayan Bagh, Malhar Aashram, Chandan Apart., Panth Vaid Colony, Jatti Colony, Tapasya Apart., Etc.	
5	INDORE CITY	WEST	UNSI HAT	11KV	LOHAR PATTI-02	CHQ	14.10.2019	12:30	13:00	0:30	FOR VCB WORK BY STM.	SE CITY	AE (HTM)	No	Yes	0.6		11KV LOHAR PATTI FEEDER RELATED AREA.	
6	INDORE CITY	WEST	UNSI HAT	11KV	GOKARJUND	CHQ	14.10.2019	13:00	13:30	0:30	FOR VCB WORK BY STM.	SE CITY	AE (HTM)	No	Yes	0.98		Juni Hot Ground, Gajal Hotel, TV Hospital, Mahant Complex, Tamboli Bakhal, Cenra Bank, Gorakbund Chouraha, Murla Tea, Madhuri Sadi, Junaush Mata Mandir, Pambha Electrical.	
7	INDORE CITY	WEST	UNSI HAT	33KV	33KV SANGAM NAGAR-1	CHQ	14.10.2019	13:30	14:00	0:30	FOR CT TEST WORK BY STM.	SE CITY	AE (HTM)	No	Yes	0.8		33KV SANGAM NAGAR FEEDER RELATED AREA.	
8	INDORE CITY	WEST	UNSI HAT	33KV	33KV M.P. NAGAR	CHQ	14.10.2019	14:30	15:00	0:30	FOR VCB WORK BY STM.	SE CITY	AE (HTM)	No	Yes	0.9		Nil.	
9	INDORE CITY	WEST	UNSI HAT	33KV	33KV PTR NO.-3	CHQ	14.10.2019	14:30	15:00	0:30	FOR VCB WORK BY STM.	SE CITY	AE (HTM)	No	Yes	0.9		Nil.	
10	INDORE CITY	Central	Nagin Nagar	11 KV	Rani palace	CHQ	14.10.2019	08:00	11:00	3:00	Due to Gaurling & 2 No.DTR charging work at rani palace Under IPDS.	SE CITY	AE (HTM)	No	Yes	0.6	Paper Declared	Rani palace,Ambar nagar, Diamond palace, & ETC.	
11	INDORE CITY	Central	Rajendra Nagar	11 KV	Annapurna	CHQ	14.10.2019	08:00	11:00	3:00	2 No. DTR installation & Charging Work at Near rajendra nager railway Crossing Under IPDS.	SE CITY	AE (HTM)	No	Yes	0.8	Paper Declared	Takshila purisar: Woman Polotecnick Collage, Dhanvantri nagar, rajendra nagar & Etc.	
12	INDORE CITY	Central	Ahirkhedi	11 KV	Vidar nagar	CHQ	14.10.2019	08:00	11:00	3:00	Due to 3 No.DTR installation & charging Work at Rishi palace Under IPDS.	SE CITY	AE (HTM)	No	Yes	0.6	Paper Declared	Cat Road, Ritshi Palace, Digvijay Mulhy, Hawabangla Road & Etc.	
13	INDORE CITY	Central	Navda panth	11 KV	Sinhasa IP	CHQ	14.10.2019	08:00	11:00	3:00	4 No. pole erection Baah basti pole erection, nafens hackery, jawahar tekri Under IPDS.	SE CITY	AE (HTM)	No	Yes	0.4	Paper Declared	Dhar Road, Gram Sinhasa , Gram bank, NH-59 IND-AHMD & Etc.	
14	INDORE CITY	Central	Bijapur	11 KV	Sanjay nagar	CHQ	14.10.2019	08:00	11:00	3:00	3 No. pole erection & 4 Span conductor stringing Work /Jtu patwari j office road, shri krishna mandir bijapur under IPDS.	SE CITY	AE (HTM)	No	Yes	0.6	Paper Declared	Sanjay nagar Gram Bijapur & Etc.	
15	INDORE CITY	Central	Bijapur	32 kv	rajendra nagar o/g	CHQ	14.10.2019	16:30	17:00	0:30	vcb testing work TSG.	SE CITY	AE (HTM)	Yes	Yes	-		Nil.	
16	INDORE CITY	Central	Revenue Nagar	11 KV	Vishwakarma Nagar	CHQ	14.10.2019	08:00	11:00	3:00	3 No. Pole erection & 2 No. DTR augmentation at Vishwakarma nagar Under IPDS.	SE CITY	AE (HTM)	No	Yes	0.7	Paper Declared	Vishwakarma nagar, bank Colony narendra tiwari marg	
17	INDORE CITY	Central	Rajmohalla	11 KV	Jawahar marg-1	CHQ	14.10.2019	08:00	10:00	2:00	Due to Smart City Work For Line Shifting by IMC.	SE CITY	AE (HTM)	No	Yes	0.8	Paper Declared	South raj Mohalla, North Raj Mohalla, Bivabani, Malgani Square & Etc.	
18	INDORE CITY	Central	Rajmohalla	11 KV	Maharajani	CHQ	14.10.2019	08:00	10:00	2:00	Due to Smart City Work For Line Shifting by IMC.	SE CITY	AE (HTM)	No	Yes	0.5		Bivabani , jaganpuri Para, Prem Kumar Hospital & Etc.	
19	INDORE CITY	South Division	Sabji Mandi	11 kv	A.B.Road	CHQ	14.10.2019	08:00:00	12:00:00	4:00	Conductor Stringing Structure work by IPDS Scheme at A.B. Road	SE CITY	AE (HTM)	No	Yes	1.69	Paper Declared	Chaitram,vrindawan garden 1,2, m r 3 regional park,	
20	INDORE CITY	South Division	Palda industrial	11 kv	Kalindi feeder	CHQ	14.10.2019	14:00:00	17:00:00	3:00	3 no. Pole Erection work by IPDS scheme at Udhog Nagar area	SE CITY	AE (HTM)	No	Yes	1.42	Paper Declared	Udhog nagar or related area	
21	City circle	South Division	Navlakha	11 kv	Main no. 2	CHQ	14.10.2019	15:30:00	16:00:00	00:30:00	11 kv main no. 2 feeder VCB work by STM	SE CITY	AE (HTM)	No	Yes	0.84		Vidhya nagar & Microwave	
22	City circle	South Division	Sabji Mandi	11 kv	Piplyapala	CHQ	14/10/2019	06:00:00	07:00:00	01:00:00	11 kv feeder R-phase CT clamp red hot work at yard	SE CITY	AE (HTM)	No	Yes	0.52		NEW KISSAN INDUSRIE LAGAN GARDEN, ASHOK PLASTIC KE PASS, piplyapala	
23	City circle	South Division	Sabji mandi	11 kv	Main no. 4	CHQ	14/10/2019	06:00:00	07:00:00	01:00:00	11 kv main no. 4 I/C Isolator clamp & Bas side R-V-phase Isolator clamp red hot work at yard	SE CITY	AE (HTM)	No	Yes	1.2		Bijapur , Gayatri nagar , Pawanputra nagar	
24	City circle	South Division	Sabji mandi	33 kv	Sabji Mandi I/C	CHQ	14/10/2019	07:00:00	07:30:00	00:30:00	33 kv Sabji mandi O/G feeder ME R-phase & V-B-phase Isolator /CT Clamp red hot work at yard	SE CITY	AE (HTM)	Yes	Yes	Nil		Nil	
25	INDORE CITY	North	33/11 kv shivnath	8 MVA	8 MVA PTR	CHQ	14.10.2019	15:00:00	15:30:00	0:30	Y-phase o/g Isolator red hot work	SE CITY	AE (HTM)	No	Yes	0.65		11 kv over Bridge & shivaji nagar & Shivshakti nagar & kulkarni bhatta	
26	INDORE CITY	North	33/11 kv Vijay nagar	11 kv	11 kv Scheme no 7B	CHQ	14.10.2019	08:00:00	11:00:00	3:00	for Feeder Bifurcation work by STC Team	SE CITY	AE (HTM)	No	Yes	0.85		Schm.No.7B, Prestige Public school	
27	INDORE CITY	North	132 KV Electronic com	33 kv	33 kv ESI 1st	VIII	14.10.2019	07:00:00	07:30:00	0:30	line maintenance & tree cutting work jumper cut	SE CITY	AE (HTM)	No	Yes	0.95		scheme no. 136 1st & 2nd & HT Consumer	
28	INDORE CITY	North	132 KV Electronic com	33 kv	33 kv ESI 1st	VIII	14.10.2019	11:00:00	11:30:00	0:30	after work Jumper Connected	SE CITY	AE (HTM)	No	Yes	0.95		scheme no. 136 1st & 2nd & HT Consumer	
29	INDORE CITY	EAST	220KV-B MARDANA	33KV	VANDANA NAGAR - 2	VIII	14.10.2019	06:30:00	10:30:00	4:00	LINE MAINTENANCE & TREE CUTTING WORK	SE CITY	AE (HTM)	YES.	Yes	nil	Paper Declared	WILL BE SUPPLY CHANGEOVER-AVALIBEL	
30	INDORE CITY	EAST	MANORAMANGA VI	11KV	KC2	CHQ	14.10.2019	06:30:00	10:30:00	4:00	DUE TO DOUBLE CIRCUIT WITH VANDANA NAGAR-2	SE CITY	AE (HTM)	NO.	Yes	0.25	Paper Declared	NAV RATAN,WHITEHARCHI, DHAR KOTHI SENT REPHIL SCHOOL, AND MY HOSPITAL ETC.	
31	INDORE CITY	EAST	SATYA SAI	11KV	BMVA POWER X-MER NO.1	CHQ	14.10.2019	08:30:00	09:30:00	01:00:00	BMVA POWER X-MER NO.1 MAINTNANCE WORK BY STM.	SE CITY	AE (HTM)	YES.	Yes	nil	WILL BE SUPPLY CHANGEOVER-AVALIBEL	WILL BE SUPPLY CHANGEOVER-AVALIBEL	
32	INDORE CITY	EAST	SATYA SAI	11KV	BMVA POWER X-MER NO.2	CHQ	14.10.2019	09:30:00	10:30:00	01:00:00	BMVA POWER X-MER NO.2 MAINTNANCE WORK BY STM.	SE CITY	AE (HTM)	YES.	Yes	nil	WILL BE SUPPLY CHANGEOVER-AVALIBEL	WILL BE SUPPLY CHANGEOVER-AVALIBEL	
33	INDORE CITY	EAST	SATYA SAI	11KV	BMVA POWER X-MER NO.3	CHQ	14.10.2019	10:30:00	11:30:00	01:00:00	BMVA POWER X-MER NO.3 MAINTNANCE WORK BY STM.	SE CITY	AE (HTM)	YES.	Yes	nil	WILL BE SUPPLY CHANGEOVER-AVALIBEL	WILL BE SUPPLY CHANGEOVER-AVALIBEL	