

M.P.P.K.V.V. C. LTD. INDORE CIRCLE																			
S.No	Name of Circle	NAME OF DIVISION	Name of EHV S/s or 33/11 KV S/s	Line KV Capacity (33 or 11)	Planned shutdown			DATE- 26.11.2019				Reason for Planned Shutdown (Maintenance/Erection work/ FSP / Safety purpose etc.)	Shutdown Approved by	Approval Granted to-	Alternate Supply Arrangements are available or not (Yes/No)	It has been Reported on Whatsapp Group	Demand in MW affected due to Shutdown.	Remark(Are as affected)	Remark(Areas affected)
					Name of 33 KV / 11 KV feeder	Group (for 33KV) / Category (for 11 KV)	Date of Planned Shutdown	Duration of From	to	Total Duration									
1	INDORE CITY	South	Daily college	33 kv	PTR no.3	CHQ	26.11.2019	8:30	9:30	1:00	Oil Topping & Maintenance by STM	SE CITY	AE(Maint.)	NO	YES	1.23		Industrial & stadium feeder	
2	INDORE CITY	South	Daily college	33 kv	PTR no.2	CHQ	26.11.2019	10:00	11:00	1:00	Oil Topping & Maintenance by STM	SE CITY	AE(Maint.)	No	YES	1.12		PTS & Residency feeder	
3	INDORE CITY	South	Daily college	33 kv	PTR no.1	CHQ	26.11.2019	11:30	12:30	1:00	PTR Maintenance by STM	SE CITY	AE(Maint.)	No	YES	1.09		Azad nagar ,Moosakhedi feeder	
4	INDORE CITY	South	Indra complex	11 kv	main no.2	CHQ	26.11.2019	12:30	13:00	0:30	For VCB Work By STM	SE CITY	AE(Maint.)	No	YES	0.87		shankar bagh & jaora compound	
5	INDORE CITY	South	Indra complex	33 kv	5 mva PTR no.2	CHQ	26.11.2019	13:00	13:30	0:30	For LV side RED hot work by STM	SE CITY	AE(Maint.)	No	YES	0.83		TS no. 1 &2 Feeder	
6	INDORE CITY	South	Indra complex	11 kv	TS no.2	CHQ	26.11.2019	13:30	14:00	0:30	CT Replacement Work By STM	SE CITY	AE(Maint.)	No	YES	0.58		loha mandi , jhatka matan other Area	
7	INDORE CITY	South	Indra complex	11 kv	main no. 1 & Shankar bagh	CHQ	26.11.2019	14:00	15:00	1:00	C.T. & VCB Checked by STM	SE CITY	AE(Maint.)	No	YES	0.68		shankar bagh & Indracomplex	
8	INDORE CITY	South	Indra complex	33 kv	Daily college -2 O/G	CHQ	26.11.2019	15:00	15:30	0:30	C.T. Checked by STM	SE CITY	AE(Maint.)	No	YES	nil		nil	
9	INDORE CITY	South	Machenic nagar	11 kv	5 mva PTR	CHQ	26.11.2019	16:00	16:30	0:30	For PTR "B"Phase HV Side Red hot work by STM	SE CITY	AE(Maint.)	No	YES	1.14		Aditya nagar &Shidharth Nagar Feeder	
10	INDORE CITY	South	Mayur Nagar	11 kv	Main no.1	CHQ	26.11.2019	17:00	17:30	0:30	For VCB Work By STM	SE CITY	AE(Maint.)	No	YES	1.09		Firdosh nagar & Ram nagar feeder	
11	INDORE CITY	North	220KV MANGLIYA	33 kv	33KV RUCHI SOYA	IX	26.11.2019	10:00	10:20	0:20	HPCL WORK, JUMPER DISCONNECT (For M.E. & L.A. Work)	SE CITY	AE(Maint.)	NO	YES	0.68		MANGLIYA	
12	INDORE CITY	North	220KV MANGLIYA	33 kv	33KV RUCHI SOYA	IX	26.11.2019	14:00	14:20	0:20	HPCL WORK, JUMPER RECONNECT	SE CITY	AE(Maint.)	NO	YES	0.68		MANGLIYA	
13	INDORE CITY	North	MANGLIYA	11 kv	11 KV SDA FEEDER	CHQ	26.11.2019	7:00	7:20	0:20	6 Span Conductor Replacement work near Singapur colony Under IPDS WORK JUMPER DISCONNECT	SE CITY	AE(Maint.)	NO	YES	0.58		SDA COMPOUND & L. MORI, 1 NO. DTR affected	
14	INDORE CITY	North	MANGLIYA	11 kv	11 KV SDA FEEDER	CHQ	26.11.2019	10:00	10:20	0:20	6 Span Conductor Replacement work near Singapur colony Under IPDS WORK JUMPER Re- CONNECT	SE CITY	AE(Maint.)	NO	YES	0.58		SDA COMPOUND & L. MORI, 1 NO. DTR affected	
15	INDORE CITY	EAST	TULSI NAGAR	33KV	SAKET GRID	CHQ	26.11.2019	6:30	7:30	1:00	33KV VCB's CT REPLACEMENT WORK.	SE CITY	AE(Maint.)	YES	YES	-		WILL BE SUPPLY CHANGEOVER AVALIBEL	
16	INDORE CITY	EAST	SANJNA PARK GRID	11KV	SANJNA PARK	CHQ	26.11.2019	10:00	11:00	1:00	FOR VCB FAIL CT REPLACEMENT WORK.	SE CITY	AE(Maint.)	NO	YES	0.64		SANJANA PARK COMLETLY	
17	INDORE CITY	EAST	SANJNA PARK GRID	11KV	MILAN HEIGHTS	CHQ	26.11.2019	11:00	11:30	0:30	FOR 11 kv FEEDER ISOLATOR RED HOT ATTEND WORK.	SE CITY	AE(Maint.)	NO	YES	0.65		MILAN HIGHTS	
18	INDORE CITY	WEST	CITY CONTROL ROOM	11KV	URJA PARISAR & I.T. BUIDING	CHQ	26.11.2019	6:00	7:00	1:00	FOR TREE CUTTING WORK IN GPH CAMPUS	SE CITY	AE(Maint.)	NO	YES	0.24		URJA PARISAR & I.T. BUIDING	
19	INDORE CITY	WEST	132 KV CHAMBAL	33 KV	H.T. INDUSTRIAL	CHQ	26.11.2019	13:00	13:30	0:30	FOR JASH PRECION H.T. CONSUMER PDC WORK	SE CITY	AE(Maint.)	NO	YES	0.15		22 NO's H.T. CONSUMER AFFECTED	
20	INDORE CITY	WEST	220 KV NORTH ZONE	33 KV	SANGAM NAGAR- I & II	CHQ	26.11.2019	13:00	13:30	0:30	SAFETY PURPOSE FOR L.T. POLE WORK AT AGARBATTI COMPLEX	SE CITY	AE(Maint.)	NO	YES	-		SUPPLY CHANGE OVER	
21	INDORE CITY	WEST	SECTOR -A	11KV	11 KV MAIN NO. 3	CHQ	26.11.2019	7:30	7:45	0:15	FOR 11 KV MAIN NO.-3 B-PHASE C.T. RED HOT WORK	SE CITY	AE(Maint.)	NO	YES	0.36		SECTOR -A & AVANTIKA	