

M.P.P.K.V.V. C. LTD. INDORE CIRCLE																		
S.N o	Planned shutdown DATE- 16.08.2019										Reason for Planned Shutdown (Maintenance/Erection work/ FSP / Safety purpose etc.)	Shutdown Approved by -	Approval Granted to-	Alternate Supply Arrangements are available or not (Yes/No)	It has been Reported on Whatsapp Group	Demand in MW affected due to Shutdown.	Remark( Areas affected)	Remark(Areas affected)
	Name of Circle	NAME OF DIVISION	Name of EHV S/s or 33/11 KV S/s	Line KV Capacity (33 or 11)	Name of 33 KV / 11 KV feeder	Group (for 33KV) / Category (for 11 KV)	Date of Planned Shutdown	Duration of Planned		Total Duration								
1	INDORE CITY	South	Univarcity	11 kv	Ekta Nagar	CHQ	16.08.2019	07:00	10:00	03:00	3 No's Pole Erection work at Ekta Nagar by Kshama power under IPDS	SE CITY	AE (HTM)	No	Yes	1.78	Paper Declared	Ekta nagar , Ring road Kushwaha ka bagicha , Shri yantra nagar , Sant nagar
2	INDORE CITY	South	Tejaji nagar	11 kv	Anuradha nagar	CHQ	16.08.2019	07:00	10:00	03:00	3 No's Pole Erection work at Anuradha nagar by Kshama power under IPDS	SE CITY	AE (HTM)	No	Yes	1.63	Paper Declared	Anuradha nagar ,khandwa road , ashish nagar
3	INDORE CITY	South	Karbala	11 kv	Prem nagar	CHQ	16.08.2019	07:00	10:00	03:00	3 No's DTR Charging & 5 Span Conductor stringing work Near Prem Nagar area By STC under IPDS	SE CITY	AE (HTM)	No	Yes	1.72	Paper Declared	18 GOPAL BAGH TOWER, LADKANA NAGAR, 55 PREM NAGAR, 2 B PREM NAGAR
4	INDORE CITY	Central	Rajmohalla	33 kv	Rajmohalla-1	CHQ	16.08.2019	10:00	10:30	00:30	Due to 33 KV A.B. Switch Red Hot Work at grid	SE CITY	AE (HTM)	Yes	Yes	-		No Any Area Affected
5	INDORE CITY	Central	Bijalpur	11 kv	Setelight	CHQ	16.08.2019	08:00	11:00	03:00	Due to Tree Cutting & line maintenance Work	SE CITY	AE (HTM)	No	Yes	0.98	Paper Declared	Stelight Town Ship, Haidary Town Ship. Maskin E Sefiya Shivalaya Part-1 & 2 & ETC
6	INDORE CITY	Central	Bijalpur	11 kv	Bilawali	CHQ	16.08.2019	08:00	11:00	03:00	Due to RMU Charging Work By Megawin	SE CITY	AE (HTM)	No	Yes	0.76	Paper Declared	Datt Cold Storage, Mohmmadi Town Ship. Gram Chappri, Sai Paradise, Aananda Colony & ETC
7	INDORE CITY	Central	Rau	11 kv	Rau-1	CHQ	16.08.2019	08:00	09:00	01:00	5 Span Guarding & 1 No. DTR Charging Work at Satsang Bhawan Under IPDS	SE CITY	AE (HTM)	No	Yes	0.45	Paper Declared	Rau Bas Stand, kanupriya Nagar, Hasan ji Nagar, royal Krishna & ETC
8	INDORE CITY	Central	Nagin nagar	11 kv	Nagin nagar	CHQ	16.08.2019	08:00	09:00	01:00	7 Span Guarding & 1 No. DTR Charging Work Near BSF Boundary Under IPDS	SE CITY	AE (HTM)	No	Yes	0.5	Paper Declared	nagin nagar, Ramanand nagar, Ghandi Chook, BSF Boundary & ETC
9	INDORE CITY	WEST	Gandhi Nagar	11 kv	Budhaniya	CHQ	16.08.2019	09:00	10:00	01:00	200 KVA Failed DTR Replacement work Near Nandan Bag	SE CITY	AE (HTM)	NO	YES	0.75	-	Budhaniya
10	INDORE CITY	North	220 KV Mangaliya	33 kv	Mahalaxmi	VIII	16.08.2019	11:00	11:40	00:40	For New HT connection charging work of Zenith exim A.B. Road	SE CITY	AE (HTM)	NO	YES	0.85	-	HT connections in sk compound,sda,sr compound
11	INDORE CITY	North	Vijay Nagar	11 kv	11 kv Old Vijay Nagar	CHQ	16.08.2019	06:30	11:00	04:30	Line Maintenance & Tree Cutting Work	SE CITY	AE (HTM)	NO	YES	0.45	Paper Declared	Area Affected
12	INDORE CITY	North	Electronic Complex	5 MVA	5 MVA PTR No. 3	Nil	16.08.2019	06:00	08:00	02:00	Due to VCB's C.T. Replacement work at S/s By STM	SE CITY	AE (HTM)	NO	YES	0.5	-	Readymade Com & Clrek Colony & EC -1
13	INDORE CITY	North	Vijay Nagar	5 MVA	5 MVA PTR No.3	Nil	16.08.2019	11:00	12:00	01:00	Due to VCB's Pole Replacement work at S/s By STM	SE CITY	AE (HTM)	NO	YES	0.68	-	11KV Rasoma Feeder & Old Vijay Nagar & AB Road
14	INDORE CITY	North	L.I.G.	11KV	11KV Main	CHQ	16.08.2019	08:30	09:00	00:30	Due to VCB's C.T. Replacement work at S/s By STM	SE CITY	AE (HTM)	NO	YES	0.7	-	11KV Industry House & Uttam Bhog & Old Palasiya
15	INDORE CITY	North	MPSRTC	8 MVA	8 MVA PTR No.2	Nil	16.08.2019	09:30	10:30	01:00	Due to VCB's C.T. Replacement work at S/s By STM	SE CITY	AE (HTM)	NO	YES	0.42	-	Shopping Com & Mechanic Nagar & ITI
16	INDORE CITY	North	Khatipura	11KV	11KV Main	CHQ	16.08.2019	12:00	13:00	01:00	Due to VCB's C.T. Replacement work at S/s By STM	SE CITY	AE (HTM)	NO	YES	0.69	-	Khatipura Grid & Sector D & Agrawal Compound
17	INDORE CITY	North	Electronic Complex	33 KV	33 KV ECz & Milk Dairy	Nil	16.08.2019	06:00	08:00	02:00	Due to VCB's C.T. Replacement work at S/s By STM	SE CITY	AE (HTM)	NO	YES	0.5	-	Readymade Com & Clrek Colony & EC -1 & EC -2 & Veena Nagar & Nanda Nagar & Bhagirath Pura & Gauri Nagar
18	INDORE CITY	EAST	SANCHAR NGR.	11KV	DILIP NGR.	CHQ	16.08.2019	10:00	10:30	00:30	200 KVA DTR REPALCEMENT WORK AT MITRA BANDHU NAGAR	SE CITY	AE (HTM)	NO	YES	0.45	-	DILIP NAGAR , MIRTA BANDHU NAGAR AND ADVOCATE NAGAR , SURAJ NAGAR
19	INDORE CITY	EAST	MANORAMAGANJ	11KV	TELEPHONE EXCHANGE1	CHQ	16.08.2019	11:00	11:30	00:30	100 KVA FAILED DTR REPALCEMENT WORK AT OMNI PALACE	SE CITY	AE (HTM)	NO	YES	0.96	-	MEDICAL COLLAGE, RATLAM KOTHI, CRP LINE AND GOKULDAS HOSPITAL ETC.
20	INDORE CITY	EAST	PRESS COMPLEX	11KV	SHREE NAGAR	CHQ	16.08.2019	12:00	12:30	00:30	100 KVA FAILED DTR REPALCEMENT WORK	SE CITY	AE (HTM)	NO	YES	0.7	-	CHAMELI PARK , ARCHANA MEDICAL ,TILAK NAGAR AND VINOBA NAGAR ETC.
21	INDORE CITY	EAST	220KV-B.MARDANA	33KV	VANDANA NAGAR - I	CHQ	16.08.2019	06:30	07:30	01:00	Due to VCB's C.T. Replacement work at S/s By STM	SE CITY	AE (HTM)	NO	YES	0.64	-	WILL BE SUPPLY CHANGEOVER AVALIBEL